

8 July 2025

LGOIMA 25-124



Tēnā koe 

Request for information

Thank you for your request of 9 June 2025, made under the Local Government Official Information and Meetings Act 1987 (LGOIMA – the Act) for the following:

Can you please provide me with the following details for Dates between

1st May – 1st June 2021

1st May – 1st June 2022

1st May – 1st June 2023

1st May – 1st June 2024

1st May – 1st June 2025

If the testing of these substances are not captured between these dates please specify why they were not and the alternative consistent dates they were tested, and provide that data.

The test point location should be clearly identified and an indication that this point remained unfiltered or screened prior to testing. Show where the publicly accessible common tap furthest downstream, from the Water treatment facility while still within the CBD Area (WS) a Surface Water Site (SW) and Well Site (MW) near the Water Treatment Facility.

All data needs to be reported in Micro Grams per Liter ug/L in an editable Excel format


Your request was transferred from South Wairarapa District Council, Porirua City Council, Upper Hutt City Council and Greater Wellington Regional Council to Wellington Water under section 12 of the Act, as we are the lead agency for Wellington's water infrastructure. The response to your questions is available in the appendix on the next page.

Please note that it is our policy to publicly release our responses to official information requests where possible. Our response to your request may be published at <https://www.wellingtonwater.co.nz/about-us/official-requests/official-information-act-responses/> with any personal information removed.

You have the right to seek an investigation and review by the Ombudsman of this decision. Information about how to make a complaint is available at www.ombudsman.parliament.nz or freephone 0800 802 602.

If you wish to discuss this decision with us, please feel free to email us at official.information@wellingtonwater.co.nz

Nāku noa, nā



Acting Group Manager
Treatment and Control Systems

APPENDIX

Sample Point	Supply Component	Parameter Test	Sample Date	Result	Unit of Measure
Kingsley Reservoir	WS	Lead - Acid Soluble	2-May-21	<0.0005	g/m ³
Rahui Flushed	WS	Lead - Acid Soluble	6-May-21	<0.0005	g/m ³
Rahui Unflushed	WS	Lead - Acid Soluble	6-May-21	0.136	g/m ³
Rahui Reservoir Outlet	WS	Lead - Acid Soluble	8-May-21	<0.0005	g/m ³
Karori Flushed	WS	Lead - Acid Soluble	10-May-21	<0.0005	g/m ³
Karori Unflushed	WS	Lead - Acid Soluble	10-May-21	0.0282	g/m ³
Thorndon Flushed	WS	Lead - Acid Soluble	10-May-21	<0.0005	g/m ³
Thorndon Unflushed	WS	Lead - Acid Soluble	10-May-21	0.0326	g/m ³
Wainuiomata Service Centre	WS	Lead - Acid Soluble	12-May-21	<0.0005	g/m ³
Gear Island Treated Water @ Outlet	WS	Lead - Total	14-May-21	<0.001	g/m ³
Gracefield Reservoir	WS	Lead - Acid Soluble	14-May-21	<0.0005	g/m ³
Wainuiomata Treated Water @ Gate House	WS	Lead - Total	14-May-21	<0.001	g/m ³
Waterloo Treated Water @ Outlet	WS	Lead - Total	14-May-21	<0.001	g/m ³
10B Konini Street	WS	Lead - Acid Soluble	16-May-21	<0.0005	g/m ³
Te-Marua Treated Water @ Pumping Station	WS	Lead - Total	19-May-21	<0.001	g/m ³
Kingsley Reservoir	WS	Lead - Acid Soluble	20-May-21	<0.0005	g/m ³
Wainuiomata Reservoir 1	WS	Lead - Acid Soluble	28-May-21	<0.0005	g/m ³
Gracefield Reservoir	WS	Lead - Acid Soluble	30-May-21	<0.0005	g/m ³
Te-Marua Treated Water @ Pumping Station	WS	Lead (Pb)	3-May-23	<0.0005	mg/l
Wainuiomata Treated Water @ Gate House	WS	Lead (Pb)	3-May-23	<0.001	mg/l
Te Marua Treated Water @ Pumping Station	WS	Lead (Pb)	1-May-24	<0.0005	mg/l

Wainuiomata Treated Water @ Gate House Monthly	WS	Lead (Pb)	1-May-24	<0.001	mg/l
Te Marua Treated Water @ Pumping Station	WS	Lead (Pb)	6-May-25	<0.0005	mg/l
Wainuiomata Treated Water @ Gate House Monthly	WS	Lead (Pb)	6-May-25	<0.001	mg/l

PFOA, PFPeA, PFNA, PFHA, PFHxS, M8PFOA, PFBA, PFBS, PFOS, PFAS (Forever Chemicals), Terbutylazine, Atrazine, Triazine, Cyanazine, Desethyl terbutylazine, Nitrogen (Synthetic Nitrates), Asbestos, Protozoa, Organochlorine, Organophosphate, Polysorbate 20, Polysorbate 30, Polysorbate 40, Polysorbate 60, Polysorbate 65 and Polysorbate 80 are not tested for, and are not required to be tested.

Therefore, in accordance with Section 17(e) of the Act we are unable to grant this request as the information does not exist.

Please note, Head of Network Performance Treatment and Control Systems, [REDACTED] is happy to discuss any part of this response or any other questions you may have. Should you want to contact [REDACTED] he is available on [REDACTED] [@wellingtonwater.co.nz](mailto:[REDACTED]@wellingtonwater.co.nz) and [REDACTED].