


Greytown Wastewater Treatment Plant performance - October 2025

Commentary	Items of significance	Current status	
<p>In 2023, Greater Wellington Regional Council issued letters requesting explanations of non-compliance. Wellington Water is implementing the required corrective actions where possible within the plant and resource constraints.</p> <p>The plant is currently non-compliant for effluent quality. The non-compliant parameters are Total Ammonia-Nitrogen and Total Nitrogen. The consented limit allows no more than three non-compliant results within any 12 consecutive monthly tests for either parameter. The Plant has been non-compliant for both parameters since April. While the plant recorded compliant effluent quality results in October, this single month did not bring overall compliance back within the consented limits. The overall compliance has not been within consented limits since April.</p> <p>Capital delivery is with SWDC, major investment is required.</p>	<p>With effect 01 July 2025, SWDC took back ownership of the Capital Delivery Programme and associated projects.</p> <p>Wellington Water submitted a draft growth and capacity study to SWDC in December 2024. SWDC have taken ownership and need to consider the next steps.</p>	Non-compliant	 A solid red circle, likely a status indicator for non-compliance.