

Lake Ferry Wastewater Treatment Plant performance - August 2025

Commentary	Items of significance	Current status	
<p>The new resource consent application was submitted this month. However ongoing work associated with the consent process will be managed by SWDC.</p>	<p>With effect 01 July 2025, SWDC took back ownership of the Capital Delivery Programme and associated projects.</p> <p>Source of current high inflow and infiltration is still not funded for investigation. Peak loads are impacting on the plant's hydraulic capacity, which is likely to adversely affect the WWTP performance and compliance.</p>	<p>Compliant, but with the risks identified below</p>	