

Martinborough Wastewater Treatment Plant performance - September 2025

Commentary	Items of significance	Current status	
GWRC lifted the "To do" Abatement notices, dated 12 May 2025, as a result of the desludging project completion. However, the Wastewater Treatment Plant is still non-compliant for effluent quality. The key quality parameters are Total Ammonia – Nitrogen and Total Nitrogen. Neither can exceed their respective consented limit in more than 4 out of any 12 consecutive monthly test results. Capital delivery is with SWDC, major investment is required.	With effect 01 July 2025, SWDC took back ownership of the Capital Delivery Programme and associated projects. Current plant design is insufficient to avoid non-compliance. WWL submitted a draft growth and capacity study to SWDC in December 2024; SWDC have taken ownership and need to consider the next steps.	Non-compliant	