

Martinborough Wastewater Treatment Plant performance - October 2025

Commentary	Items of significance	Current status	
<p>Greater Wellington Regional Council lifted the "To do" Abatement notices, dated 12 May 2025, as a result of the desludging project completion.</p> <p>The plant recorded compliant effluent quality results in September and October; however, the overall compliance has not been within consented limits since April due to the non-compliant quality parameter for Total Nitrogen. The consented limit is no more than 4 non-compliant results out of any 12 consecutive monthly test result.</p> <p>Capital delivery is with SWDC, major investment is required.</p>	<p>With effect 01 July 2025, SWDC took back ownership of the Capital Delivery Programme and associated projects.</p> <p>Current plant design is insufficient to avoid non-compliance.</p> <p>Wellington Water submitted a draft growth and capacity study to SWDC in December 2024. SWDC have taken ownership and need to consider the next steps.</p>	Non-compliant	