

Moa Point Wastewater Treatment Plant performance - April 2025

Commentary	Discharges	Odour Complaints	Items of significance	Current status	
<p>Daily effluent results are compliant with daily limits. Faecal coliforms remains non-compliant for the 90th percentile limit but trends project this parameter to move into compliance soon.</p>	<p>There were three unconsented discharges via the Long Outfall in April due to wet weather and the reduced treatment capacity of the plant from the clarifier renewal works.</p>	<p>There were 8 odour complaints in April. One relating to Moa Point and seven relating to the Southern Landfill site and Careys Gully Sludge Dewatering plant.</p>	<p>Clarifier #1 Renewal Project: Physical works on the clarifier are progressing well; the project reached a major milestone in April when the replacement main bearing was lifted into position. With two of three clarifiers in operation, processing capacity is reduced.</p> <p>Odour Management System: An investigation is underway into the decreased performance of the chemical scrubber system during the summer months. The plant recorded non-compliant results for Total Reduced Sulphur (TRS) during this period.</p> <p>Community Liaison Group (CLG) Meeting: The annual CLG to report on plant performance and consent compliance to the community on took place on 16 April. The meeting minutes will be available on the Wellington Water website in May for public perusal.</p>	<p>Non-compliant</p>	