

Porirua Wastewater Treatment Plant performance - December 2025

Commentary	Discharges	Odour Complaints	Items of significance	Current status	
<p>The plant is compliant for effluent quality.</p>	<p>No non-compliant discharges in December.</p>	<p>No odour complaints in December.</p>	<p>The Duron UV system fault was rectified in December enabling it to return as the duty system full time with the TAK UV system available as backup during higher flows as per under normal operation.</p> <p>Physical works on the odour control unit (OCU) project are progressing well. This is a major project that will deliver a odour treatment system into the process, of which the plant does not currently have. The OCU project is expected to be completed in June 2026.</p>	<p>Compliant</p>	