

Porirua Wastewater Treatment Plant performance - January 2026

Commentary	Discharges	Odour Complaints	Items of significance	Current status	
<p>The plant is compliant for effluent quality.</p>	<p>No non-compliant discharges in January.</p>	<p>No odour complaints in January.</p>	<p>The Duron UV system fault was rectified in December enabling it to return as the duty system full time. The TAK UV system is available as backup during higher flows as per normal operation.</p> <p>Physical works on the odour control unit (OCU) continue. This major project will deliver additional odour treatment capacity into the plant's current process. These works are expected to be completed in June 2026.</p>	<p>Compliant</p>	