

Porirua Wastewater Treatment Plant performance - August 2025

Commentary	Discharges	Odour Complaints	Items of significance	Current status	
The plant is compliant for effluent quality.	No discharges in August.	No odour complaints in August.	Improvements in the biological process has returned solids concentration in the process to a more manageable level, with encouraging trends observed in the dewatering efficiency. This has improved overall sludge and effluent process outcomes.	Compliant	