

## Porirua Wastewater Treatment Plant performance - November 2025

Commentary	Discharges	Odour Complaints	Items of significance	Current status	
The plant is compliant for effluent quality.	No non-compliant discharges in November.	No odour complaints in November.	<p>The plant continues to run the backup TAK UV system as duty during night hours and weekends until the fault with the Duron UV system can be fixed. This duty switch has been successful during previous Duron faults and is reliable mitigation for ensuring continuous UV disinfection until the Duron unit is reliably repaired.</p> <p>Community Liason Group (CLG) meeting: The annual CLG took place in November discussing plant performance and consent compliance for the last financial year with the local community.</p>	Compliant	