

# Seaview Wastewater Treatment Plant performance - October 2025

Commentary	Discharges	Odour Complaints	Items of significance	Odour Treatment Project	Current status	
<p>Faecal coliforms remain non-compliant for both the 90-day geomean and 80th percentile. Suspended solids and biochemical oxygen demand are compliant with consent parameters.</p>	<p>There were four consented wet weather discharges to the Waiwhetū Stream in October.</p>	<p>No odour complaints in October.</p>	<p>Effluent Non-compliance: Unplanned maintenance to the thermal dryer in September is requiring dewatered sludge to be loaded out while repairs were carried out and negatively impacting the biological process. The recovery to the process has been slower than anticipated however trends and daily effluent results indicate the process is on the correct path to restoring compliance.</p> <p>Community Odour Monitors: Four of the five monitors have been installed in the designated locations, with one still to be installed. The community website platform is now expected to be available later in November.</p>	<p>What has been completed:</p> <ul style="list-style-type: none"> <li>- Community Liaison Group Meeting – 22 October 2025</li> <li>- New milliscreen odour treatment unit ducting is complete</li> </ul> <p>What’s coming up:</p> <ul style="list-style-type: none"> <li>- Installation of the final community odour monitor to be completed</li> <li>- Complete and commission the new milliscreen odour treatment system</li> <li>- Install and commission new Milliscreen and Biofilter fans (delayed due to manufacturing delays)</li> </ul>	<p>Non-compliant</p>	