

Seaview Wastewater Treatment Plant performance - December 2025

Commentary	Discharges	Odour Complaints	Items of significance	Odour Treatment Project	Current status	
<p>Suspended solids and Faecal coliforms are non-compliant for both the 90-day geomean and 80th percentile. Biochemical oxygen demand is compliant with consent parameters.</p>	<p>There were two consented wet weather discharges to the Waiwhetū Stream in December due to heavy rainfall.</p>	<p>There were 6 odour complaints received in December, two of which were deemed offensive and objectionable by GWRC.</p>	<p>Effluent Non-compliance: Several asset failures over the previous couple of months have negatively impacted the biological process however the team at the plant are urgently addressing these failures to restore effluent compliance.</p> <p>GWRC issued a Please Explain letter in December in relation to the two odour events which were assessed as offensive and objectionable. A response will be provided within the required timeframe.</p>	<p>What has been completed:</p> <ul style="list-style-type: none"> - The new milliscreen odour treatment system was fully commissioned -The second Milliscreen and Biofilter fans were installed and commissioned -The main project works were completed. <p>What's coming up:</p> <ul style="list-style-type: none"> -Installation of the final community odour monitor -Independent assessment of the effectiveness of the Odour Control Project – Stages 1 and 2. 	<p>Non-compliant</p>	