

Seaview Wastewater Treatment Plant performance - August 2025

Commentary	Discharges	Odour Complaints	Items of significance	Odour Treatment Project	Current status	
The plant is compliant for effluent quality.	There were three consented wet weather discharges to the Waiwhetū Stream in August.	There was one odour complaint received in August.	<p>Primary Sedimentation Tank (PST) refurbishments: Planned refurbishment to PST #1 was completed in August. This means all four PST's have been refurbished in the past 12 months and will help stabilise the plants biological process.</p> <p>Community Odour Monitors: The project is progressing well with the first two monitors installed at the plant in August. The remaining three monitors will be installed in the designated community locations and commissioned before end of September.</p>	<p>What has been completed:</p> <ul style="list-style-type: none"> - The contractor design has been approved accepted by Wellington Water - 50% of the new milliscreen ducting has been installed - Sealing of the external ducting is complete <p>Whats coming up:</p> <ul style="list-style-type: none"> - Installation of the new community odour monitors to be completed - Complete installation of the new milliscreen ducting - Progress on remaining stage 2 construction works 	Compliant	