


# Seaview Wastewater Treatment Plant performance - November 2025

| Commentary  | Discharges   | Odour Complaints                        | Items of significance  | Odour Treatment Project  | Current status       |   |
|---|--|---|--|--|----------------------|---|
| <p>Faecal coliforms remain non-compliant for both the 90-day geomean and 80th percentile. Suspended solids and biochemical oxygen demand are compliant with consent parameters.</p> | <p>There was one consented wet weather discharge to the Waiwhetū Stream in November.</p> | <p>No odour complaints in November.</p> | <p>Effluent Non-compliance: Several asset failures over the previous couple of months have negatively impacted the biological process however the team at the plant are urgently addressing these failures to restore effluent compliance.</p> <p>Community Odour Monitors: The community website platform, to see live odour readings, is now available on the Wellington Water website. Four of the five monitors are viewable with the final monitor awaiting installation.</p> | <p>What has been completed:</p> <ul style="list-style-type: none"> <li>- Final ducting connections arrived on site</li> <li>- First new milliscreen fan and first new biofilter fan have been installed</li> <li>- New milliscreen odour treatment system completed the first stage of commissioning testing.</li> </ul> <p>What's coming up:</p> <ul style="list-style-type: none"> <li>- Installation of the final community odour monitor to be completed</li> <li>- Complete second stage of testing for the new milliscreen odour treatment system</li> <li>- Install and commission second Milliscreen and Biofilter fans</li> <li>- Project completion</li> </ul> | <p>Non-compliant</p> |  |