



South Wairarapa Water Treatment Plants

Monthly Performance Report

September 2025

Month/Year
September 2025

Safe Drinking Water

- Compliant – we are meeting the necessary regulatory requirements
- Compliant but requiring more work
- Not compliant with necessary regulatory requirements

| Water Treatm.. | Comments | Fluoride | Safe Drinking Water |
|----------------|--|---------------------------------------|---------------------|
| Martinborough | The Martinborough WTP is compliant against the bacterial and protozoal Rules. Work is underway to decommission the soda ash dosing system, due to being surplus to requirements. A project has commenced to optimise how the UV reactors work. | Currently not yet mandated by the MoH | |
| Memorial Park | The Memorial Park WTP is compliant against the bacterial and protozoal Rules. The caustic soda dosing upgrade project is now with the SWDC Capital Projects Delivery team to complete. A trial shutdown was undertaken in preparation for the planned 1080 drop in the Waiohine Catchment. The bore pump is having mechanical issues and an condition assessment is underway. | Currently not yet mandated by the MoH | |
| Pirinoa | Pirinoa is compliant against the bacterial and protozoal Rules. The raw water storage tank, and associated pipework, has been handed over to the SWDC Capital Projects Delivery team to complete. | Currently not yet mandated by the MoH | |
| Waiohine | The Waiohine WTP is compliant against the bacterial and protozoal Rules. The caustic soda dosing upgrade project is now with the SWDC Capital Projects Delivery team for completion. A trial shutdown was undertaken in preparation for the planned 1080 drop in the Waiohine Catchment. Some minor improvements were identified to provide confidence that the Greytown Reservoir can meet demand during a 72hr shutdown. | Currently not yet mandated by the MoH | |