

Western Wastewater Treatment Plant performance - December 2025

Commentary	Discharges	Odour Complaints	Items of significance	Current status	
<p>The plant remains non-compliant for faecal coliforms on the 80th percentile and became non-compliant for biochemical oxygen demand late November also on the 80th percentile. The plant is compliant for suspended solids.</p>	<p>No non-compliant discharges in December.</p>	<p>No odour complaints in December.</p>	<p>Effluent Non-compliance: The plant remains non-compliant for faecal coliforms on the percentile due to the November electrical failure in the UV disinfection system however daily results are back to below the compliance limits. Adjustments have been made to the biological process to address the biochemical oxygen demand non-compliance as the team continue to monitor the process closely.</p>	<p>Non-compliant</p>	