

14 September 2022

**OIA IRO-279**

Email: [REDACTED] [@windowslive.com](mailto:[REDACTED]@windowslive.com)

Kia ora [REDACTED],

I write regarding your official information request dated Thursday 11 August 2022 for copies of all water pipe leak reports for the past 10 years in Ngaio, bounded by Junction of Perth Street and Ngaio Gorge Road, to Junction of Cockayne and Punjab Street (including side roads such as Ambala Way), junction of Crofton Road and Kenya Street. Old Porirua Road to Capitan Edward Daniel drive.

**Following our notification to extend part of your request, please see attached in our email to you all other Job Sheets Wellington Water holds.**

Please note that the information we hold dates back only to 2014, therefore we are unable to fulfil your request for 10 years' worth of data. Furthermore, the data in this response consists of a different layout – this is because there were multiple data logging systems in use at the time.

Pursuant to [Section 7\(2\)\(a\)](#) of the Local government Official information and Meetings Act 1987 some information has been redacted as it contains personal information about private individuals.

You have the right to seek an investigation and review by the Ombudsman of this decision. Information about how to make a complaint is available at [www.ombudsman.parliament.nz](http://www.ombudsman.parliament.nz) or freephone 0800 802 602.

Ngā mihi

[REDACTED]  
**Manager, Customer Experience**  
**Wellington Water Ltd**

For the latest news and updates, follow us on our social channels:

 /wellingtonwater

 @wgtwaternz & @wgtwateroutage

 @wellington\_water

[www.wellingtonwater.co.nz](http://www.wellingtonwater.co.nz)

**Our water, our future.**

No.	Address	Council Ref ID	Water Type	Request ID	Request type	Comm Description	Date Created	Status	Resolution Date	Priority	Allocation	Responsible User
	1 ambala wayngaiowgtn	WCC	Water	WCC2328622	No water calls to council	W-P1 No Water	04 Mar 2015	Completed	04 Mar 2015	P1	CityCare	Wellington Water
				WCC2570369	0	W-Toby Fault	16 May 2017	Completed	19 May 2017	P3	CityCare	City Care - Water
	2 ambala wayngaiowgtn	WCC	Water	WCC2342229	0	W-Toby Fault	20 Apr 2015	Completed	22 Apr 2015	P3	CityCare	Wellington Water
	4 ambala wayngaiowgtn	WCC	Water	WCC2559692	No water calls to council	W-P1 No Water	10 Apr 2017	Completed	04 May 2017	P1	CityCare	City Care - Water
	Ambala way (private) ambala way ngaio wgtn	WCC	Water	WCC2831230		Information Request Client Council	02 Sep 2019	Completed	30 Sep 2019	P3	FH	FH
	Ambala way (private) os 1 ambala way, ngaio	WCC	Water	WCC2829194		Major Burst or Breakage	26 Aug 2019	Completed	02 Sep 2019	P2	FH	FH
	Ambala way, ngaio, wellington, 6035	WCC	Water	WCCSR-104049	System faults	Leaking Pipes	13 Feb 2021	90 closed (close)	16 Feb 2021	P3	007-WGTN- PW-RETC	
	Ambala wayngaiowgtn	WCC	Water	WCC2379503	0	W-P3 Minor Leaks	24 Aug 2015	Completed	26 Aug 2015	P3	CityCare	Wellington Water
	Bottom of ambala wayngaiowgtn	WCC	Water	WCC2177990	0	W-P3 Minor Leaks	28 Aug 2013	Completed	13 Sep 2013	P3	Capacity	

No.	Details	Data Source	ID asset	Asset ID	Asset Description
	Caller reported no water in his property. Caller advised that the water just stopped coming in last 5 minutes.	Councils			
	Hello there - I live at 1 Ambala Way, Ngaio. My plumber has just been to fix a tap and had to turn off the main water Toby. He tells me that it is broken and needs replacing - it is leaking and in an emergency he tells me it might fail.	CityCare	3242086	WCC_PW011562	W-valve-1 ambala way ngaio
	Unable to turn toby off please attend and repair. Water is leaking under the house but plumber is unable to turn toby off to look at this.	CityCare	3245627	WCC_PW019494	W-valve-2 ambala way ngaio
	Callers toby tap is broken and unable to turn off, They have no water and are needing to turn the tap of for a replacement tap to be replaced at the home.	CityCare	3242091	WCC_PW011566	W-valve-4 ambala way ngaio
	Relates to job 2829194. caller is concerned as the water leak has caused a lot of damage to the road burm and his driveway. He is wanting to confirm who will do the repair and when. Please contact [REDACTED]	MagicBus			
	caller advised there is water leaking from a crack in the center of the road. please attend to assess.	MagicBus			
	Leaking Pipes AMBALA WAY, Ngaio	Maximo			
	Arrived onsite and follow were water is coming from and found it coming from Ambala Way.	Councils			
	Water is leaking out of bank at bottom of Ambala Way Ngaio, where it joins Cockayne Rd. Possibly broken pipe from somewhere.	CityCare	3245592	WCC_PW019482	W-valve-259 cockayne rd ngaio-khandallah

No.	Address	Council Ref ID	Water Type	Request ID	Request type	Comm Description	Date Created	Status	Resolution Date	Priority	Allocation	Responsible User
	3d armitage stngaiowgtn	WCC	Water	WCC2264700	No water calls to council	W-P1 No Water	13 Jul 2014	Completed	13 Jul 2014	P1	Capacity	[REDACTED]
	5 armitage street, ngaio, wellington, 6035	WCC	Water	WCCSR-335179	System faults	Leaky or Faulty Connection/Meter/Toby	24 Feb 2022	90 closed (close)	17 Mar 2022	P3	007-WGTN-PW-RETC-DIST-VALV	[REDACTED]
	13 armitage street, ngaio, wellington, 6035	WCC	Water	WCCSR-112468	System faults	Leaky or Faulty Connection/Meter/Toby	26 Feb 2021	90 closed (close)	17 Mar 2021	P3	007-WGTN-PW-RETC	[REDACTED]
				WCCSR-132751		General Fault	26 Mar 2021	90 closed (close)	26 Mar 2021	P2	007-WGTN-PW-RETC	[REDACTED] Plumbing
				WCCSR-205753	No water calls to council	Loss of Service	23 Jul 2021	90 closed (close)	23 Jul 2021	P1	007-WGTN-PW-RETC	Not Given
	Armitage st 13 armitage st ngaio wgtn	WCC	Water	WCC2850798		Fault	06 Nov 2019	Completed		P3	FH	[REDACTED]
	Old porirua rd 302 old porirua rd ngaio. 3d armitage street, ngaio, wellington 6035, new zealand	WCC	Water	WCC2892322		Leaky Connection/Meter/Toby	13 Mar 2020	Completed	26 Mar 2020	P3	FH	[REDACTED]



No.	Details	Data Source	ID asset	Asset ID	Asset Description
	URGENT - no water to this property may be linked to a gushing water pipe on the corner outside this street, please attend.	Councils			
	Leaky Connection 5 Armitage Street, Ngaio	Maximo	384498	WCC_PW012290	Wcc_pw012290 valve ball 0mm
	Leaky Connection 13 ARMITAGE STREET, Ngaio	Maximo			
	Fault 13 ARMITAGE STREET, Ngaio	Maximo			
	Loss of Service 13 ARMITAGE STREET, Ngaio	Maximo			
	Callers driveway is subsiding very near her toby which is up the drive closer tot he house was leaking and repaired by WW and has asked if someone can come out and see if the subsidence is a result of the leak that was comg from the toby	MagicBus			
	Old water leak in road has failed again, water is running from under seal, requires inspection.  Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.2552288,174.7758935&amp;mapz=19">http://maps.google.co.nz/?q=-41.2552288,174.7758935&amp;mapz=19</a>	MagicBus			

No.	Address	Council Ref ID	Water Type	Request ID	Request type	Comm Description	Date Created	Status	Resolution Date	Priority	Allocation	Responsible User
	6 bankot cres	WCC	Water	WCC2498606	0	W-Instructed Works	26 Sep 2016	Completed	05 Dec 2016	P4	CityCare	City Care - Water
	11 bankot cresngaiowgtn	WCC	Water	WCC2283126	0	W-Enquiry to Engineer	22 Sep 2014	Completed	30 Sep 2014	P4	WWL	
				WCC2462978	0	W-P3 Minor Leaks	30 May 2016	Completed	31 May 2016	P3	CityCare	Wellington Water
	19 bankot cresngaiowgtn	WCC	Water	WCC2305587	0	W-Private Leaks	11 Dec 2014	Cancelled	11 Dec 2014	P3	WWL	
				WCC2305590	0	W-P2 Major Leaks	11 Dec 2014	Completed	11 Dec 2014	P2	WWL	
				WCC2393553	0	W-P3 Non Urgent Fault	14 Oct 2015	Completed	26 May 2016	P3	CityCare	Wellington Water
	29 bankot cres, ngaio, wgtm	WCC	Water	WCC2634580	0	W-Private Leaks	12 Dec 2017	Completed	21 Dec 2017	P3	CityCare	City Care - Water
	33 bankot crescent, ngaio, wellington, 6035	WCC	Water	WCCSR-325975	System faults	Leaking Pipes	11 Feb 2022	90 closed (close)	16 Feb 2022	P2	007-WGTN-PW-RETC-CONN-VALV	
	34 bankot cresngaiowgtn	WCC	Water	WCC2797991	0	W-P3 Minor Leaks	16 May 2019	Completed	17 Jun 2019	P3	CityCare	City Care - Water
	35 bankot cres ngaio	WCC	Water	WCC2168126	0	W-P3 Non Urgent Fault	24 Jul 2013	Completed	05 Aug 2013	P3	CityCare	Capacity
	38 bankot crescent, ngaio, wellington, 6035	WCC	Water	WCCSR-51539	System faults	Leaking Pipes	29 Oct 2020	90 closed (close)	30 Oct 2020	P2	007-WGTN-PW-RETC	
				WCCSR-51539R		Asphalt Reinstatement	29 Oct 2020	90 closed (close)	20 Nov 2020	P4	007-WGTN-PW-RETC	
	42 bankot cresngaiowgtn	WCC	Water	WCC2779323	0	W-P3 Minor Leaks	20 Mar 2019	Completed	16 May 2019	P3	CityCare	City Care - Water
	46 bankot cres ngaio wgtm	WCC	Water	WCC2904690		Leaky Connection/Meter/Toby	19 May 2020	Awaiting reinstatement	04 Jun 2020	P3	FH	FH
	46 bankot crescent wellington ngaio	WCC	Water	WCC2238364	0	W-P3 Minor Leaks	01 Apr 2014	Completed	03 Apr 2014	P3	CityCare	Capacity
	46 bankot cresngaiowgtn	WCC	Water	WCC2326033	0	W-P3 Minor Leaks	25 Feb 2015	Completed	12 Mar 2015	P3	CityCare	Wellington Water
	50 bankot crescent, ngaio, wellington, 6035	WCC	Water	WCCSR-96318	System faults	Leaking Pipes	30 Jan 2021	90 closed (close)	11 Feb 2021	P3	007-WGTN-PW-RETC	
				WCCSR-96318R		Asphalt Reinstatement	30 Jan 2021	90 closed (close)	10 Mar 2021	P4	007-WGTN-PW-RETC	
	Back of 29 bankot cres, caller's neighbourngaiowgtn	WCC	Water	WCC2163413	0	W-Private Leaks	08 Jul 2013	Completed	23 Jul 2013	P3	Capacity	
	Bankot cres 3b bankot cres ngaio wgtm	WCC	Water	WCC2829003		Leaky Connection/Meter/Toby	26 Aug 2019	Completed	30 Aug 2019	P2	FH	FH
	Bankot cres 36 bankot cres ngaio, wgtm	WCC	Water	WCC2841171		Leaky Connection/Meter/Toby	04 Oct 2019	Cancelled		P3	FH	FH
	Bankot cres 38 bankot cres ngaio wgtm	WCC	Water	WCC2841179		Leaking Pipes	04 Oct 2019	Completed	14 Oct 2019	P2	FH	FH
				WCC2852387		Leaking Pipes	11 Nov 2019	Completed	17 Dec 2019	P3	FH	FH
	Bankot cres 38 bankot cres, ngaio	WCC	Water	WCC2841226		Major Burst or Breakage	04 Oct 2019	Cancelled		P1	FH	FH
	Bankot cres 39 bankot cres, ngaio	WCC	Water	WCC2867452		Leaking Pipes	30 Dec 2019	Completed	30 Dec 2019	P2	FH	FH
	Opp 42 bankot cresngaiowgtn	WCC	Water	WCC2166981	0	W-P3 Minor Leaks	19 Jul 2013	Completed	20 Jul 2013	P3	Capacity	



No.	Details	Data Source	ID asset	Asset ID	Asset Description
	Toby marked. Rechecked three times. Water visible running in drain right-hand side of property.	Councils			
	there is a 200 m diametre, cast iron dug shallow about 5-10 centimetres down looks like it had previous repairs but it has a large crack going through it caller is not sure what it is can WCC please attend to see what it is as it is not showing up on the LIM and there is water coming out of it	Councils			
	Slow leaking water from WCC mains onto caller private property at rear where WCC mains are located. Plse call caller before going out on site. This has been reported by [REDACTED] on [REDACTED].	Councils			
	Caller reported burst water main at his property. He said that the flow is quite heavy. Caller also advised that though the leak can be spotted inside his house but the actual source could be on the road. Please attend.	Councils			
	Caller reported major water leak at his property. He said that the flow is quite heavy. Caller also advised that though the leak can be spotted inside his house but the actual source could be on the road. Please attend.	Councils			
	seepage occurs only when contractors turn F/H on. Previous job inspected by drainage 2393095	Councils			
	Caller advised they have noticed a leak start here just today but are unsure where it is coming from. Can see it is on 29 Bankot St and is a steady amount of water leaking down onto the footpath and down the gutter. Please assess.	Councils			
	Leaking Pipes 33 Bankot Crescent, Ngaio	Maximo	308732	WCC_PW013299	Wcc_pw013299 valve ball 20mm
	RI ASSIGNED 14/05/19 CAR R591199 15/05 Reinstatement Information Location : Road Type : Asphalt Size (sq/m) : 1x1 Other Details : 00 Road : Open PLANS ATTACHED 05/04/19 NOTES AS PER ADR 26/03/19 I have marked a leak beneath the road outside #34 Bankot Cres. See picture attached JOB ON HOLD EMAILED ADR 26/03/19 Plumber asking for assistance - leak possibly coming from council side, Caller is plumber attending a job. Ground water leak, toby has been turned off on this property but the leak is still coming through the ground. Plumber suspects it may be coming from a main. Please assess EM#[3650894] - do not delete this.	Councils			
	Leaking fire hydrant at 35 Bankot Cres. marked.	CityCare	3184029	WCC_PW000685	Wfht-35 bankot cres ngaio
	Leaking Pipes 38 BANKOT CRESCENT, Ngaio	Maximo			
	Reinstatement: Leaking Pipes 38 BANKOT CRESCENT, Ngaio	Maximo			
	Caller is plumber attending a job. Ground water leak, toby has been turned off on this property but the leak is still coming through the ground. Plumber suspects it may be coming from a main. Please assess	Councils			
	Caller advised the toby is leaking outside their address and making the ground muddy.	MagicBus		WCC_PW013284	Wcc_pw013284
	Water leaking from pipe into kerb, photo attached	CityCare	3184035	WCC_PW013266	W-valve-48 bankot cres ngaio
	There is a water leak coming from the gutter at location site.	CityCare	3236078	WCC_PW013284	W-valve-46 bankot cres ngaio
	Leaking Pipes 50 BANKOT CRESCENT, Ngaio	Maximo			
	Reinstatement: Leaking Pipes 50 BANKOT CRESCENT, Ngaio	Maximo			
	Water is running off their property from a bank, slow trickle	Councils			
	caller advised her toby box is filled with water and is leaking into her pavers close to her front door. please contact to attend to fix.	MagicBus			
	36 to 38 Bankot Cres. Caller reported a steady flow of water coming out their toby near the top of their drive.	MagicBus			
	Caller reported really strong leak in this location. from a small round metal cover	MagicBus			
	The caller says that there is a FH at the bottom of the shared driveway that is leaking. Please assess	MagicBus		WCC_PWP093740	Wcc_pwp093740
	Caller advised water is gushing out of a crack where the road meets the driveway to these apartment. Their property at 40 Bankot Cres is being flooded by this. Please attend ASAP	MagicBus			
	Caller advised the toby outside his house is pouring out water. He advised it is loud and sounds like there is lots of pressure. Please attend ASAP. Thanks	MagicBus			
	Complaint that there is still water leaking from the bank, refer to ref#2154787. Caller doesn't believe that this is ground water as she said that there was no water trickling from the bank until after the storm. She would like someone to go back out and have another look and would like someone to ring her about this.	Councils			



No.	Address	Council Ref ID	Water Type	Request ID	Request type	Comm Description	Date Created	Status	Resolution Date	Priority	Allocation	Responsible User
	Cockayne rdngaiowgtn	WCC	Water	WCC2340094	0	W-P2 Major Leaks	13 Apr 2015	Completed	17 Apr 2015	P2	CityCare	Wellington Water
	Cockayne rdngaiowgtn	WCC	Water	WCC2400259	0	W-P3 Minor Leaks	08 Nov 2015	Completed	10 Nov 2015	P3	CityCare	Wellington Water
	Cockayne rdngaiowgtn	WCC	Water	WCC2400394	0	W-P3 Minor Leaks	09 Nov 2015	Cancelled	09 Nov 2015	P3	CityCare	Wellington Water
	2/282 cockayne rd	WCC	Water	WCC2498612	0	W-Instructed Works	26 Sep 2016	Completed	29 Nov 2016	P4	CityCare	City Care - Water
	129 cockayne rd, ngaio, wgtm	WCC	Water	WCC2398555	0	W-P3 Minor Leaks	02 Nov 2015	Completed	03 Nov 2015	P3	CityCare	Wellington Water
	143 cockayne rdngaiowgtn	WCC	Water	WCC2353035		Drinking water clarity complaints, clarity, odour, taste	22 May 2015	Completed	22 May 2015	P1	CityCare	Wellington Water
	146 cockayne rdngaiowgtn	WCC	Water	WCC2347944	0	W-P3 Minor Leaks	07 May 2015	Completed	08 May 2015	P3	CityCare	Wellington Water
	148a cockayne road, khandallah, wellington, 6035	WCC	Water	WCCSR-49029	System faults	Leaking Pipes	23 Oct 2020	90 closed (close)	09 Nov 2020	P3	007-WGTN-PW-RETC	Notgiven DO NOT DELETE
	150 cockayne rd, between flats.	WCC	Water	WCC2737306	0	W-P3 Minor Leaks	13 Nov 2018	Completed	27 Nov 2018	P3	CityCare	City Care - Water
	161 cockayne rdngaiowgtn	WCC	Water	WCC2358161	0	W-Instructed Works	10 Jun 2015	Completed	23 Jul 2015	P4	CityCare	Wellington Water
	161a cockayne rdngaiowgtn	WCC	Water	WCC2345760	0	W-Toby Fault	01 May 2015	Completed	22 May 2015	P3	CityCare	Wellington Water
	167 cockayne rdngaiowgtn	WCC	Water	WCC2272789	0	W-P3 Minor Leaks	14 Aug 2014	Completed	15 Aug 2014	P3	CityCare	Capacity
	167 cockayne road, ngaio, wellington, 6035	WCC	Water	WCC2925771		General Fault	09 Sep 2020	90 closed (close)	11 Sep 2020	P3	007-WGTN-PW-RETC	
	168 cockayne rdngaiowgtn	WCC	Water	WCC2389392	0	W-P1 Urgent Fault	29 Sep 2015	Completed	29 Sep 2015	P1	CityCare	Wellington Water
				WCC2636355	0	W-P3 Minor Leaks	18 Dec 2017	Completed	21 Dec 2017	P3	CityCare	City Care - Water
	170 cockayne rdngaiowgtn	WCC	Water	WCC2343248	0	W-P2 Major Leaks	22 Apr 2015	Completed	23 Apr 2015	P2	CityCare	Wellington Water
	173 cockayne rd ngaio wgtm	WCC	Water	WCC2810226		Leaky Connection/Meter/Toby	26 Jun 2019	Completed	22 Aug 2019	P3	FH	FH
	173 cockayne road, ngaio, wellington, 6035	WCC	Water	WCCSR-165183	System faults	Leaking Pipes	17 May 2021	90 closed (close)	28 Jul 2021	P3	007-WGTN-PW-RETC-CONN-VALV	Not Given
	179 cockayne rdngaiowgtn	WCC	Water	WCC2326529	0	W-Damage Caused By 3rd Party	26 Feb 2015	Completed	26 Feb 2015	P2	CityCare	Wellington Water
	182 cockayne road ngaio	WCC	Water	WCC2295813	0	W-Toby Fault	07 Nov 2014	Completed	10 Nov 2014	P3	CityCare	Wellington Water
	186 cockayne rdngaiowgtn	WCC	Water	WCC2514933	0	W-Private Leaks	18 Nov 2016	Completed	21 Nov 2016	P3	CityCare	City Care - Water
	188 cockayne rdngaiowgtn	WCC	Water	WCC2296084	0	W-P1 Urgent Fault	08 Nov 2014	Completed	08 Nov 2014	P1	CityCare	Wellington Water
	192 cockayne rd, ngaio	WCC	Water	WCC2338602	0	W-P1 Urgent Fault	08 Apr 2015	Cancelled	29 Apr 2015	P1	CityCare	Wellington Water
	198 cockayne rd, ngaio	WCC	Water	WCC2224510	0	W-P3 Minor Leaks	14 Feb 2014	Completed	17 Feb 2014	P3	CityCare	Capacity
	198 cockayne road, ngaio, wellington, 6035	WCC	Water	WCCSR-87302-1	System faults	Leaking Pipes	02 Mar 2021	90 closed (close)	19 May 2021	P4	007-WGTN-PW-RETC	
	201 cockayne rd	WCC	Water	WCC2520527	0	W-P3 Non Urgent Fault	05 Dec 2016	Cancelled	05 Dec 2016	P3	CityCare	City Care - Water
	202 cockayne rd, ngaio	WCC	Water	WCC2357704	0	W-Damage Caused By 3rd Party	09 Jun 2015	Completed	10 Jun 2015	P2	CityCare	Wellington Water
	204a cockayne rd, khandallah, wellington, 6035	WCC	Water	WCCSR-87302-2	System faults	Leaking Pipes	02 Mar 2021	90 closed (close)	19 May 2021	P4	007-WGTN-PW-RETC	
	204a cockayne rdngaiowgtn	WCC	Water	WCC2304453	0	W-Private Leaks	08 Dec 2014	Completed	09 Dec 2014	P3	WWL	
	206a cockayne rdngaiowgtn	WCC	Water	WCC2222644	0	W-Private Leaks	07 Feb 2014	Completed	12 Mar 2014	P3	Capacity	
	206a cockayne road, ngaio, wellington, 6035	WCC	Water	WCCSR-105030		General Fault	15 Feb 2021	90 closed (close)	25 Feb 2021	P3	007-WGTN-PW-RETC	
	209 cockayne rdngaiowgtn	WCC	Water	WCC2363395	0	W-P3 Minor Leaks	27 Jun 2015	Cancelled	29 Jun 2015	P3	CityCare	Wellington Water
	210 cockayne rdngaiowgtn	WCC	Water	WCC2314277	0	W-P2 Major Leaks	16 Jan 2015	Completed	27 Mar 2015	P2	CityCare	Wellington Water
	210 cockayne road, ngaio, wellington, 6035	WCC	Water	WCCSR-359710		General Fault	06 Apr 2022	50 pre-claim, for review (preclaim)	01 Jun 2022	P3	007-WGTN-PW-RETC-CONN-PIPE	



214 cockayne rdngaiowgtn	WCC	Water	WCC2363714	0	W-P1 Urgent Fault	29 Jun 2015	Cancelled	29 Jun 2015	P1	CityCare	Wellington Water
214a cockayne road	WCC	Water	WCC2363461	0	W-P3 Minor Leaks	27 Jun 2015	Cancelled	29 Jun 2015	P3	CityCare	Wellington Water
215 cockayne rdngaiowgtn	WCC	Water	WCC2373596	0	W-Damage Caused By 3rd Party	03 Aug 2015	Completed	03 Aug 2015	P2	CityCare	Wellington Water
226 cockayne rdngaiowgtn	WCC	Water	WCC2288937	0	W-Toby Locate	13 Oct 2014	Completed	16 Oct 2014	P3	CityCare	Wellington Water
231 cockayne road, ngaio, wellington, 6035	WCC	Water	WCCSR-195662	System faults	Leaking Pipes	09 Jul 2021	31 on site work complete - may require reinstatement (jobcomp)	27 Jul 2021	P3	007-WGTN-PW-RETC-CONN-VALV	
			WCCSR-195662R		Concrete Reinstatement	09 Jul 2021	90 closed (close)	18 Jan 2022	P4	007-WGTN-PW-RETC-CONN-VALV	
			WCCSR-196897	System faults	Leaking Pipes	12 Jul 2021	90 closed (close)	12 Jul 2021	P2	007-WGTN-PW-RETC	
238 cockayne rd, ngaio	WCC	Water	WCC2355466	0	W-P2 Major Leaks	01 Jun 2015	Completed	01 Jun 2015	P2	CityCare	Wellington Water
			WCC2441989	0	W-P3 Minor Leaks	24 Mar 2016	Completed	02 Apr 2016	P3	CityCare	Wellington Water
238 cockayne rdngaiowgtn	WCC	Water	WCC2477421	0	W-P2 Major Leaks	18 Jul 2016	Completed	20 Jul 2016	P2	CityCare	City Care - Water
			WCC2654389	0	W-P1 Urgent Fault	18 Feb 2018	Completed	18 Feb 2018	P1	CityCare	City Care - Water
254 cockayne rdngaiowgtn	WCC	Water	WCC2631938	0	W-P3 Minor Leaks	05 Dec 2017	Completed	08 Dec 2017	P3	CityCare	City Care - Water
256 cockayne rdngaiowgtn	WCC	Water	WCC2566445	0	W-Instructed Works	03 May 2017	Cancelled	29 May 2017	P4	CityCare	City Care - Water
256 cockayne road wellington ngaio	WCC	Water	WCC2311498	0	W-P3 Minor Leaks	07 Jan 2015	Completed	07 Jan 2015	P3	CityCare	Wellington Water
257 cockayne rd. ngaio.	WCC	Water	WCC2434056	0	W-P3 Minor Leaks	01 Mar 2016	Completed	10 Mar 2016	P3	CityCare	Wellington Water
258 cockayne rd, ngaio	WCC	Water	WCC2357928	0	W-P1 Urgent Fault	09 Jun 2015	Completed	21 Jun 2015	P1	CityCare	Wellington Water
258 cockayne rd, ngaiowgtn	WCC	Water	WCC2368081	0	W-P1 Urgent Fault	14 Jul 2015	Completed	14 Jul 2015	P1	CityCare	Wellington Water
259 cockayne road, ngaio, wellington, 6035	WCC	Water	WCCSR-32088	System faults	Leaking Pipes	22 Sep 2020	90 closed (close)	29 Sep 2020	P3	007-WGTN-PW-RETC	
			WCCSR-63051	System faults	Leaking Pipes	19 Nov 2020	90 closed (close)	25 Nov 2020	P3	007-WGTN-PW-RETC	
267 cockayne rd, ngaio, wgtm	WCC	Water	WCC2380179	0	W-P2 Major Leaks	26 Aug 2015	Completed	01 Sep 2015	P2	CityCare	Wellington Water
267 cockayne rdngaiowgtn	WCC	Water	WCC2274211	0	W-P3 Minor Leaks	19 Aug 2014	Completed	27 Aug 2014	P3	CityCare	Capacity
270 cockayne rdngaiowgtn	WCC	Water	WCC2519459	0	W-Enquiry to Engineer	01 Dec 2016	Completed	10 Dec 2016	P4	CityCare	City Care - Water
278 cockayne road, ngaio, wellington, 6035	WCC	Water	WCCSR-92841		Instructed Works	23 Jan 2021	90 closed (close)	03 Feb 2021	P4	007-WGTN-PW-RETC	.notgiven
279 cockayne rdngaiowgtn	WCC	Water	WCC2727708	0	W-P3 Minor Leaks	12 Oct 2018	Cancelled	15 Oct 2018	P3	CityCare	City Care - Water
282 cockayne rd, ngaio	WCC	Water	WCC2493855	0	W-Toby Fault	11 Sep 2016	Completed	14 Sep 2016	P3	CityCare	City Care - Water
282 cockayne road, ngaio, wellington, 6035	WCC	Water	WCCSR-101328	System faults	Leaking Pipes	09 Feb 2021	90 closed (close)	01 Mar 2021	P3	007-WGTN-PW-RETC-CONN-VALV	Notgiven DO NOT DELETE
283 cockayne rdngaiowgtn	WCC	Water	WCC2193614	0	W-P3 Minor Leaks	22 Oct 2013	Completed	24 Oct 2013	P3	CityCare	Capacity
286 cockayne rdngaiowgtn	WCC	Water	WCC2269901	0	W-P3 Minor Leaks	03 Aug 2014	Completed	03 Sep 2014	P3	CityCare	Capacity
288 cockayne road, ngaio, wellington	WCC	Water	WCC2728378	0	W-P2 Major Leaks	15 Oct 2018	Completed	28 May 2019	P2	CityCare	City Care - Water
290 cockayne road, 290 cockayne road, ngaio, wellington	WCC	Water	WCC2722297	0	W-P3 Minor Leaks	23 Sep 2018	Completed	25 Sep 2018	P3	CityCare	City Care - Water
292 cockayne rd, ngaio	WCC	Water	WCC2405968	0	W-P3 Non Urgent Fault	26 Nov 2015	Completed	14 Dec 2015	P3	CityCare	Wellington Water
292 cockayne rdngaiowgtn	WCC	Water	WCC2406773	0	W-P3 Minor Leaks	30 Nov 2015	Cancelled	30 Nov 2015	P3	CityCare	Wellington Water
			WCC2727674	0	W-P3 Minor Leaks	11 Oct 2018	Completed	19 Nov 2018	P3	CityCare	City Care - Water
294 cockayne rd, ngaio, wgtm	WCC	Water	WCC2407066	0	W-P3 Minor Leaks	30 Nov 2015	Cancelled	01 Dec 2015	P3	CityCare	Wellington Water

294 cockayne road wellington ngaio	WCC	Water	WCC2406089	0	W-P3 Minor Leaks	27 Nov 2015	Cancelled	27 Nov 2015	P3	CityCare	Wellington Water
Above property 226 cockayne rd, ngaio, wgtm	WCC	Water	WCC2301470	0	W-P3 Non Urgent Fault	27 Nov 2014	Completed	27 Nov 2014	P3	CityCare	Wellington Water
Cnr cockayne rd old porirua rdngaio wgtm	WCC	Water	WCC2162069	0	W-P1 Urgent Fault	04 Jul 2013	Completed	04 Jul 2013	P1	CityCare	Capacity
Cnr old porirua rd and cockayne rd ngaio wgtm	WCC	Water	WCC2589058	0	W-P3 Minor Leaks	17 Jul 2017	Completed	18 Jul 2017	P3	CityCare	City Care - Water
			WCC2247399	0	W-Mark Outs	06 May 2014	Completed	30 May 2014	P4	CityCare	Capacity
			WCC2247400	0	W-Mark Outs	06 May 2014	Completed	13 Jun 2014	P4	CityCare	Capacity
			WCC2278838	0	W-Mark Outs	05 Sep 2014	Completed	02 Oct 2014	P4	CityCare	Wellington Water
			WCC2435933	0	W-P3 Minor Leaks	07 Mar 2016	Completed	09 Mar 2016	P3	CityCare	Wellington Water
			WCC2482484	0	W-Mark Outs	04 Aug 2016	Completed	11 Aug 2016	P4	CityCare	City Care - Water
Cockayne rd 187 cockayne road 187 cockayne rd, ngaio, wellington 6035, new zealand	WCC	Water	WCC2831508		Leaky Connection/Meter/Toby	03 Sep 2019	Completed	25 Jan 2020	P2	FH	FH
Cockayne rd 188 cockayne rd, ngaio, wellington 6035, new zealand	WCC	Water	WCC2839104		Leaky Connection/Meter/Toby	27 Sep 2019	Cancelled		P3	FH	FH
Cockayne rd 189 cockayne rd ngaio wgtm	WCC	Water	WCC2834849		Major Burst or Breakage	13 Sep 2019	Completed	19 Sep 2019	P1	FH	FH
			WCC2871826		Information Request Client Council	15 Jan 2020	Cancelled		P4	FH	FH
Cockayne rd 190 cockayne road, ngaio, wellington 6035, new zealand	WCC	Water	WCC2866690		Leaky Connection/Meter/Toby	25 Dec 2019	Completed	06 May 2021	P4	FH	FH
Cockayne rd 199 cockayne rd ngaio wgtm	WCC	Water	WCC2851129		Leaky Connection/Meter/Toby	07 Nov 2019	Cancelled		P3	FH	FH
Cockayne rd 199a cockayne rd ngaio wgtm	WCC	Water	WCC2850749		Fault	06 Nov 2019	Awaiting reinstatement	16 Dec 2019	P2	FH	FH
Cockayne rd 201 cockayne road cockayne road at setsan way, wellington 6035, new zealand	WCC	Water	WCC2855692		Leaking Pipes	21 Nov 2019	Cancelled		P3	FH	FH
Cockayne rd 204 cockayne rd ngaio wgtm	WCC	Water	WCC2863354		Locate Asset	13 Dec 2019	Completed	23 Dec 2019	P2	FH	FH
Cockayne rd 206 cockayne rd ngaio wgtm	WCC	Water	WCC2861778	No water calls to council	Loss of Service	09 Dec 2019	Completed	11 Dec 2019	P1	FH	FH
Cockayne rd 210 cockayne rd ngaio wgtm	WCC	Water	WCC2854405		Locate Asset	18 Nov 2019	Completed	18 Nov 2019	P2	FH	FH
Cockayne rd 210a cockayne road, ngaio, wellington 6035, new zealand	WCC	Water	WCC2859993		Fault	04 Dec 2019	Completed	29 Jan 2020	P3	FH	FH
Cockayne rd 259 cockayne rd ngaio wgtm	WCC	Water	WCC2892093		Leaky Connection/Meter/Toby	12 Mar 2020	Completed	06 Apr 2020	P3	FH	FH
Cockayne rd 267 cockayne rd, ngaio, wellington	WCC	Water	WCC2830857		Leaky Connection/Meter/Toby	31 Aug 2019	Completed	02 Sep 2019	P1	FH	FH
Cockayne rd 279 cockayne rd ngaio wgtm	WCC	Water	WCC2877533		Fault	01 Feb 2020	Completed	18 Mar 2020	P3	FH	FH
Cockayne rd / mysore st reserve 189 cockayne road ngaio	WCC	Water	WCC2870318		Information Request Client Council	10 Jan 2020	Completed	29 Apr 2021	P4	FH	FH
Cockayne rd cockayne rd	WCC	Water	WCC2820543		Leaky Connection/Meter/Toby	29 Jul 2019	Completed	15 Aug 2019	P3	FH	FH

Cockayne rd cockayne road at setsan way, wellington 6035, new zealand	WCC	Water	WCC2855936		Leaking Pipes	22 Nov 2019	Cancelled		P2	FH	FH
Cockayne rd ngaio	WCC	Water	WCC2407884	0	W-Instructed Works	03 Dec 2015	Completed	21 Jun 2017	P4	Council	
Cockayne rd, ngaio, wellington, 6035	WCC	Water	WCCSR-45926	System faults	Leaking Pipes	20 Oct 2020	Cancelled, raised in error (can)		P2	007-WGTN-PW-RETC	
Cockayne rd, ngaio, wellington, 6035	WCC	Water	WCC2395392	0	W-P3 Minor Leaks	21 Oct 2015	Completed	22 Oct 2015	P3	CityCare	Wellington Water
From 210 cockayne rdngaiowgtn	WCC	Water	WCC2334953	0	W-P3 Minor Leaks	25 Mar 2015	Completed	26 Mar 2015	P3	CityCare	Wellington Water
Intersection of cockayne rd and setsan way	WCC	Water	WCC2521234	0	W-P3 Minor Leaks	07 Dec 2016	Cancelled	07 Dec 2016	P3	CityCare	City Care - Water
Intersection of cockayne road and quetta street ngaio.	WCC	Water	WCC2240594	0	W-P3 Minor Leaks	09 Apr 2014	Completed	09 Apr 2014	P3	CityCare	Capacity
Intersection of punjab and cockayne rd.	WCC	Water	WCC2400705	0	W-P3 Minor Leaks	09 Nov 2015	Cancelled	10 Nov 2015	P3	CityCare	Wellington Water
Intersection of punjab st & cockayne rd, khandallah, wgtm	WCC	Water	WCC2400677	0	W-P3 Minor Leaks	09 Nov 2015	Cancelled	10 Nov 2015	P3	CityCare	Wellington Water
O/s 186-188 cockayne rd, ngaio, wgtm	WCC	Water	WCC2320524	0	W-P1 Urgent Fault	05 Feb 2015	Completed	13 Feb 2015	P1	CityCare	Wellington Water
O/s 203 cockayne rd, ngaio, wgtm	WCC	Water	WCC2268061	0	W-P2 Major Leaks	27 Jul 2014	Completed	30 Jul 2014	P2	CityCare	Capacity
O/s 214 cockayne rd, ngaio, wgtm	WCC	Water	WCC2363439	0	W-P1 Urgent Fault	27 Jun 2015	Completed	08 Jul 2015	P1	CityCare	Wellington Water
O/s 238 cockayne rd, ngaio	WCC	Water	WCC2195530	0	W-Damage Caused By 3rd Party	29 Oct 2013	Completed	29 Oct 2013	P2	CityCare	Capacity
Opposite 142 cockayne road ngaio	WCC	Water	WCC2276416	0	W-P3 Minor Leaks	28 Aug 2014	Completed	09 Sep 2014	P3	CityCare	Capacity
Os 185 cockayne rd on roadngaiowgtn	WCC	Water	WCC2276407	0	W-P3 Minor Leaks	28 Aug 2014	Completed	01 Sep 2014	P3	CityCare	Capacity
Outside 240 cockayne road ngaio.	WCC	Water	WCC2240595	0	W-Toby Fault	09 Apr 2014	Completed	10 Apr 2014	P3	CityCare	Capacity
Square patch in road that has been sealed over o/s 95 cockayne road, ngaio	WCC	Water	WCC2192187	0	W-P3 Minor Leaks	17 Oct 2013	Completed	04 Nov 2013	P3	CityCare	Capacity



No.	Details	Data Source	ID asset	Asset ID	Asset Description
	Water leak on a main at the intersection of Cockayne rd and Setsan Way. It is leaking quite a lot of water into the construction site nearby. Detection company have already identified the leak, contact number for them is [REDACTED]	CityCare	3158363	WCC_PW019427	W-valve-199 cockayne rd ngaio-khandallah
	Caller is ringing to report a leaking fire Hydrant. Located on the road. Can someone please attend and assess.	Councils			
	On the corner of Cockayne rd and Punjab st theres a leaking fire hydrant. Caller said its been leaking for over a week now and its progressively getting worse. Please attend and assess fault.	Councils			
	Toby marked. Toby currently turned right down. When opened up water is visible in driveway.	Councils			
	Advised that there is water coming out of a Fire Hydrant in the road on Cockayne Rd and intersection of Punjab Street. It is lightly leaking.	Councils			
	g	Councils			
	Caller reported a steady amount of water coming off from a copper like water feed pipe across the road from 146 Cockayne Rd and running down the bank.	CityCare	3115313	WCC_PWP040477	W-pipe connection service-140 cockayne rd
	Leaking Pipes 148a COCKAYNE ROAD, Khandallah	Maximo			
	Caller thinks there is a burst pipe under property There is water coming from somewhere that is slowly leaking on to road but he says the grass area is very soggy and thinks water may be going under houses.	Councils			
	leaking SV	CityCare	3179305	WCC_PW019430	W-valve-161a cockayne rd ngaio-khandallah
	Road works are happening on the road, toby has been effected and is now leaking water. Can this please be fixed.	Councils			
	Leaking toby, Toby has small leak on connection.	Councils			
	Fault 167 Cockayne Rd Ngaio Wgtn	Maximo			
	URGENT water works happened this morning in this are but [REDACTED] has flushed her water at least three times but it is still extremely dirty. Please attend.	Councils			
	Caller noticed the area around the toby is really wet. It has been like that for some time. Please assess.	Councils			
	Caller reported lot of water gushing out from further up the road from her house. Caller advised that its coming from a water main, where the contractors were working earlier.	Councils			
	Caller advised they have noticed a water leak at number 173 Cockayne Rd. They are not the owners of this proeprty, however have noticed this from the street for a few months. You can hear the water running from the road and the leak is located halfway up there steps. Water is draining down the hill. Please investigate.	MagicBus		WCC_PW160272	Water valve: wcc_pw160272
	Leaking Pipes 173 COCKAYNE ROAD, Ngaio	Maximo	444871	WCC_PW160272	Wcc_pw160272 valve 20mm
	Burstmain hit by dews construction while they were doing work.	Councils			
	Minor leaking toby at this location.	CityCare	3236928	WCC_PW019460	W-valve-182 cockayne rd ngaio-khandallah
	Caller reports a leak coming from a nextdoor property which has been flowing across her driveway for a month or so now. Very minor leak but constantly flowing.	Councils			
	Downers are reinstating the footpath here but cannot continue until a toby leak is repaired	CityCare	3112062	WCC_PW083502	W-pipe connection service-188 cockayne rd
	URGENT [REDACTED] is from a trenching company who are currently laying a new water main and are getting lots of water coming out of the existing main. It is running in like a stream faster than they can dig. Please attend.	Councils			
	Leaking toby at this location, there is also an internal leak at this location that they are aware of, please repair toby.	Councils			
	198 Cockayne Road, Ngaio	Maximo			
	Water running from mains out on to the road	Councils			
	[REDACTED] from Dews Construction has phoned to advised that their contractors have hit water lateral, contact number is for [REDACTED], substantial amount of water coming out	Councils			
	204A Cockayne Road , Ngaio	Maximo			
	There is a water leak coming from the neighbors property please attend.	Councils			
	Caller would like someone to come and take a sample of a water leak as he is wandering if it is spring water or tap water	Councils			
	Fault 206A COCKAYNE ROAD, Ngaio	Maximo			



Caller is ringing to report water leaking from outside the property. There were recent works done in the area. can someone please attend.	Councils			
█ had a problem with a toby that was leaking a couple of months ago and he thinks may be the same problem as he is a property that sits underneath other properties so if any pipe was leaking it would come down onto his property and coming home from holiday he has noticed a large amount of water in the garden which has turned the grass a yellow colour	CityCare	3236931	WCC_PW048791	W-valve-199 cockayne rd ngaio-khandallah
Fault 210 Cockayne Road, Ngaio (ROVER)	Maximo	554309	WCC_PWP092225	Wcc_pwp092225 pipe pressure 20mm mdpe80
Outside property 214 where their has been previous work done on the footpath and road has now lifted with water gushing out. thanks	Councils			
Water spouting from pavement. Photo attached.	Councils			
Caller has advised that they were doing work and accidently hit a water main and it has split in half please attend	Councils			
Urgent - property has internal leak. Please locate and mark out.	CityCare	3245577	WCC_PW019476	W-valve-236 cockayne rd ngaio-khandallah
Leaking Pipes 231 COCKAYNE ROAD, Ngaio	Maximo	343375	WCC_PW019477	Wcc_pw019477 valve ball 0mm
Reinstatement: Leaking Pipes 231 COCKAYNE ROAD, Ngaio	Maximo	343375	WCC_PW019477	Wcc_pw019477 valve ball 0mm
Leaking Pipes 231 COCKAYNE ROAD, Ngaio	Maximo			
Caller has hit a black pipe with a blue tap and constant water flow going all over the place. She doesn't know what she can do as there is alot of water being wasted.	CityCare	3117656	WCC_PWP040479	W-pipe connection service-238 cockayne rd
Slow leaking toby. Located on the accessway which goes to 238-240 Cockayne RdNgaio.	CityCare	3242019	WCC_PW019475	W-valve-238 cockayne rd ngaio-khandallah
Caller has informed that there is water soming out of a pipe beside the garage at this location. Have asked caller if it is on private property as we do not deal with private property he has informed it is council land and not provate property. Have advised caller if this leak is on private property our contractors will not repair.	CityCare	3242019	WCC_PW019475	W-valve-238 cockayne rd ngaio-khandallah
Caller has advised vehicle has hit exposed water main and there is water gushing out onto the drive, please attend and repair.	CityCare	3242019	WCC_PW019475	W-valve-238 cockayne rd ngaio-khandallah
Called to report her toby box is leaking. A small flow but constant. Please attend.	CityCare	3245918	WCC_PW019496	W-valve-250 cockayne rd ngaio-khandallah
passing hydrant leak outside 256 Cockayne. has been marked by █ Please attend and fix as required. No need to call customer.	CityCare	3160855	WCC_PW001680	Wfht-256 cockayne rd ngaio-khandallah
Fire hydrant pouring water Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.252666,174.776825&amp;z=19">http://maps.google.co.nz/?q=-41.252666,174.776825&amp;z=19</a>	CityCare	3160855	WCC_PW001680	Wfht-256 cockayne rd ngaio-khandallah
h	Councils			
There is a steady flow of water coming out of the water toby. Caller said that it would be approx 2 litres flowing out per minute. Caller has also asked that unless it is necessary for further information required, please do not ring caller.	CityCare	3180165	WCC_PW019442	W-valve-256 cockayne rd ngaio-khandallah
Reinstatement InformationLocation : Type : Size (sq/m) : Other Details : Road : ASPHALT STILL TO BE DONE 24/6/15B4UDIG: 819415 23/06/2015RI ASSIGNED 12/6/15 - ASPHALT / CONCRETEReinstatement InformationLocation : Road, FootpathType : Asphalt, ConcreteSize (sq/m) : 1x1 ashphalt 1x1 curb .5x. 5 Ashlylt footpathOther Details : .Road : OpenGAS PLANS ATTACHED 10/06/2015There is a steady flow of water coming out of the water toby. Caller said that it would be approx 2 litres flowing out per minute. Caller has also asked that unless it is necessary for further information required, please do not ring caller. EM#[2492564] - do not delete this.	Councils			
Leaking Pipes 259 COCKAYNE ROAD, Ngaio	Maximo			
Leaking Pipes 259 COCKAYNE ROAD, Ngaio	Maximo			
A water main is leaking and pouring ot of a bank near the entrance to 267 Cockayne Road. Given the seepage from the nbank, it is l kely to cause subsidence very soon. Water is then flowing into two blocked sumps.	CityCare	3176040	WCC_PW019443	W-valve-267 cockayne rd ngaio-khandallah
There is a water leak coming from the road please attend	CityCare	3245616	WCC_PW019487	W-valve-267 cockayne rd ngaio-khandallah
I believe the council water main on Cockayne Road above our house is leaking. There is water constantly running down our driveway. This started after the November 14 earthquake. It is not associated with our own water supply which is well away from where the water is running. Nor is it associated with any other services on our property e.g. storm water as these are also a considerable distance away from where the water is running. There is also a slight flow of water on the road which would seem to be in about the same place as where it is running down	CityCare	3117663	WCC_PW019483	W-pipe connection service-263 cockayne rd

our driveway. We need this attended to as it makes our very steep driveway hazardous - very slippery					
PRIVATE LEAK 278 COCKAYNE ROAD, Ngaio	Maximo				
water leak	Councils				
I noticed the water connection on street making a lot of noise when I wa ked past it. Is it possibly leaking?	Councils				
Leaking Pipes 282 COCKAYNE ROAD, Khandallah	Maximo	323864	WCC_PW019485	Wcc_pw019485 valve ball 0mm	
SERVICE LEAK ON BANK NEED TO INSTALL BALLVALVE AND ABOUT 1M PIPE MARKED BY ROYCE SERVICE IN OLD PORIRUA ROAD	CityCare	3114607	WCC_PWP059745	W-pipe connection service-281 old porirua rd	
Quite a steady leak coming from toby	CityCare	3242075	WCC_PW083529	W-valve-286 cockayne rd ngaio-khandallah	
Large water leak in middle of road, flowing down from cockayne into Crofton Rd	Councils				
Minor leak coming up through ashphalt in middle of road outside 290 Cockayne Rd	Councils				
There is slow leak of water coming out of the road.	Councils				
Report of water coming up through the road surface outside 292. Can someone please attend.	Councils				
Water leak coming from asphalt outside location. Steady amount of water filling the gutters. Was a only a small wet patch in the weekend.	Councils				
Minor water leak in the left hand lane going up hill in the road.	Councils				
Water seeping from the side of the road underneath the asphalt. Photo attached. Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.254612,174.776199&amp;z=19">http://maps.google.co.nz/?q=-41.254612,174.776199&amp;z=19</a>	Councils				
Relates to 2298726 [REDACTED] is dealing with this property and would like to request please can a leak detection be done here to establish if theres any problems with the water main	Councils				
Steady flow of water gushing down the road. Caller has no other details.	Councils				
Caller has advised water flowing across road near corner of Old Porirua and Cockayne Rd in Ngaio. Logged as minor leak based on caller's description.	Councils				
Mark out, Cockayne Rd from Perth St to 239 Cockayne Rd (pipe bursting & replacing exist MHs)	Councils				
Mark out, for Cockayne Rd between Quetta St & Setsan Way Khandallah (sewer pipe bursting & replacing MHs)	Councils				
Mark out, Cockayne Street from Old Porirua Road to Khandallah	Councils				
Coner of Punjab and Cockayne Rd, leak coming from the toby	Councils				
RE: Water markout for Cockayne road from Old Porirua Road to Ellora	Councils				
ponding of water next to council utility building.looks like it is getting worse.unclear where water is coming from.  Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.2529551,174.780756&amp;amp;z=19">http://maps.google.co.nz/?q=-41.2529551,174.780756&amp;amp;z=19</a>	MagicBus				
Soaked ground, probable water leak uphill?	MagicBus				
Plumber reported there is a lot of water coming from a property at this address Also coming from the next door property as well which makes him believe it is a council mains issue. he said water is going into a power substation next to 189 so he believes it needs to be looked at quite urgently	MagicBus				
Refer 2831508. Caller wished to lay a formal complaint regarding the lack of service from both WCC and WW. There is a leak which he reported over 4mths ago which is flowing into his property at #189 and into the neighbouring property at #187, pooling in the front yard. He has done his own investigate and believes the leak originates from somewhere on Setsan Way, however leak detection still hasn't come back to him to advise of any findings or action. The leak has now become worse and starting to flood his property, his family are unable to use the front yard anymore for BBQs or kids to play on. He is very frustrated that this has taken so long with no result and would like WCC to step in and do something about it now. Please investigate and contact caller to discuss the matter further.	MagicBus				
small water leak in berm outside this address.	MagicBus				
Caller advised water leaking up through the concrete on road reserve near 199 Cockayne Rd, right at the end of the driveway to 199A and 201 Cockayne Rd. Started approx. 2 weeks ago, small flow. Please attend.	MagicBus				
Minor leak on footpath by garage and blue mai box unsure if private or Council	MagicBus				

continuous water leak coming out of side of hill, onto footpath and road	MagicBus			
Toby locate please	MagicBus		WCC_PW160206	Water valve: wcc_pw160206
Caller advised no water to her property at 206 Cockayne Rd. Please attend.	MagicBus			
Toby locate please	MagicBus			
Leak	MagicBus			
The water toby for our property is leaking. Can you please send a technician to fix it please.	MagicBus			
Water is coming from our retaining wall and under driveway concrete. Water appears to be coming from houses/driveway located in Ambala Way. Water volume from our /retaining wall/driveway had increased each day for the last couple of days.  Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.253926,174.776714&amp;map;z=19">http://maps.google.co.nz/?q=-41.253926,174.776714&amp;map;z=19</a>	MagicBus			
279 Cockayne Road + corner of Bendbrooke Way and Waikowhai Road Two significant leaks require repairing: - Leak 1 - 279 Cockayne Road. This has been leaking for at least 2 weeks and I'd estimate between 10 and 15 litres of water a minute (15,000 and 22,000 litres a day) is escaping. - Leak 2 - Corner of Bendbrooke way and Waikowhai street. Leak adjacent to toby. Has been leaking since pre-Xmas, failed attempt to fix it over a week ago. Still leaking up to 10,000 litres a day.	MagicBus		WCC_PW019492	Wcc_pw019492
Complaint - a private leak that is ongoing since September and nothing has been done regarding it. The garden is flooded and kids unable to play outside.	MagicBus			
Cnr of Cockayne Road and Punjab Street, Khandallah. There is a pipe that protrudes from the bank beside the road. This is leaking and is slowly eroding the bank behind the pipe.	MagicBus		WCC_PW163200	Water valve: wcc_pw163200
Burst water pipe somewhere near the road.	MagicBus			
The concern I am raising with you today is regarding the (apparently) never ending roadworks on Cockayne Road between Quetta and (now) Clutha streets. If you examine your records, you will see that I have raised requests in the past and each request has been met with an excellent response, clear, concise and actioned on point. I have returned my thanks on these past occasions. However, and it's a big however, the roadworks for the mains water and the sewerage are still going on, months after the advertised date of your subcontractor's due date of May 2015. I work from home and I live uphill from the road works so the noise is so bad I have wear headphones to get things done. I'm not asking for miracles but is there any way you can get an end date, as the chaps on the road have been digging up the same 5 stretches of road for 9 months day in and day out, weekends included and, in my experience as a project manager, things overrunning this long denote as very serious problem.	Councils			
Leaking Pipes COCKAYNE ROAD, Ngaio	Maximo			
Water coming out of manhole on road near 145 Cockayne Road. Not gushing out.	Councils			
There is a water leak at location site please attend. Please contact caller with the outcome.	Councils			
comms for NZ Bus reported his driver seeing a water leak coming from the footpath. Has been like this for the last couple of days Please assess.	Councils			
There is a water valve that is leaking.	CityCare	3160847	WCC_PW019439	W-valve-229 cockayne rd ngaio-khandallah
Intersection of Punjab and Cockayne Rd. Clear water. Seeping slowly accross the road.	Councils			
There is a minor water leak in the middle of the road. It is a steady flow and could fill a bucket in 3-4 minutes. Caller called this in a few days ago and has advised it has started back up again and is worse than it was before.	Councils			
Toby leaking quite badly and looks like it may burst if not looked at	Councils			
There is a leak on the tar seal in the road but it appears to be leaking underneath the tar seal and his property is directly underneath this and he has a lot of ground water so thinks its leaking from road onto his property	Councils			
From the edge of the footpath is a lot of water gushing up. The street has recently had its tobys replaced so not sure if anything to do with that or not but definatley needs someone to come out	Councils			
A truck has run over the water pipe that is attached to the toby and water is flowing out. Caller that rang this thru is working on another site but	CityCare	3117656	WCC_PW019475	W-pipe connection service-238 cockayne rd

	saw the truck hit the pipe. He says that if we want it, he will try and get the name of the truck that ran over the pipe.				
	Water leak coming out of a retaining wall	CityCare	3240547		W-meter cus manifold-142 cockayne rd ngaio-khandallah
	Water seeping out of FH and wet patch around top	CityCare	3179302	WCC_PW001673	Wfht-183 cockayne rd ngaio-khandallah
	Leaking toby.	CityCare	3242018	WCC_PW019474	W-valve-240 cockayne rd ngaio-khandallah
	water leaked out of sealed patch	Councils			



No.	Address	Council Ref ID	Water Type	Request ID	Request type	Comm Description	Date Created	Status	Resolution Date	Priority	Allocation	Responsible User
	4 crofton road, ngaio, wellington, 6035	WCC	Water	WCCSR-298308	System faults	Leaking Pipes	23 Dec 2021	90 closed (close)	30 Dec 2021	P3	007-WGTN-PW-RETC	
	4a crofton road, ngaio, wellington, 6035	WCC	Water	WCCSR-374116	System faults	Leaking Pipes	03 May 2022	31 on site work complete - may require reinstatement (jobcomp)	20 May 2022	P3	007-WGTN-PW-RETC-CONN-PIPE	
				WCCSR-374116R		Asphalt Reinstatement	03 May 2022	00 received (rcvd)		P4	007-WGTN-PW-RETC	
	5 crofton rd, ngaio, wellington	WCC	Water	WCC2772618	0	W-P3 Minor Leaks	01 Mar 2019	Completed	09 May 2019	P3	CityCare	City Care - Water
				WCC2795450	0	W-Reinstatment Issues	09 May 2019	Completed	06 Jun 2019	P4	CityCare	City Care - Water
	5 crofton rdngaiowgtn	WCC	Water	WCC2199027	0	W-P3 Minor Leaks	09 Nov 2013	Completed	10 Nov 2013	P3	CityCare	Capacity
	5 crofton rdngaiowgtn	WCC	Water	WCC2292058	0	W-Toby Fault	24 Oct 2014	Completed	24 Oct 2014	P3	CityCare	Wellington Water
	5 crofton road, ngaio, wellington, 6035	WCC	Water	WCCSR-297773	System faults	Leaking Pipes	22 Dec 2021	90 closed (close)	31 Dec 2021	P2	007-WGTN-PW-RETC	
	5a crofton rdngaiowgtn	WCC	Water	WCC2287504	0	W-P3 Minor Leaks	08 Oct 2014	Completed	08 Oct 2014	P3	CityCare	Wellington Water
				WCC2774693	0	W-P2 Major Leaks	07 Mar 2019	Cancelled	07 Mar 2019	P2	CityCare	City Care - Water
	6 crofton rdngaiowgtn	WCC	Water	WCC2571860	0	W-Toby Locate	20 May 2017	Completed	21 May 2017	P3	CityCare	City Care - Water
				WCC2658266	0	W-P3 Minor Leaks	28 Feb 2018	Completed	19 Apr 2018	P3	CityCare	City Care - Water
	6 crofton road, ngaio, wellington	WCC	Water	WCC2663671	0	W-P3 Minor Leaks	15 Mar 2018	Completed	04 May 2018	P3	CityCare	City Care - Water
	6 crofton road, ngaio, wellington, 6035	WCC	Water	WCCSR-30367		Instructed Works	18 Sep 2020	90 closed (close)	24 Sep 2020	P4	007-WGTN-PW-RETC	Notgiven DO NOT DELETE
	7 crofton rdngaiowgtn	WCC	Water	WCC2575225	0	W-P3 Minor Leaks	31 May 2017	Completed	02 Jun 2017	P3	CityCare	City Care - Water
				WCC2735256	0	W-P3 Minor Leaks	07 Nov 2018	Completed	06 Dec 2018	P3	CityCare	City Care - Water
	8 crofton road, ngaio, wellington, 6035	WCC	Water	WCCSR-55118	System faults	Leaking Pipes	04 Nov 2020	90 closed (close)	23 Nov 2020	P3	007-WGTN-PW-RETC	Notgiven DO NOT DELETE
	9 crofton rdngaiowgtn	WCC	Water	WCC2389817	0	W-P3 Minor Leaks	01 Oct 2015	Completed	01 Oct 2015	P3	CityCare	Wellington Water
	9 crofton road, ngaio, wellington, 6035	WCC	Water	WCCSR-338446	System faults	Leaking Pipes	01 Mar 2022	90 closed (close)	02 Mar 2022	P3	007-WGTN-PW-RETC	
				WCCSR-383394	System faults	Leaking Pipes	19 May 2022	90 closed (close)	19 May 2022	P2	007-WGTN-PW-RETC	
	9a crofton rdngaiowgtn	WCC	Water	WCC2389887	0	W-P3 Minor Leaks	01 Oct 2015	Completed	02 Oct 2015	P3	CityCare	Wellington Water
				WCC2796964	0	W-P3 Minor Leaks	14 May 2019	Completed	27 May 2019	P3	CityCare	City Care - Water
	9a crofton road, ngaio, wellington, 6035	WCC	Water	WCCSR-194597	System faults	Leaking Pipes	07 Jul 2021	90 closed (close)	12 Jul 2021	P1	007-WGTN-PW-RETC	Not Given
				WCCSR-194597R		Topsoil Reinstatement	07 Jul 2021	90 closed (close)	03 Aug 2021	P4	007-WGTN-PW-RETC	Not Given
				WCCSR-324833	System faults	Leaking Pipes	09 Feb 2022	31 on site work complete - may require reinstatement (jobcomp)	17 Mar 2022	P3	007-WGTN-PW-RETC-DIST-PIPE	
				WCCSR-324833R		Topsoil Reinstatement	09 Feb 2022	90 closed (close)	02 Apr 2022	P4	007-WGTN-PW-RETC-DIST-PIPE	
				WCCSR-336850	System faults	Leaking Pipes	27 Feb 2022	90 closed (close)	01 Mar 2022	P2	007-WGTN-PW-RETC	
				WCCSR-337513	System faults	Leaking Pipes	28 Feb 2022	90 closed (close)	01 Mar 2022	P2	007-WGTN-PW-RETC	Not Given
				WCCSR-337867	System faults	Leaking Pipes	01 Mar 2022	90 closed (close)	02 Mar 2022	P2	007-WGTN-PW-RETC	
				WCCSR-337952	System faults	Leaking Pipes	01 Mar 2022	90 closed (close)	02 Mar 2022	P3	007-WGTN-PW-RETC	
				WCCSR-338489	System faults	Leaking Pipes	02 Mar 2022	90 closed (close)	02 Mar 2022	P2	007-WGTN-PW-RETC	
				WCCSR-339086	System faults	Leaking Pipes	02 Mar 2022	90 closed (close)	07 Mar 2022	P3	007-WGTN-PW-RETC	Not Given



				WCCSR-339724	System faults	Leaking Pipes	03 Mar 2022	90 closed (close)	07 Mar 2022	P2	007-WGTN-PW-RETC	64211823439
				WCCSR-340854	System faults	Leaking Pipes	05 Mar 2022	90 closed (close)	07 Mar 2022	P2	007-WGTN-PW-RETC	██████
				WCCSR-341400	System faults	Leaking Pipes	07 Mar 2022	90 closed (close)	07 Mar 2022	P2	007-WGTN-PW-RETC	██████
				WCCSR-343169	System faults	Leaking Pipes	09 Mar 2022	90 closed (close)	10 Mar 2022	P2	007-WGTN-PW-RETC	Not Given
				WCCSR-343921	System faults	Leaking Pipes	10 Mar 2022	90 closed (close)	11 Mar 2022	P2	007-WGTN-PW-RETC	██████
				WCCSR-344063	System faults	Leaking Pipes	10 Mar 2022	90 closed (close)	11 Mar 2022	P2	007-WGTN-PW-RETC	██████
				WCCSR-363861	System faults	Leaking Pipes	13 Apr 2022	50 pre-claim, for review (preclaim)	20 May 2022	P3	007-WGTN-PW-RETC-DIST-PIPE	Not Given
				WCCSR-363861R		Asphalt Reinstatement	13 Apr 2022	50 pre-claim, for review (preclaim)	15 Jun 2022	P4	007-WGTN-PW-RETC	Not Given
				WCCSR-369339	System faults	Leaking Pipes	25 Apr 2022	90 closed (close)	28 Apr 2022	P2	007-WGTN-PW-RETC	██████
				WCCSR-370642	System faults	Leaking Pipes	27 Apr 2022	90 closed (close)	28 Apr 2022	P3	007-WGTN-PW-RETC	██████
				WCCSR-373087	System faults	Leaking Pipes	01 May 2022	90 closed (close)	03 May 2022	P3	007-WGTN-PW-RETC	██████
				WCCSR-376513	System faults	Leaking Pipes	06 May 2022	90 closed (close)	12 May 2022	P3	007-WGTN-PW-RETC	██████
9b crofton road, ngaio, wellington, 6035	WCC	Water		WCCSR-339069	System faults	Leaking Pipes	02 Mar 2022	90 closed (close)	07 Mar 2022	P2	007-WGTN-PW-RETC	██████
10 crofton rdngaio wgtn	WCC	Water		WCC2307874	0	W-Toby Fault	19 Dec 2014	Completed	23 Dec 2014	P3	CityCare	Wellington Water
10 crofton road, ngaio	WCC	Water		WCC2297533	0	W-Damage Caused By 3rd Party	13 Nov 2014	Completed	20 Nov 2014	P2	CityCare	Wellington Water
11 crofton road, ngaio, wellington, 6035	WCC	Water		WCCSR-343777	System faults	Leaking Pipes	10 Mar 2022	90 closed (close)	16 Mar 2022	P3	007-WGTN-PW-RETC	██████
15 crofton rd, ngaio, wellington	WCC	Water		WCC2709825	0	W-P3 Minor Leaks	11 Aug 2018	Completed	15 Aug 2018	P3	CityCare	City Care - Water
15 crofton road ngaio	WCC	Water		WCC2303800	0	W-P2 Major Leaks	05 Dec 2014	Completed	05 Dec 2014	P2	CityCare	Wellington Water
15 crofton road, ngaio, wellington, 6035	WCC	Water		WCCSR-75864	System faults	Leaking Pipes	14 Dec 2020	90 closed (close)	08 Jan 2021	P3	007-WGTN-PW-RETC	██████
				WCCSR-413077	System faults	Leaking Pipes	06 Jul 2022	00 received (rcvd)		P3	007-WGTN-PW-RETC	██████
16 crofton road, ngaio, wellington, 6035	WCC	Water		WCC2924430	System faults	Leaky or Faulty Connection/Meter/Toby	29 Aug 2020	Cancelled, raised in error (can)		P2	007-WGTN-PW-RETC	██████
17 crofton road, ngaio, wellington, 6035	WCC	Water		WCCSR-82274	System faults	Leaking Pipes	31 Dec 2020	90 closed (close)	05 Jan 2021	P3	007-WGTN-PW-RETC	██████
				WCCSR-294871		General Fault	17 Dec 2021	90 closed (close)	12 Jan 2022	P3	007-WGTN-PW-RETC-CONN-PIPE	Not Given
19 crofton road, ngaio, wellington, 6035	WCC	Water		WCCSR-239267	System faults	Leaky or Faulty Connection/Meter/Toby	24 Sep 2021	90 closed (close)	17 Mar 2022	P3	007-WGTN-PW-RETC-CONN-PIPE	██████
20 crofton rdngaio wgtn	WCC	Water		WCC2612787	0	W-P2 Major Leaks	30 Sep 2017	Completed	11 Oct 2017	P2	CityCare	City Care - Water
20 crofton road, ngaio, wellington	WCC	Water		WCC2458045	0	W-P2 Major Leaks	15 May 2016	Completed	16 May 2016	P2	CityCare	Wellington Water
20 crofton road, ngaio, wellington, 6035	WCC	Water		WCCSR-167630	System faults	Leaking Pipes	20 May 2021	90 closed (close)	23 Jul 2021	P3	007-WGTN-PW-RETC-CONN-VALV	██████
21 crofton rd, ngaio, wgtn	WCC	Water		WCC2587330	0	W-P2 Major Leaks	11 Jul 2017	Cancelled	11 Jul 2017	P2	CityCare	City Care - Water
21 crofton rdngaio wgtn	WCC	Water		WCC2449839	0	W-Damage Caused By 3rd Party	19 Apr 2016	Completed	21 Apr 2016	P2	CityCare	Wellington Water
21 crofton road, ngaio, wellington, 6035	WCC	Water		WCC2922757	System faults	Leaky or Faulty Connection/Meter/Toby	15 Aug 2020	90 closed (close)	05 Sep 2020	P3	007-WGTN-PW-RETC	██████
21-23 crofton road wellington ngaio	WCC	Water		WCC2587737	0	W-P3 Minor Leaks	12 Jul 2017	Cancelled	13 Jul 2017	P3	CityCare	City Care - Water
22- 24 crofton road, ngaio	WCC	Water		WCC2640924	0	W-P3 Minor Leaks	08 Jan 2018	Cancelled	09 Jan 2018	P3	CityCare	City Care - Water
23 crofton rdngaio wgtn	WCC	Water		WCC2216889	0	W-P1 Urgent Fault	16 Jan 2014	Completed	17 Jan 2014	P1	CityCare	Capacity
23 crofton road, ngaio, wellington, 6035	WCC	Water		WCC2921435	System faults	Leaky or Faulty Connection/Meter/Toby	05 Aug 2020	Cancelled, raised in error (can)		P3	007-WGTN-PW-RETC	██████ Not Taken
24 crofton road, ngaio, wellington	WCC	Water		WCC2642300	0	W-P3 Minor Leaks	12 Jan 2018	Cancelled	15 Jan 2018	P3	CityCare	City Care - Water



27 crofton rd ngaio wgtm	WCC	Water	WCC2644013	0	W-P1 Urgent Fault	18 Jan 2018	Completed	24 Mar 2018	P1	CityCare	City Care - Water
27 crofton rdngaio wgtm	WCC	Water	WCC2615335	0	W-P1 Urgent Fault	09 Oct 2017	Completed	16 Oct 2017	P1	CityCare	City Care - Water
27 crofton road, ngaio, wellington, 6035	WCC	Water	WCC2923758	System faults	Leaky or Faulty Connection/Meter/Toby	24 Aug 2020	Cancelled, raised in error (can)		P2	007-WGTN-PW-RETC	
29 crofton road, ngaio, wellington, 6035	WCC	Water	WCCSR-222477	System faults	Leaky or Faulty Connection/Meter/Toby	19 Aug 2021	90 closed (close)	19 Aug 2021	P3	007-WGTN-PW-RETC	
			WO-87161	System faults	Leaky or Faulty Connection/Meter/Toby	27 Jul 2021	31 on site work complete - may require reinstatement (jobcomp)	13 Oct 2021	P4	007-WGTN-PW-RETC-CONN-PIPE	
33a crofton road, ngaio, wellington, 6035	WCC	Water	WCC2921948	System faults	Leaky or Faulty Connection/Meter/Toby	08 Aug 2020	Cancelled, raised in error (can)		P2	007-WGTN-PW-RETC	
37 crofton rdngaio wgtm	WCC	Water	WCC2662052	0	W-P2 Major Leaks	11 Mar 2018	Completed	11 Mar 2018	P2	CityCare	City Care - Water
37 crofton road, ngaio	WCC	Water	WCC2655844	0	W-P3 Minor Leaks	22 Feb 2018	Completed	07 Mar 2018	P3	CityCare	City Care - Water
41 crofton rdngaio wgtm	WCC	Water	WCC2667619	0	W-Instructioned Works	28 Mar 2018	Completed	08 Apr 2018	P4	CityCare	City Care - Water
41 crofton road, 41 crofton road, ngaio, wellington	WCC	Water	WCC2810903	0	W-P3 Minor Leaks	28 Jun 2019	In progress	28 Jun 2019	P3	CityCare	City Care - Water
41 crofton road, ngaio, wellington, 6035	WCC	Water	WCCSR-147058	System faults	Leaking Pipes	18 Apr 2021	39 resolved (service restored)		P3	007-WGTN-PW-RETC	
			WCCSR-167630R		Asphalt Reinstatement	20 May 2021	90 closed (close)	28 Jul 2021	P4	007-WGTN-PW-RETC-CONN-VALV	
			WCCSR-189672	System faults	Leaking Pipes	29 Jun 2021	90 closed (close)	06 Jul 2021	P3	007-WGTN-PW-RETC	Not Given
51 crofton rdngaio wgtm	WCC	Water	WCC2600526	0	W-P3 Minor Leaks	21 Aug 2017	Completed	11 Oct 2017	P3	CityCare	City Care - Water
55 crofton road, ngaio, wellington, 6035	WCC	Water	WCCSR-328713	System faults	Leaking Pipes	15 Feb 2022	90 closed (close)	17 Mar 2022	P3	007-WGTN-PW-RETC-CONN-PIPE	
			WCCSR-328713R		Topsoil Reinstatement	15 Feb 2022	90 closed (close)	02 Apr 2022	P4	007-WGTN-PW-RETC-CONN-PIPE	
57 crofton rdngaio wgtm	WCC	Water	WCC2292636	0	W-Toby Fault	28 Oct 2014	Completed	12 Nov 2014	P3	CityCare	Wellington Water
Crofton rd	WCC	Water	WCC2247398	0	W-Mark Outs	06 May 2014	Completed	20 May 2014	P4	CityCare	Capacity
Crofton rd 2 crofton rd ngaio wgtm	WCC	Water	WCC2813246		Leaky Connection/Meter/Toby	05 Jul 2019	Completed	18 Jul 2019	P3	FH	FH
Crofton rd 3 crofton road, ngaio, wellington 6035, new zealand	WCC	Water	WCC2875751		Fault	27 Jan 2020	Cancelled		P3	FH	FH
Crofton rd 4 crofton rd ngaio wgtm	WCC	Water	WCC2895728		Leaky Connection/Meter/Toby	25 Mar 2020	Completed	01 Apr 2020	P3	FH	FH
Crofton rd 17 crofton road, ngaio, wellington 6035, new zealand	WCC	Water	WCC2889227		Leaking Pipes	05 Mar 2020	Completed	06 Mar 2020	P2	FH	FH
Crofton rd 22 crofton rd ngaio wgtm	WCC	Water	WCC2860984		Major Burst or Breakage	06 Dec 2019	Cancelled		P1	FH	FH
Crofton rd 41 crofton rd ngaio wgtm	WCC	Water	WCC2820328		Fault	29 Jul 2019	Completed	26 Sep 2019	P3	FH	FH
Crofton rd 41 crofton rd, ngaio, wellington 6035, new zealand	WCC	Water	WCC2849761		Leaky Connection/Meter/Toby	03 Nov 2019	Cancelled		P3	FH	FH
Crofton rd 49a crofton rd ngaio wgtm	WCC	Water	WCC2814384		Leaking Pipes	09 Jul 2019	Completed	10 Jul 2019	P2	FH	FH
Crofton rd crofton rd, ngaio	WCC	Water	WCC2879908		Leaky Connection/Meter/Toby	08 Feb 2020	Cancelled		P3	FH	FH
Crofton rd, ngaio	WCC	Water	WCC2642298	0	W-P3 Minor Leaks	12 Jan 2018	Cancelled	12 Jan 2018	P3	CityCare	City Care - Water



				WCC2655829	0	W-P3 Minor Leaks	22 Feb 2018	Completed	07 Mar 2018	P3	CityCare	City Care - Water
	Crofton rd, ngaio, wellington, 6035	WCC	Water	WCCSR-297375	System faults	Leaking Pipes	22 Dec 2021	90 closed (close)	23 Dec 2021	P2	007-WGTN-PW-RETC	[REDACTED]
				WCCSR-297507	System faults	Leaking Pipes	22 Dec 2021	90 closed (close)	23 Dec 2021	P3	007-WGTN-PW-RETC	[REDACTED]
				WCCSR-297906	System faults	Leaking Pipes	22 Dec 2021	90 closed (close)	23 Dec 2021	P2	007-WGTN-PW-RETC	[REDACTED]@gmail.com Not Given
				WCCSR-298011	System faults	Leaking Pipes	23 Dec 2021	90 closed (close)	23 Dec 2021	P2	007-WGTN-PW-RETC	Not Given
				WCCSR-298179	System faults	Leaking Pipes	23 Dec 2021	90 closed (close)	23 Dec 2021	P2	007-WGTN-PW-RETC	[REDACTED]
				WCCSR-327434		General Fault	14 Feb 2022	90 closed (close)	21 Feb 2022	P3	007-WGTN-PW-RETC	[REDACTED]
				WCCSR-377536	System faults	Leaking Pipes	09 May 2022	90 closed (close)	10 May 2022	P2	007-WGTN-PW-RETC	[REDACTED]
	Crofton road, ngaio	WCC	Water	WCC2307484	0	W-P1 Main Bursts	18 Dec 2014	Completed	18 Dec 2014	P1	CityCare	Wellington Water
	Imlay cres & crofton rd intersection ngaio wgtn	WCC	Water	WCC2641510	0	W-P3 Minor Leaks	10 Jan 2018	Completed	10 Apr 2018	P3	CityCare	City Care - Water
	Kenya st 18 crofton rd ngaio wgtn	WCC	Water	WCC2867475		Leaky Connection/Meter/Toby	30 Dec 2019	Cancelled		P3	FH	FH
	Lower part of imlay cres adj to 23 crofton rd , ngaio, wgtn	WCC	Water	WCC2217042	0	W-P2 Major Leaks	17 Jan 2014	Completed	17 Jan 2014	P2	CityCare	Capacity
	O.s 27 crofton rd, on cnr imlay and crofton road ngaio wgtn	WCC	Water	WCC2217210	0	W-P3 Minor Leaks	18 Jan 2014	Completed	21 Jan 2014	P3	CityCare	Capacity
	O/s 5 crofton road. ngaio.	WCC	Water	WCC2286909	0	W-P3 Minor Leaks	06 Oct 2014	Completed	30 Oct 2014	P3	WWL	[REDACTED]
	O/s 6 crofton road, ngaio.	WCC	Water	WCC2202888	No water calls to council	W-P1 No Water	20 Nov 2013	Completed	21 Nov 2013	P1	CityCare	Capacity
	O/s 6-8 crofton rd ngaio wgtn+A112:L116	WCC	Water	WCC2202884	0	W-Toby Fault	20 Nov 2013	Cancelled	21 Nov 2013	P3	CityCare	Capacity
	O/s around 25 crofton road. ngaio.	WCC	Water	WCC2283780	0	W-P3 Minor Leaks	24 Sep 2014	Completed	25 Sep 2014	P3	CityCare	Wellington Water
	Opposite 27 crofton road, ngaio wgtn	WCC	Water	WCC2289110	0	W-P3 Minor Leaks	14 Oct 2014	Completed	29 Oct 2014	P3	CityCare	Wellington Water
	Os 23 crofton rd ngaio wgtn	WCC	Water	WCC2587300	0	W-P1 Main Bursts	11 Jul 2017	Completed	18 Jul 2017	P1	CityCare	City Care - Water
	Perth st & crofton rd, ngaio, wellington, 6035	WCC	Water	WCCSR-224138	System faults	Leaking Pipes	24 Aug 2021	90 closed (close)	26 Aug 2021	P2	007-WGTN-PW-RETC	[REDACTED]





Leaking Pipes 9a CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes 9A CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes 9A Crofton Road, Ngaio (ROVER)	Maximo	630977	WCC_PWP006693	Wcc_pwp006693 pipe pressure 200mm ac	
Reinstatement: Leaking Pipes 9A Crofton Road, Ngaio (ROVER)	Maximo				
Leaking Pipes 9A Crofton Road, Ngaio	Maximo				
Leaking Pipes 9A Crofton Road, Ngaio	Maximo				
Leaking Pipes 9A Crofton Road, Ngaio	Maximo				
Leaking Pipes 9a CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes 9b CROFTON ROAD, Ngaio	Maximo				
Toby is leaking at a steady rate. Please assess.	Councils				
Water main hit with a sledgehammer.	CityCare	3203315	WCC_PWP006708	Reticulation main-9b crofton rd ngaio	
Leaking Pipes 11 Crofton Road, Ngaio	Maximo				
Water leak, seeping out from under footpath.	Councils				
copper pipe has been damaged. It is on the road way. The contractors have called it through. Water is leaking out onto the road	Councils				
Leaking Pipes 15 CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes 15 Crofton Road, Ngaio	Maximo				
Leaky Connection 16 Crofton Road, Ngaio, Wellington 6035, New Zealand	Maximo				
Leaking Pipes 17 CROFTON ROAD, Ngaio	Maximo				
Fault 17 Crofton Road, Ngaio	Maximo	1218773	WCC_PWP041792	Wcc_pwp041792 pipe pressure 20mm cu	
Leaky Connection 19 CROFTON ROAD, Ngaio	Maximo	1218773	WCC_PWP041792	Wcc_pwp041792 pipe pressure 20mm cu	
Not far from toby on berm there is a wet patch, the water is running along the road.	CityCare	3115187	WCC_PWP041800	W-pipe connection service-20 crofton rd	
Water coming from pipe at the side of the road. Very steady.	Councils				
Leaking Pipes 41 CROFTON ROAD, Ngaio (ROVER)	Maximo	337047	WCC_PW021005	Wcc_pw021005 valve ball 0mm	
Significant water flow from under new tarseal.	Councils				
Pipe has been knocked and damaged. Water leaking now. Can someone please attend and assess.	Councils				
Leaky Connection 21 Crofton Road, Ngaio, Wellington 6035, New Zealand	Maximo				
Leaking water Main valve on corner of inlay and Crofton Road. A leaking Main was fixed here last night, now the valve is leaking Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.253094,174.774826&amp;z=19">http://maps.google.co.nz/?q=-41.253094,174.774826&amp;z=19</a>	Councils				
A water pipe is leaking under the road between 22 & 24 Crofton Road, Ngaio. Water is flowing down the street from under what looks to be a recent asphalt patch	Councils				
This has already been reported to CC 2216868 but this caller is getting the overflow coming down into his section and flooding it. Is there anyway to deter the leak as it is going to wreck private property? please attend	Councils				
Leaky Connection 23 Crofton Rd Ngaio Wgtn	Maximo				
Leak in Road Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.2540905893596,174.774853661656&amp;z=19">http://maps.google.co.nz/?q=-41.2540905893596,174.774853661656&amp;z=19</a>	Councils				
B4UDIG 833614 4/12/17 Reinstatement Information Location : Road Type : Asphalt Size (sq/m) : 1x1 Other Details : . Road : Open ATTENDED BY ██████ MONDAY 09/10 Suspected Water burst at this location. Advised by ██████. EM#[3247332] - do not delete this.	CityCare	3115185	WCC_PW020994	W-pipe connection service-27 crofton rd	
ATTENDED BY ██████ MONDAY 09/10 Suspected Water burst at this location. Advised by ██████.	CityCare	3115185	WCC_PWP041793	W-pipe connection service-27 crofton rd	
Leaky Connection In middle of road potable water leak 27 Crofton Road, Ngaio, Wellington 6035, New Z	Maximo				
Leaky Connection 29 CROFTON ROAD, Ngaio	Maximo				
Toby fault 29 Crofton Road, Ngaio, Wellington, 6035	Maximo	1202786	WCC_PWP041795	Wcc_pwp041795 pipe pressure 20mm cu	
Leaky Connection 33A Crofton Road, Ngaio, Wellington 6035, New Zealand	Maximo				
Caller advised a large amount of water is spurting out of the toby at 37 Crofton Rd. Please assist.	Councils				

There is a minor leak here.	Councils				
Leaking Toby	CityCare	3236906	WCC_PW021005	W-valve-41 crofton rd ngaio	
Water Toby leaking badly. Has blue faded spray paint on it.	Councils				
LEAK DETECTION; 41 CROFTON ROAD, Ngaio	Maximo				
Reinstatement: Leaking Pipes 41 CROFTON ROAD, Ngaio (ROVER)	Maximo	337047	WCC_PW021005	Wcc_pw021005 valve ball 0mm	
Leaking Pipes 41 CROFTON ROAD, Ngaio	Maximo				
Caller advised that Toby is squirting water, small leak but reasonably high pressure.	CityCare	3240501	WCC_PW021008	W-valve-51 crofton rd ngaio	
Leaking Pipes 55 CROFTON ROAD, Ngaio	Maximo	612157	WCC_PWP041809	Wcc_pwp041809 pipe pressure 20mm cu	
Reinstatement: Leaking Pipes 55 CROFTON ROAD, Ngaio	Maximo	612157	WCC_PWP041809	Wcc_pwp041809 pipe pressure 20mm cu	
Toby water is trickling out. Lid is stiff.	CityCare	3203293	WCC_PW020986	Reticulation main-57 crofton rd ngaio	
Mark out, Crofton Rd from 22 to intersection of Perth St Ngaio (pipe bursting & replacing exist MHs)	Councils				
Caller advised that there is a leak near the water meter at this dairy. Unsure if this is a council pipe being affected. Please investigate.	MagicBus				
is it rain in an existing ulcer? or a leak? i'm not sure?	MagicBus				
Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.2519481,174.7734311&amp;map;zoom=19">http://maps.google.co.nz/?q=-41.2519481,174.7734311&amp;map;zoom=19</a>					
Leaking toby at this address. Advised by Glenis at Wellington Water	MagicBus		WCC_PW020990	Wcc_pw020990	
There is a major water leak from the Toby at 17 Crofton Road. Please attend.	MagicBus				
Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.2524552,174.7746341&amp;map;zoom=19">http://maps.google.co.nz/?q=-41.2524552,174.7746341&amp;map;zoom=19</a>					
Urgent toby shut off please. Pipe has burst under the house, but unable to turn the toby because it is jammed.	MagicBus				
Caller advised that there is a leaking from a toby at this address. Please fix.	MagicBus		WCC_PW021001	Wcc_pw021001	
Leaking water Toby on footpath outside number 41 Crofton road Ngaio.	MagicBus				
Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.2541213241151,174.775246582733&amp;map;zoom=19">http://maps.google.co.nz/?q=-41.2541213241151,174.775246582733&amp;map;zoom=19</a>					
Caller advised they have had this problem before. Advised the tree roots from the property above them get blocked in the pipes. Currently water coming down from the bank and now pooling next to callers house. It smells a bit so unsure if it is waste water or stormwater. Please Attend.	MagicBus				
Near the Phoenix takeaway, water is making potholes form, water is trickling out.	MagicBus				
Left hand side driving towards town. About halfway up Crofton Road. Leak spreading everywhere, but not fast. Very visible.	Councils				
Non urgent email request. Outside 15 and 37 Crofton Rd. Upon walking along this street tonight, it was very surprising to see the bad water leaks outside numbers 15 and 37 are still just as bad as they were in September last year and for some time before that. Given that we have been bombarded with radio advertising to remind us to watch our water usage and to only water our gardens on alternate days I am mystified as to why these leaks have not yet been repaired? So, as a concerned ratepayer I thought I should bring it to your attention again.	Councils				
Leaking Pipes CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes CROFTON ROAD, Ngaio	Maximo				
Fault CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes 9 CROFTON ROAD, Ngaio	Maximo				
Cnr Crofton Road and Kenya St. Water shooting up from the road. Not shooting up high but still a lot of water.	Councils				
Water leak	CityCare	3134686	WCC_PW097968	W-pipe connection service-45 imlay cres	
Caller reported leak in road at this location	MagicBus				
Water coming out at a different point from last nights repair, not gushing but quite a lot of water	CityCare	3176031	WCC_PW030973	W-valve-27 crofton rd ngaio	

Water main toby is leaking. Council was notified by neighbour previously, and vsited yesterday but is still leaking accoss driveway. Is not starting to erode tarseal.	CityCare	3176034	WCC_PW020984	W-valve-27 crofton rd ngaio
Slow but constant water leak here in the footpath.	Councils			
No water at property, also there is a water toby that is gushing water and leaking out onto the footpath and road.	Councils			
water is flowing out of water toby	Councils			
Water leaking from a toby here. Lid has been pushed up.	CityCare	3236895	WCC_PW020994	W-valve-27 crofton rd ngaio
There is a water leak on the road	CityCare	3236894	WCC_PWP041793	Tee-27 crofton rd ngaio
Caller advised that there is a lot of water coming out, reckons 4L a second coming out through the tarseal and going into the drain.	CityCare	3203315	WCC_PWP006708	Reticulation main-9b crofton rd ngaio
Leaking Pipes Perth St & Crofton Rd, Ngaio (ROVER)	Maximo			
details	Data_Sourc e	_id_ass et	asset id	asset description
Leaking Pipes 4 Crofton Road, Ngaio	Maximo			
Leaking Pipes 4A Crofton Rd, Ngaio, Wellington	Maximo	836833	WCC_PWP041788	Wcc_pwp041788 pipe pressure 20mm cu
Reinstatement: Leaking Pipes 4A Crofton Rd, Ngaio, Wellington	Maximo			
Minior leak under road, outside location.	Councils			
NOT COMPLETED RI ASSIGNED 13/03/19 - CAR R576389 15/03/19 Reinstatement Information Location : Road Type : Asphalt Size (sq/m) : 1 Other Details : Na Road : Open ATMS LEAK PLANS ATTACHED 06/03/19 Minior leak under road, outside location. EM#[3644584] - do not delete this.	Councils			
Please turn the toby off at number 5 Crofton Road as there is a major leak on this property that looks to be a private leak. The caller lives next door and doesn't think anyone is home until Monday.	Councils			
Burst pipe in house, toby will not shut off	Councils			
Leaking Pipes 5 CROFTON ROAD, Ngaio	Maximo			
leaking ball valve	Councils			
Caller advised lots of water flowing through the tarseal on road, approx. 300mm fom kerb directly outside 5a Crofton Rd. Filling up road channel and flowing straight into sumps. Please attend.	Councils			
Big leak on property pls locate toby and shut off water	Councils			
Just up from stairs of 6 Crofton Rd, but near cnr house of 8 Crofton Rd. Water is coming up from underneath the tarseal on the road and flowing down the guttering.	Councils			
Leaking water mains under road. Location on Google Map: <a href="http://maps.google.co.nz/?q=41.2523077576985,174.773935340345&amp;z=19">http://maps.google.co.nz/?q=41.2523077576985,174.773935340345&amp;z=19</a>	CityCare	3236892	WCC_PW020993	W-valve-6 crofton rd ngaio
PRIVATE LEAK - Leaking Pipes 6 Crofton Road	Maximo			
Caller advised that there is water leaking up through the road. Caller advised that it is just a minor leak. Please assist.	Councils			
Caller advised there is a water leak from the front lawn outside 7 Crofton Rd, webmap clearly shows mains pipe in the area. Going for approx 3 days now, flowing out of lawn area with no specific point it is coming from. Please assist.	CityCare	3190612	WCC_PWP006693	Reticulation main-9b crofton rd ngaio
Leaking Pipes 8 CROFTON ROAD, Ngaio	Maximo			
Steady flow of water seeping from a WCC valve on the private driveway of 9 Crofton Rd. Ngaio.	Councils			
Leaking Pipes 9 CROFTON ROAD, Ngaio	Maximo			
Leaking Pipes 9 CROFTON ROAD, Ngaio	Maximo			
Slow leak from toby. Filled box and case.	Councils			
Water seepage between road and toby	Councils			
Leaking Pipes 9a CROFTON ROAD, Ngaio	Maximo			
Reinstatement: Leaking Pipes 9a CROFTON ROAD, Ngaio	Maximo			
Leaking Pipes 9A Crofton Road, Ngaio (ROVER)	Maximo	630977	WCC_PWP006693	Wcc_pwp006693 pipe pressure 200mm ac
Reinstatement: Leaking Pipes 9A Crofton Road, Ngaio (ROVER)	Maximo	630977	WCC_PWP006693	Wcc_pwp006693 pipe pressure 200mm ac
Leaking Pipes 9a CROFTON ROAD, Ngaio	Maximo			

Leaking Pipes 9a CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes 9A CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes 9A CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes 9a CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes 9a CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes 9A CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes 9a CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes 9a CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes 9a CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes 9a CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes 9A Crofton Road, Ngaio (ROVER)	Maximo	630977	WCC_PWP006693	Wcc_pwp006693 pipe pressure 200mm ac	
Reinstatement: Leaking Pipes 9A Crofton Road, Ngaio (ROVER)	Maximo				
Leaking Pipes 9A Crofton Road, Ngaio	Maximo				
Leaking Pipes 9A Crofton Road, Ngaio	Maximo				
Leaking Pipes 9A Crofton Road, Ngaio	Maximo				
Leaking Pipes 9a CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes 9b CROFTON ROAD, Ngaio	Maximo				
Toby is leaking at a steady rate. Please assess.	Councils				
Water main hit with a sledgehammer.	CityCare	3203315	WCC_PWP006708	Reticulation main-9b crofton rd ngaio	
Leaking Pipes 11 Crofton Road, Ngaio	Maximo				
Water leak, seeping out from under footpath.	Councils				
copper pipe has been damaged. It is on the road way. The contractors have called it through. Water is leaking out onto the road	Councils				
Leaking Pipes 15 CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes 15 Crofton Road, Ngaio	Maximo				
Leaky Connection 16 Crofton Road, Ngaio, Wellington 6035, New Zealand	Maximo				
Leaking Pipes 17 CROFTON ROAD, Ngaio	Maximo				
Fault 17 Crofton Road, Ngaio	Maximo	1218773	WCC_PWP041792	Wcc_pwp041792 pipe pressure 20mm cu	
Leaky Connection 19 CROFTON ROAD, Ngaio	Maximo	1218773	WCC_PWP041792	Wcc_pwp041792 pipe pressure 20mm cu	
Not far from toby on berm there is a wet patch, the water is running along the road.	CityCare	3115187	WCC_PWP041800	W-pipe connection service-20 crofton rd	
Water coming from pipe at the side of the road. Very steady.	Councils				
Leaking Pipes 41 CROFTON ROAD, Ngaio (ROVER)	Maximo	337047	WCC_PW021005	Wcc_pw021005 valve ball 0mm	
Significant water flow from under new tarseal.	Councils				
Pipe has been knocked and damaged. Water leaking now. Can someone please attend and assess.	Councils				
Leaky Connection 21 Crofton Road, Ngaio, Wellington 6035, New Zealand	Maximo				
Leaking water Main valve on corner of inlay and Crofton Road. A leaking Main was fixed here last night, now the valve is leaking Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.253094,174.774826&amp;z=19">http://maps.google.co.nz/?q=-41.253094,174.774826&amp;z=19</a>	Councils				
A water pipe is leaking under the road between 22 & 24 Crofton Road, Ngaio. Water is flowing down the street from under what looks to be a recent asphalt patch	Councils				
This has already been reported to CC 2216868 but this caller is getting the overflow coming down into his section and flooding it. Is there anyway to deter the leak as it is going to wreck private property? please attend	Councils				
Leaky Connection 23 Crofton Rd Ngaio Wgtn	Maximo				
Leak in Road Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.2540905893596,174.774853661656&amp;z=19">http://maps.google.co.nz/?q=-41.2540905893596,174.774853661656&amp;z=19</a>	Councils				
B4UDIG 833614 4/12/17 Reinstatement Information Location : Road Type : Asphalt Size (sq/m) : 1x1 Other Details : . Road :	CityCare	3115185	WCC_PW020994	W-pipe connection service-27 crofton rd	



Open ATTENDED BY █████ MONDAY 09/10 Suspected Water burst at this location. Advised by █████. EM#[3247332] - do not delete this.					
ATTENDED BY █████ MONDAY 09/10 Suspected Water burst at this location. Advised by █████	CityCare	3115185	WCC_PWP041793	W-pipe connection service-27 crofton rd	
Leaky Connection In middle of road potable water leak 27 Crofton Road, Ngaio, Wellington 6035, New Z	Maximo				
Leaky Connection 29 CROFTON ROAD, Ngaio	Maximo				
Toby fault 29 Crofton Road, Ngaio, Wellington, 6035	Maximo	1202786	WCC_PWP041795	Wcc_pwp041795 pipe pressure 20mm cu	
Leaky Connection 33A Crofton Road, Ngaio, Wellington 6035, New Zealand	Maximo				
Caller advised a large amount of water is spurting out of the toby at 37 Crofton Rd. Please assist.	Councils				
There is a minor leak here.	Councils				
Leaking Toby	CityCare	3236906	WCC_PW021005	W-valve-41 crofton rd ngaio	
Water Toby leaking badly. Has blue faded spray paint on it.	Councils				
LEAK DETECTION; 41 CROFTON ROAD, Ngaio	Maximo				
Reinstatement: Leaking Pipes 41 CROFTON ROAD, Ngaio (ROVER)	Maximo	337047	WCC_PW021005	Wcc_pw021005 valve ball 0mm	
Leaking Pipes 41 CROFTON ROAD, Ngaio	Maximo				
Caller advised that Toby is squirting water, small leak but reasonably high pressure.	CityCare	3240501	WCC_PW021008	W-valve-51 crofton rd ngaio	
Leaking Pipes 55 CROFTON ROAD, Ngaio	Maximo	612157	WCC_PWP041809	Wcc_pwp041809 pipe pressure 20mm cu	
Reinstatement: Leaking Pipes 55 CROFTON ROAD, Ngaio	Maximo	612157	WCC_PWP041809	Wcc_pwp041809 pipe pressure 20mm cu	
Toby water is trickling out. Lid is stiff.	CityCare	3203293	WCC_PW020986	Reticulation main-57 crofton rd ngaio	
Mark out, Crofton Rd from 22 to intersection of Perth St Ngaio (pipe bursting & replacing exist MHs)	Councils				
Caller advised that there is a leak near the water meter at this dairy. Unsure if this is a council pipe being affected. Please investigate.	MagicBus				
is it rain in an existing ulcer? or a leak? i'm not sure?  Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.2519481,174.7734311&amp;map;z=19">http://maps.google.co.nz/?q=-41.2519481,174.7734311&amp;map;z=19</a>	MagicBus				
Leaking toby at this address. Advised by Glenis at Wellington Water	MagicBus		WCC_PW020990	Wcc_pw020990	
There is a major water leak from the Toby at 17 Crofton Road. Please attend. Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.2524552,174.7746341&amp;map;z=19">http://maps.google.co.nz/?q=-41.2524552,174.7746341&amp;map;z=19</a>	MagicBus				
Urgent toby shut off please. Pipe has burst under the house, but unable to turn the toby because it is jammed.	MagicBus				
Caller advised that there is a leaking from a toby at this address. Please fix.	MagicBus		WCC_PW021001	Wcc_pw021001	
Leaking water Toby on footpath outside number 41 Crofton road Ngaio.  Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.2541213241151,174.775246582733&amp;map;z=19">http://maps.google.co.nz/?q=-41.2541213241151,174.775246582733&amp;map;z=19</a>	MagicBus				
Caller advised they have had this problem before. Advised the tree roots from the property above them get blocked in the pipes. Currently water coming down from the bank and now pooling next to callers house. It smells a bit so unsure if it is waste water or stormwater. Please Attend.	MagicBus				
Near the Phoenix takeaway, water is making potholes form, water is trickling out.	MagicBus				
Left hand side driving towards town. About halfway up Crofton Road. Leak spreading everywhere, but not fast. Very visible.	Councils				
Non urgent email request. Outside 15 and 37 Crofton Rd. Upon walking along this street tonight, it was very surprising to see the bad water leaks outside numbers 15 and 37 are still just as bad as they were in September last year and for some time before that. Given that we have been bombarded with radio advertising to remind us to watch our water usage and to only water our gardens on alternate days I am mystified as to why these leaks have not yet been repaired? So, as a concerned ratepayer I thought I should bring it to your attention again.	Councils				
Leaking Pipes CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes CROFTON ROAD, Ngaio	Maximo				
Leaking Pipes CROFTON ROAD, Ngaio	Maximo				

Leaking Pipes CROFTON ROAD, Ngaio	Maximo			
Leaking Pipes CROFTON ROAD, Ngaio	Maximo			
Fault CROFTON ROAD, Ngaio	Maximo			
Leaking Pipes 9 CROFTON ROAD, Ngaio	Maximo			
Cnr Crofton Road and Kenya St. Water shooting up from the road. Not shooting up high but still a lot of water.	Councils			
Water leak	CityCare	3134686	WCC_PW097968	W-pipe connection service-45 imlay cres
Caller reported leak in road at this location	MagicBus			
Water coming out at a different point from last nights repair, not gushing but quite a lot of water	CityCare	3176031	WCC_PW030973	W-valve-27 crofton rd ngaio
Water main toby is leaking. Council was notified by neighbour previously, and vsited yesterday but is still leaking across driveway. Is not starting to erode tarseal.	CityCare	3176034	WCC_PW020984	W-valve-27 crofton rd ngaio
Slow but constant water leak here in the footpath.	Councils			
No water at property, also there is a water toby that is gushing water and leaking out onto the footpath and road.	Councils			
water is flowing out of water toby	Councils			
Water leaking from a toby here. Lid has been pushed up.	CityCare	3236895	WCC_PW020994	W-valve-27 crofton rd ngaio
There is a water leak on the road	CityCare	3236894	WCC_PWP041793	Tee-27 crofton rd ngaio
Caller advised that there is a lot of water coming out, reckons 4L a second coming out through the tarseal and going into the drain.	CityCare	3203315	WCC_PWP006708	Reticulation main-9b crofton rd ngaio
Leaking Pipes Perth St & Crofton Rd, Ngaio (ROVER)	Maximo			

No.	Address	Council Ref ID	Water Type	Request ID	Request type	Comm Description	Date Created	Status	Resolution Date	Priority	Allocation	Responsible User
	1 ellora stngaiowgtn	WCC	Water	WCC2727413	0	W-Instructed Works	11 Oct 2018	Completed	19 Nov 2018	P4	CityCare	City Care - Water
	5 ellora st ngaio wgn	WCC	Water	WCC2800853	0	W-Instructed Works	26 May 2019	In progress	27 May 2019	P4	CityCare	City Care - Water
	9 ellora stngaiowgtn	WCC	Water	WCC2523779	0	W-P3 Minor Leaks	14 Dec 2016	Cancelled	15 Dec 2016	P3	CityCare	City Care - Water
	11 ellora stngaiowgtn	WCC	Water	WCC2522379	0	W-P3 Minor Leaks	10 Dec 2016	Completed	11 Jan 2017	P3	CityCare	City Care - Water
	14 ellora street ngaio.	WCC	Water	WCC2240591	0	W-Toby Fault	09 Apr 2014	Completed	09 Apr 2014	P3	CityCare	Capacity
	18 ellora stngaiowgtn	WCC	Water	WCC2327883	0	W-P3 Minor Leaks	03 Mar 2015	Completed	04 Mar 2015	P3	CityCare	Wellington Water
	18 ellora street, ngaio	WCC	Water	WCC2554047	0	W-P3 Minor Leaks	24 Mar 2017	Completed	27 Mar 2017	P3	CityCare	City Care - Water
	18 ellora street, ngaio, wellington, 6035	WCC	Water	WCCSR-56055	System faults	Leaking Pipes	06 Nov 2020	90 closed (close)	16 Nov 2020	P3	007-WGTN-PW-RETC	
				WCCSR-56055R		Asphalt Reinstatement	06 Nov 2020	90 closed (close)	23 Dec 2020	P4	007-WGTN-PW-RETC	
				WO-22797		Instructed Works	01 Dec 2020	90 closed (close)	01 Apr 2022	P4	007-WGTN-PW-RETC-DIST-PIPE	
	Ellora st 20 ellora st ngaio wgn	WCC	Water	WCC2882710		Fault	16 Feb 2020	Cancelled		P3	FH	FH
	O/s 18 ellora st, ngaio, wgn	WCC	Water	WCC2552561	0	W-Damage Caused By 3rd Party	20 Mar 2017	Completed	21 Mar 2017	P2	CityCare	City Care - Water
	O/s 18 ellora stngaiowgtn	WCC	Water	WCC2198159	0	W-P2 Major Leaks	06 Nov 2013	Completed	12 Nov 2013	P2	CityCare	Capacity



No.	Details	Data Source	ID asset	Asset ID	Asset Description
	Leaking Toby (small)	Councils			
	21/05/2019 06:01:52 EM Services 2010 Ltd: Note needs box to be raised currently set too low CAR R593684 26/05/19 RELATED TO JOB REF 3622783 - 2787003 Reinstatement Information Location : Footpath Type : Asphalt Size (sq/m) : 1x1 Other Details : 00 Road : Open PLANS ATTACHED 16/04/19 The cause is not ground water as there is a water pipe located adjacent to the bank. The leak is most probably from there. I have previously visited the site and engineers have assessed the bank as to be a low risk. [REDACTED] Structures Engineer B.E.(Hons)Civil; M.Eng(Civil)   Wellington City Council P 04 803 8691  M [REDACTED]   F E [REDACTED] @wcc.govt.nz   W Wellington.govt.nz   ALL INFO IN LINKS. EM#[3658267] - do not delete this.	Councils			
	Near boundary of 9 & 11 Ellora St Ngaio. Water continuously pouring out of pipe above kerb. The pipe was installed when contractors upgraded the water on the street earlier in the year. Water has been continuous and regular for some time regardless of the weather.	Councils			
	Leak is coming little bank, water coming out of a white pipe outside location.	Councils			
	Leaking water toby	CityCare	3308565	WCC_PW023899	W-valve-12 ellora st ngaio
	Leaking fire hydrant on the footpath needs to be rewashered. Royce	CityCare	3160862	WCC_PW002312	Wfht-18 ellora st ngaio
	Relate: 2552561. The water main at this address was recently fixed after it was accidentally damaged by downer. The pipe is still leaking near the toby box and needs to be fixed again.	Councils			
	Leaking Pipes 18 ELLORA STREET, Ngaio	Maximo			
	Reinstatement: Leaking Pipes 18 ELLORA STREET, Ngaio	Maximo			
	Service request 18 Ellora Street, Ngaio, Wellington 6035	Maximo	828043	WCC_PWP093129	Wcc_pwp093129 pipe pressure 50mm pe 9
	Approx 20 Ellora St	MagicBus			
	Downers have clipped a water lateral and will need someone out urgently please	Councils			
	Strong leak from hydrant.	CityCare	3160862	WCC_PW002312	Wfht-18 ellora st ngaio



No.	Address	Council Ref ID	Water Type	Request ID	Request type	Comm Description	Date Created	Status	Resolution Date	Priority	Allocation	Responsible User
	5 imlay cresngaiowgtn	WCC	Water	WCC2485447	0	W-P3 Minor Leaks	15 Aug 2016	Completed	16 Aug 2016	P3	CityCare	City Care - Water
				WCC2525388	0	W-P3 Minor Leaks	20 Dec 2016	Completed	28 Dec 2016	P3	CityCare	City Care - Water
	6 imlay cresngaiowgtn	WCC	Water	WCC2238158	No water calls to council	W-P1 No Water	01 Apr 2014	Completed	01 Apr 2014	P1	CityCare	Capacity
				WCC2249061	0	W-Instructed Works	12 May 2014	Completed	14 May 2014	P4	CityCare	Capacity
	12 imlay cresngaiowgtn	WCC	Water	WCC2164067	0	W-P3 Minor Leaks	10 Jul 2013	Completed	12 Jul 2013	P3	CityCare	Capacity
	13 imlay cresngaiowgtn	WCC	Water	WCC2231996	0	W-P3 Minor Leaks	11 Mar 2014	Completed	12 Mar 2014	P3	CityCare	Capacity
				WCC2464744	0	W-P1 Urgent Fault	04 Jun 2016	Completed	09 Jun 2016	P1	CityCare	Wellington Water
				WCC2508096	0	W-P3 Minor Leaks	28 Oct 2016	Completed	03 Nov 2016	P3	CityCare	City Care - Water
	16 imlay cresngaiowgtn	WCC	Water	WCC2389001	0	W-P3 Minor Leaks	28 Sep 2015	Completed	29 Oct 2015	P3	CityCare	Wellington Water
				WCC2393997	0	W-Enquiry to Engineer	15 Oct 2015	Completed	02 Nov 2015	P4	WWL	
	19 imlay cres ngaio wgtm	WCC	Water	WCC2807573		Leaking Pipes	17 Jun 2019	Completed	23 Aug 2019	P3	FH	FH
	24 imlay cresngaiowgtn	WCC	Water	WCC2381799	0	W-P2 Major Leaks	01 Sep 2015	Completed	01 Sep 2015	P2	CityCare	Wellington Water
	31 imlay cresngaiowgtn	WCC	Water	WCC2316747	0	W-P3 Minor Leaks	25 Jan 2015	Completed	13 Feb 2015	P3	CityCare	Wellington Water
				WCC2528446	0	W-P2 Major Leaks	06 Jan 2017	Completed	06 Jan 2017	P2	CityCare	City Care - Water
				WCC2738828	0	W-P1 Urgent Fault	18 Nov 2018	Completed	18 Nov 2018	P1	CityCare	City Care - Water
	35 imlay cresngaiowgtn	WCC	Water	WCC2345861	0	W-P1 Urgent Fault	01 May 2015	Completed	02 May 2015	P1	CityCare	Wellington Water
	39 imlay crescent, ngaio, wellington, 6035	WCC	Water	WCCSR-78465	System faults	Leaking Pipes	18 Dec 2020	90 closed (close)	08 Jan 2021	P3	007-WGTN-PW-RETC	
	39 imlay cresngaiowgtn	WCC	Water	WCC2727400	0	W-Private Leaks	11 Oct 2018	Completed	16 Oct 2018	P3	CityCare	City Care - Water
	39a imlay crescent, ngaio, wellington, 6035	WCC	Water	WCCSR-289128		Instructed Works	09 Dec 2021	30 in progress		P4	007-WGTN-PW-RETC	
	41 imlay cres, ngaio, wgtm	WCC	Water	WCC2522212	0	W-P3 Minor Leaks	09 Dec 2016	Completed	14 Dec 2016	P3	CityCare	City Care - Water
	41 imlay cresngaiowgtn	WCC	Water	WCC2523094	0	W-Enquiry to Engineer	13 Dec 2016	Cancelled	13 Dec 2016	P4	CityCare	City Care - Water
				WCC2523649	0	W-Enquiry to Engineer	14 Dec 2016	Cancelled	15 Dec 2016	P4	CityCare	City Care - Water
				WCC2536388	0	W-P3 Minor Leaks	01 Feb 2017	Cancelled	01 Feb 2017	P3	CityCare	City Care - Water
				WCC2543683	0	W-P3 Minor Leaks	22 Feb 2017	Completed	07 Mar 2017	P3	CityCare	City Care - Water
				WCC2787576	0	W-P3 Minor Leaks	12 Apr 2019	Completed	17 Apr 2019	P3	CityCare	City Care - Water
	43 imlay cresngaiowgtn	WCC	Water	WCC2757399	0	W-P3 Minor Leaks	19 Jan 2019	Completed	04 Feb 2019	P3	CityCare	City Care - Water
	43b imlay cresngaiowgtn	WCC	Water	WCC2757420	0	W-P2 Major Leaks	19 Jan 2019	Completed	26 Jan 2019	P2	CityCare	City Care - Water
	43c imlay crescent, ngaio, wellington, 6035	WCC	Water	WCCSR-123530	System faults	Leaking Pipes	14 Mar 2021	90 closed (close)	31 Mar 2021	P3	007-WGTN-PW-RETC	Not Given
	43c imlay cresngaiowgtn	WCC	Water	WCC2388230	0	W-P3 Minor Leaks	25 Sep 2015	Cancelled	28 Sep 2015	P3	CityCare	Wellington Water
				WCC2388627	0	W-P1 Main Bursts	27 Sep 2015	Completed	27 Sep 2015	P1	CityCare	Wellington Water
	45 imlay cresngaiowgtn	WCC	Water	WCC2216157	0	W-P2 Major Leaks	14 Jan 2014	Completed	16 Jan 2014	P2	CityCare	Capacity
	51 imlay crescent, ngaio, wellington	WCC	Water	WCC2641940	0	W-P3 Minor Leaks	11 Jan 2018	Cancelled	12 Jan 2018	P3	CityCare	City Care - Water
				WCC2642197	0	W-P3 Minor Leaks	12 Jan 2018	Cancelled	12 Jan 2018	P3	CityCare	City Care - Water
	Directly down from 43c imlay cresngaiowgtn	WCC	Water	WCC2216868	0	W-P3 Minor Leaks	16 Jan 2014	Completed	17 Jan 2014	P3	CityCare	Capacity
	Entrance of imlay cresngaiowgtn	WCC	Water	WCC2250791	0	W-P3 Non Urgent Fault	19 May 2014	Cancelled	19 May 2014	P3	CityCare	Capacity

	Imlay cres	WCC	Water	WCC2296287	0	W-P3 Minor Leaks	09 Nov 2014	Completed	10 Nov 2014	P3	CityCare	Wellington Water
	Imlay cres 39 Imlay cres	WCC	Water	WCC2825228		Fault - Third Party Damage	13 Aug 2019	Completed	13 Aug 2019	P2	FH	FH
	Imlay cres & crofton rd intersection ngaio wgt	WCC	Water	WCC2641510	0	W-P3 Minor Leaks	10 Jan 2018	Completed	10 Apr 2018	P3	CityCare	City Care - Water
	Lower part of Imlay cres adj to 23 Crofton rd, ngaio, wgt	WCC	Water	WCC2217042	0	W-P2 Major Leaks	17 Jan 2014	Completed	17 Jan 2014	P2	CityCare	Capacity
	Lower part of Imlay cres, ngaio	WCC	Water	WCC2215642	0	W-P3 Minor Leaks	13 Jan 2014	Cancelled	17 Jan 2014	P3	CityCare	Capacity
	Lower part of Imlay cres ngaio wgt	WCC	Water	WCC2251071	0	W-P3 Minor Leaks	19 May 2014	Completed	21 May 2014	P3	CityCare	Capacity
	Unit 4/6 Imlay cres ngaio wgt	WCC	Water	WCC2288695	0	W-P3 Minor Leaks	13 Oct 2014	Completed	12 Nov 2014	P3	CityCare	Wellington Water



No.	Details	Data Source	ID asset	Asset ID	Asset Description
	Caller reporting a leaky water meter on the bank, that joins the water meter to the toby. A test water meter apparently. Just where its fastened to the main pipe/toby.	Councils			
	Caller has advised a minor leakin coming from below the meterbox going into the gutter from this location. Please assess.	CityCare	3239331	WCC_PW030976	W-valve-3 imlay cres ngaio
	Reinstatement InformationLocation : Type : Size (sq/m) : Other Details : Road : NO CHARGE TO CITY CARE - REWORKS AS PER CHARLES 7/3 - Defect/s Identified: Footpath reinstatement non compliant to the 1m rule Remedial Work/s Required: Need to digout footpath reinstatement, and extend to edges within 1m and reinstate inaccordance with spec 5.6.1 and 5.6.2 NCOPI The Utility Operator is required to undertake the remedial work by: 21/03/2014 B4UDIG 803727 9/12 - ASSIGNED TO EMS 9/12Reinstatement InformationLocation : RoadType : AsphaltSize (sq/m) : 3x4Other Details : imlay crescent ngaio.Road : OpenNo water EM#[2143986] - do not delete this.	Councils			
	Hydrant has seized need to be able to turn on & off fo [REDACTED] to carry out contra flow test	CityCare	3157877	WCC_PW003514	Wfht-3 imlay cres ngaio
	minor leak from toby	Councils			
	Slow leaking water on the road for the last 48 hours.	Councils			
	Theres a pipe coming out of the embankment which is spraying quite a lot of water out of a pipe. [REDACTED] is sure that this is a council pipe not private. It also has not affected his water at all so doesn't appear to be affecting his property.	Councils			
	Leaking water coming from council pathway next to callers property and it is leaking onto his property. Steady flow.	Councils			
	Water works have been done in this street however now there is water pooling down from the road and trickling down the stairs to callers property. She is unaware of where the water is coming from but there is a distinct amount of water that has never appeared there before on the stairs down to her property.	Councils			
	Refer to ref 2389001. Caller advised that she received a letter from WCC today stating that the leak is private and she needs to get that fixed. Caller is concerned about the fact that there had been a major work for replacing the water mains that took place in Imlay Cres about couple of months ago and they moved the toby during that time. Caller claims that there had been no leaks or any such issues prior to that water mains work that was carried out by WCC. Caller is going to appoint her plumber tomorrow and would also like to speak to the Head Officer at WCC in relation to this. Caller advised that if she is unable to take calls for some reason then please leave a voicemail.	Councils			
	Water is leaking off the bank on to the road. The drive to 19 is before the leak. You have to drive past and you will see it.	MagicBus			
	Opposite this address this contractor has pulled a copper service off the main. There now a lot of water coming out and leaking. Please attend	Councils			
	Not urgent Minor leak from pipe that feeds toby, toby is actually up by house on Quetta St side of property	CityCare	5233394	WCC_PW045169	W-valve-31 imlay cres ngaio
	Caller has advised that there is alot of water coming out of a council pipe thats coming onto her property. Please assess.	Councils			
	Water is leaking from callers toby, which is at the back of the house. Water is coming down under callers house	CityCare	5233394	WCC_PW045169	W-valve-31 imlay cres ngaio
	Urgent toby locate trying to fix a fault private water leak	CityCare	3281949	WCC_PW030992	W-valve-35 imlay cres ngaio
	Leaking Pipes 39 IMLAY CRESCENT, Ngaio	Maximo			
	Small sounding private leak on the copper pipe where the toby is up the steps to the letter box	Councils			
	PRIVATE LEAK 39A Imlay Crescent, Ngaio, Wellington	Maximo			
	Steady flow of water is coming out of a pipe outside of 41 Imlay Cres on the street. Has been like this all week.	CityCare	3281953	WCC_PW031002	W-valve-41 imlay cres ngaio
	Related to 2519459. Caller from this property has had water coming down the bank at the back of her property, Advised that this was determined to be related to a leak on Cockayne Rd but this has now been fixed and she still reported the water coming down. Please assess this issue and contact [REDACTED].	Councils			
	Related to 2522212 and 2523094. Last job was closed off with no notes to related open job, but advised that samples were being taken from this address in relation to a water leak. Please assess.	Councils			
	Caller advised that there is a small leaking coming from a pipe on the road that is coming through to the callers property. Please assess.	Councils			

There's a square service cover that is leaking outside this address. The caller suspects it's the toby. This is unrelated to another job where a private leak at Laura Avenue. This happened soon after this leak was fixed. Please check again.	CityCare	3281953	WCC_PW031002	W-valve-41 imlay cres ngaio
Caller advised toby is leaking, water bubbling up. Steady flow. Please attend.	Councils			
Toby leaking outside this property.	Councils			
Water pipe broken. Water gushing out of a Council toby outside 43B Imlay Cres	CityCare	3285520	WCC_PW097972	Tee-43c imlay cres ngaio
LEAK DETECTION 43C IMLAY CRESCENT, Ngaio	Maximo			
GWRC called to advised that Nicola called about a water leak outside her property. Advised that there is a water leak outside this property and not sure whether it is coming from the road or footpath. Please assess.	Councils			
Water shooting up into the air from a rectangle plate between callers property and a access path. Would fill a 10lt bucket instantly.	CityCare	3285518	WCC_PW097971	W-valve-43b imlay cres ngaio
water leak coming from WCC side of the toby heavy leak please attend, please contact caller.	CityCare	3285662	WCC_PW097968	W-valve-45 imlay cres ngaio
Water leak near fire hydrant Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.2531067245093,174.775180639862&amp;z=19">http://maps.google.co.nz/?q=-41.2531067245093,174.775180639862&amp;z=19</a>	Councils			
Leaking water main under roadway on lower Imlay Cres. Breaking up tarmac and causing flooding damage in garden of 23 Crofton Road. Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.25308149,174.77508263&amp;z=19">http://maps.google.co.nz/?q=-41.25308149,174.77508263&amp;z=19</a>	Councils			
Water bubbling out from road.	CityCare	3285521	WCC_PW031004	W-valve-43c imlay cres ngaio
Water gushing out from Fire Hydrant.	Councils			
The entrance of Imlay Cres off Crofton Rd there is a toby leak please attend. Slow leak for a couple of days.	CityCare	3180565	WCC_PW030975	W-valve-35 imlay cres ngaio
Mowers struck a copper pipe. They have tried to pinch it but its still leaking a lot. Please attend urgently.	MagicBus		WCC_PWP092766	Wcc_pwp092766
Water leak	CityCare	3134686	WCC_PW097968	W-pipe connection service-45 imlay cres
Water coming out at a different point from last nights repair, not gushing but quite a lot of water	CityCare	3176031	WCC_PW030973	W-valve-27 crofton rd ngaio
There is a water leak on the covert at location site please attend and contact caller with an update.	Councils			
bottom of street, there are 2 service covers leaking, non urgent, please attend	CityCare	3176026	WCC_PW030972	Wfht-27 crofton rd ngaio
We have had water pooling in our driveway for the past week, coming from a bank that leads to the road. The water is bubbling out from the bottom of the bank. This has happened in the past and was due to mains problems coming from the road and opposite properties. Can you please investigate	CityCare	3114604	WCC_PW097964	W-pipe connection service-1/6 imlay cres



No.	Address	Council Ref ID	Water Type	Request ID	Request type	Comm Description	Date Created	Status	Resolution Date	Priority	Allocation	Responsible User
	130 old porirua rdngaiowgtn	WCC	Water	WCC2195789	0	W-P3 Minor Leaks	30 Oct 2013	Completed	05 Nov 2013	P3	Capacity	
				WCC2478513	0	W-P3 Minor Leaks	22 Jul 2016	Completed	10 Aug 2016	P3	CityCare	City Care - Water
	130 old porirua road, ngaio, wellington, 6035	WCC	Water	WCCSR-107466	System faults	Leaking Pipes	18 Feb 2021	90 closed (close)	04 Mar 2021	P2	007-WGTN-PW-RETC-DIST-PIPE	Notgiven DO NOT DELETE
				WCCSR-107466R		Asphalt Reinstatement	18 Feb 2021	90 closed (close)	16 Mar 2021	P4	007-WGTN-PW-RETC-DIST-PIPE	Notgiven DO NOT DELETE
				WCCSR-107566	System faults	Leaking Pipes	19 Feb 2021	90 closed (close)	19 Feb 2021	P3	007-WGTN-PW-RETC	
				WCCSR-127755	System faults	Leaking Pipes	19 Mar 2021	31 on site work complete - may require reinstatement (jobcomp)		P3	007-WGTN-PW-RETC	Not Given
	132 old porirua rd	WCC	Water	WCC2675574	0	W-P3 Minor Leaks	23 Apr 2018	Completed	21 May 2018	P3	CityCare	City Care - Water
	132 old porirua rd, ngaio	WCC	Water	WCC2335543	No water calls to council	W-P1 No Water	27 Mar 2015	Completed	27 Mar 2015	P1	CityCare	Wellington Water
	132 old porirua rdngaiowgtn	WCC	Water	WCC2523291	No water calls to council	W-P1 No Water	13 Dec 2016	Cancelled	13 Dec 2016	P1	CityCare	City Care - Water
				WCC2523305	No water calls to council	W-P1 No Water	13 Dec 2016	Cancelled	13 Dec 2016	P1	CityCare	City Care - Water
	132 old porirua road, ngaio, wellington	WCC	Water	WCC2663761	0	W-P3 Minor Leaks	16 Mar 2018	Completed	07 May 2018	P3	CityCare	City Care - Water
	Around 280 old porirua rd	WCC	Water	WCC2668658	0	W-P3 Minor Leaks	02 Apr 2018	Cancelled	06 Apr 2018	P3	CityCare	City Care - Water
	Cnr cockayne rd old porirua rdngaiowgtn	WCC	Water	WCC2162069	0	W-P1 Urgent Fault	04 Jul 2013	Completed	04 Jul 2013	P1	CityCare	Capacity
	Cnr old porirua rd and cockayne rd ngaio wgtn	WCC	Water	WCC2589058	0	W-P3 Minor Leaks	17 Jul 2017	Completed	18 Jul 2017	P3	CityCare	City Care - Water
	O/s 130 old porirua road, ngaio.	WCC	Water	WCC2197841	0	W-P3 Minor Leaks	05 Nov 2013	Completed	06 Nov 2013	P3	CityCare	Capacity
	Old porirua rd 130 old porirua rd ngaio wgtn	WCC	Water	WCC2893522		Leaky Connection/Meter/Toby	17 Mar 2020	Completed	18 Mar 2020	P3	FH	FH
	Old porirua rd, kaiwharawhara, wellington, 6035	WCC	Water	WCCSR-107760	System faults	Leaking Pipes	19 Feb 2021	90 closed (close)	19 Feb 2021	P2	007-WGTN-PW-RETC	
				WCCSR-107784	System faults	Leaking Pipes	19 Feb 2021	90 closed (close)	19 Feb 2021	P2	007-WGTN-PW-RETC	Notgiven DO NOT DELETE
	Old porirua rd, ngaio	WCC	Water	WCC2635428	0	W-P2 Major Leaks	14 Dec 2017	Completed	15 Dec 2017	P2	CityCare	City Care - Water
				WCC2676846	0	W-P3 Minor Leaks	27 Apr 2018	Cancelled	01 May 2018	P3	CityCare	City Care - Water
	Old porirua rd, ngaio, wellington	WCC	Water	WCC2441927	0	W-Mark Outs	24 Mar 2016	Completed	02 May 2016	P4	CityCare	Wellington Water
	On road reserve bank just passed and below properties of 130 and 132, old porirua rd, ngaio	WCC	Water	WCC2193555	0	W-P1 Main Bursts	22 Oct 2013	Completed	22 Oct 2013	P1	Capacity	
	address	council name	water type	request id	request type	comm description	Day of created	status	Day of closed	Priority	allocation	responsible_user
	130 old porirua rdngaiowgtn	WCC	Water	WCC2195789	0	W-P3 Minor Leaks	30 Oct 2013	Completed	05 Nov 2013	P3	Capacity	
				WCC2478513	0	W-P3 Minor Leaks	22 Jul 2016	Completed	10 Aug 2016	P3	CityCare	City Care - Water
	130 old porirua road, ngaio, wellington, 6035	WCC	Water	WCCSR-107466	System faults	Leaking Pipes	18 Feb 2021	90 closed (close)	04 Mar 2021	P2	007-WGTN-PW-RETC-DIST-PIPE	Notgiven DO NOT DELETE
				WCCSR-107466R		Asphalt Reinstatement	18 Feb 2021	90 closed (close)	16 Mar 2021	P4	007-WGTN-PW-RETC-DIST-PIPE	Notgiven DO NOT DELETE
				WCCSR-107566	System faults	Leaking Pipes	19 Feb 2021	90 closed (close)	19 Feb 2021	P3	007-WGTN-PW-RETC	
				WCCSR-127755	System faults	Leaking Pipes	19 Mar 2021	31 on site work complete - may require reinstatement (jobcomp)		P3	007-WGTN-PW-RETC	Not Given
	132 old porirua rd	WCC	Water	WCC2675574	0	W-P3 Minor Leaks	23 Apr 2018	Completed	21 May 2018	P3	CityCare	City Care - Water



132 old porirua rd, ngaio	WCC	Water	WCC2335543	No water calls to council	W-P1 No Water	27 Mar 2015	Completed	27 Mar 2015	P1	CityCare	Wellington Water
132 old porirua rdngaiowgtn	WCC	Water	WCC2523291	No water calls to council	W-P1 No Water	13 Dec 2016	Cancelled	13 Dec 2016	P1	CityCare	City Care - Water
			WCC2523305	No water calls to council	W-P1 No Water	13 Dec 2016	Cancelled	13 Dec 2016	P1	CityCare	City Care - Water
132 old porirua road, ngaio, wellington	WCC	Water	WCC2663761	0	W-P3 Minor Leaks	16 Mar 2018	Completed	07 May 2018	P3	CityCare	City Care - Water
Around 280 old porirua rd	WCC	Water	WCC2668658	0	W-P3 Minor Leaks	02 Apr 2018	Cancelled	06 Apr 2018	P3	CityCare	City Care - Water
Cnr cockayne rd old porirua rdngaiowgtn	WCC	Water	WCC2162069	0	W-P1 Urgent Fault	04 Jul 2013	Completed	04 Jul 2013	P1	CityCare	Capacity
Cnr old porirua rd and cockayne rd ngaio wgtn	WCC	Water	WCC2589058	0	W-P3 Minor Leaks	17 Jul 2017	Completed	18 Jul 2017	P3	CityCare	City Care - Water
O/s 130 old porirua road, ngaio.	WCC	Water	WCC2197841	0	W-P3 Minor Leaks	05 Nov 2013	Completed	06 Nov 2013	P3	CityCare	Capacity
Old porirua rd 130 old porirua rd ngaio wgtn	WCC	Water	WCC2893522		Leaky Connection/Meter/Toby	17 Mar 2020	Completed	18 Mar 2020	P3	FH	FH
Old porirua rd, kaiwharawhara, wellington, 6035	WCC	Water	WCCSR-107760	System faults	Leaking Pipes	19 Feb 2021	90 closed (close)	19 Feb 2021	P2	007-WGTN-PW-RETC	
			WCCSR-107784	System faults	Leaking Pipes	19 Feb 2021	90 closed (close)	19 Feb 2021	P2	007-WGTN-PW-RETC	Notgiven DO NOT DELETE
Old porirua rd, ngaio	WCC	Water	WCC2635428	0	W-P2 Major Leaks	14 Dec 2017	Completed	15 Dec 2017	P2	CityCare	City Care - Water
			WCC2676846	0	W-P3 Minor Leaks	27 Apr 2018	Cancelled	01 May 2018	P3	CityCare	City Care - Water
Old porirua rd, ngaio, wellington	WCC	Water	WCC2441927	0	W-Mark Outs	24 Mar 2016	Completed	02 May 2016	P4	CityCare	Wellington Water
On road reserve bank just passed and below properties of 130 and 132, old porirua rd, ngaio	WCC	Water	WCC2193555	0	W-P1 Main Bursts	22 Oct 2013	Completed	22 Oct 2013	P1	Capacity	

No.	Details	Data Source	ID asset	Asset ID	Asset Description
	steady leak on road	Councils			
	The toby at this address is leaking that needs to be attended to by their settlement date thursday.	Councils			
	Leaking Pipes 130 OLD PORIRUA ROAD, Ngaio	Maximo	490853	WCC_PWP005978	Wcc_pwp005978 pipe pressure 300mm ac
	Reinstatement: Leaking Pipes 130 OLD PORIRUA ROAD, Ngaio	Maximo	490853	WCC_PWP005978	Wcc_pwp005978 pipe pressure 300mm ac
	Leaking Pipes 130 OLD PORIRUA ROAD, Ngaio	Maximo			
	LEAK DETECTION; 130 OLD PORIRUA ROAD, Ngaio (LDS 14/4)	Maximo			
	Minor leak coming through road service. Please assist	CityCare	3203277	WCC_PWP016690	Rider main-132 old porirua rd ngaio
	Called to say they have no water. Have checked SOAK and no water shutdown for this address.	Councils			
	130/132 have had no water since 9:30am this morning.	CityCare	3176046	WCC_PW019445	W-valve-294 cockayne rd ngaio-khandallah
	Caller advised that they have no water at this address. Has been off most of the day. Advised that there has been issues before when people do mowing that they knock the tap that turns off the supply to the house but doesnt know if they have been there today. Caller also advised that 130 has been affected. Please assess.	Councils			
	Water is seeping up through the road.	CityCare	3114619	WCC_PWP059746	W-pipe connection service-302 old porirua rd
	Caller advised water coming up through road surface on Old Porirua Rd near intersection to Cockayne Rd. Please assist	Councils			
	Steady flow of water gushing down the road. Caller has no other details.	Councils			
	Caller has advised water flowing across road near corner of Old Porirua and Cockayne Rd in Ngaio. Logged as minor leak based on caller's description.	Councils			
	There is a burst pipe here.	Councils			
	The caller says that there is water leaking from the road near 130 Old Porirua Road. Please assess	MagicBus		WCC_PWP016690	Wcc_pwp016690
	Leaking Pipes OLD PORIRUA ROAD, Kaiwharawhara	Maximo			
	Leaking Pipes OLD PORIRUA ROAD, Kaiwharawhara	Maximo			
	Email received. Appears there may be a burst water pipe on Old Porirua Road about 1/3 of the way up. Obvious as it is flowing over road.	Councils			
	NON URGENT EMAIL REQUEST: Over the past week or more, there is water constantly running down at the top end of Old Porirua Road, closer to Perth St end and is running down pass the bottom of the driveway of my street above. There were people who fixed a leak a few weeks ago near that same end of the street but it looks like there is another leak they have missed. I suggest you get them out again as there is a lot of water running down the road that is wasted.	Councils			
	Hi Please organize locates for KNH 37. PLANS ATTACHED THIS WILL START IN 2 WEEKS TIME. THAN	Councils			
	URGENT Water is gushing out of a burst pipe in the bank.	Councils			



No.	Address	Council Ref ID	Water Type	Request ID	Request type	Comm Description	Date Created	Status	Resolution Date	Priority	Allocation	Responsible User
	1 orari stngaiowgtn	WCC	Water	WCC2613631	0	W-P3 Minor Leaks	03 Oct 2017	Cancelled	05 Oct 2017	P3	CityCare	City Care - Water
	1 orari street, ngaio, wellington, 6035	WCC	Water	WCC2920164	System faults	Leaky or Faulty Connection/Meter/Toby	30 Jul 2020	90 closed (close)	26 Aug 2020	P3	007-WGTN-PW-RETC-CONN-VALV	
				WCC2920164R		Asphalt Reinstatement	30 Jul 2020	90 closed (close)	21 Oct 2020	P4	007-WGTN-PW-RETC-CONN-VALV	
	8 orari street, ngaio, wellington, 6035	WCC	Water	WCCSR-382795		General Fault	17 May 2022	90 closed (close)	20 May 2022	P3	007-WGTN-PW-RETC-CONN-VALV	
	10 orari street, ngaio, wellington, 6035	WCC	Water	WCCSR-84967	System faults	Leaking Pipes	08 Jan 2021	90 closed (close)	12 Jan 2021	P3	007-WGTN-PW-RETC	Notgiven DO NOT DELETE
				WCCSR-86754	System faults	Leaking Pipes	12 Jan 2021	90 closed (close)	14 Jan 2021	P3	007-WGTN-PW-RETC	
	11 orari stngaiowgtn	WCC	Water	WCC2747318	0	W-P3 Minor Leaks	14 Dec 2018	Completed	18 Apr 2019	P3	CityCare	City Care - Water
				WCC2794290	0	W-P3 Minor Leaks	06 May 2019	Completed	06 May 2019	P3	CityCare	City Care - Water
	12 orari street, ngaio, wellington, 6035	WCC	Water	WCCSR-83619	System faults	Leaking Pipes	05 Jan 2021	90 closed (close)	28 Jan 2021	P1	007-WGTN-PW-RETC	.not given
				WCCSR-83619R		Asphalt Reinstatement	05 Jan 2021	90 closed (close)	19 Feb 2021	P4	007-WGTN-PW-RETC	.not given
				WCCSR-223946	Drinking water complaints - pressure or flow	Reduced Service	24 Aug 2021	90 closed (close)	25 Aug 2021	P2	007-WGTN-PW-RETC-CONN-PIPE	Not Given
	15 orari street, ngaio, wellington, 6035	WCC	Water	WCCSR-101484	Third party damages	Fault - Third Party Damage	09 Feb 2021	90 closed (close)	10 Feb 2021	P2	007-WGTN-PW-RETC	Notgiven DO NOT DELETE
	16 orari st, ngaio, wellington, 6035	WCC	Water	WCCSR-369571		General Fault	26 Apr 2022	90 closed (close)	26 Apr 2022	P2	007-WGTN-PW-RETC-CONN-VALV	
				WCCSR-382794		General Fault	17 May 2022	90 closed (close)	20 May 2022	P3	007-WGTN-PW-RETC-CONN-VALV	
	16 orari stngaiowgtn	WCC	Water	WCC2528005	0	W-Private Leaks	04 Jan 2017	Completed	05 Jan 2017	P3	CityCare	City Care - Water
	16a orari stngaiowgtn	WCC	Water	WCC2771018	Drinking water pressure or flow complaints	W-Pressure Issues	26 Feb 2019	Completed	26 Feb 2019	P3	CityCare	City Care - Water
	18 orari stngaiowgtn	WCC	Water	WCC2807555	Drinking water clarity complaints, clarity, odour, taste	W-Dirty Water/Bad Taste, Odour	17 Jun 2019	Cancelled	17 Jun 2019	P1	CityCare	City Care - Water
	20b orari street	WCC	Water	WCC2420292	0	W-P1 Main Bursts	19 Jan 2016	Completed	03 Feb 2016	P1	CityCare	Wellington Water
	20b orari street, ngaio	WCC	Water	WCC2420262	0	W-P3 Non Urgent Fault	19 Jan 2016	Completed	20 Jan 2016	P3	CityCare	Wellington Water
	21 orari stngaiowgtn	WCC	Water	WCC2490199	0	W-P3 Minor Leaks	30 Aug 2016	Completed	15 Sep 2016	P3	CityCare	City Care - Water
				WCC2494131	0	W-P3 Non Urgent Fault	12 Sep 2016	Completed	13 Sep 2016	P3	CityCare	City Care - Water
				WCC2513919	0	W-P3 Minor Leaks	16 Nov 2016	Completed	24 Nov 2016	P3	CityCare	City Care - Water
	21 orari street wellington ngaio	WCC	Water	WCC2490946	0	W-P3 Minor Leaks	01 Sep 2016	Cancelled	01 Sep 2016	P3	CityCare	City Care - Water
	22 orari st, ngaio, wgtm	WCC	Water	WCC2419271	0	W-P2 Major Leaks	16 Jan 2016	Cancelled	20 Jan 2016	P2	CityCare	Wellington Water
	22 orari stngaiowgtn	WCC	Water	WCC2634399	No water calls to council	W-P1 No Water	12 Dec 2017	Completed	12 Dec 2017	P1	CityCare	City Care - Water
	Orari st 24 orari street	WCC	Water	WCC2883018		Fault - Third Party Damage	17 Feb 2020	Completed	17 Feb 2020	P2	FH	FH



No.	Details	Data Source	ID asset	Asset ID	Asset Description
	Water has pushed up small part of asphalt on the road. Corner of Orari and Crofton Road.	Councils			
	Leaky Connection 1 Orari Street, Ngaio, Wellington 6035, New Zealand	Maximo	330323	WCC_PW020996	Wcc_pw020996 valve ball 0mm
	Reinstatement: Leaky Connection 1 Orari Street, Ngaio, Wellington 6035, New Zealand	Maximo	330323	WCC_PW020996	Wcc_pw020996 valve ball 0mm
	Fault 8 Orari Street, Ngaio (ROVER)	Maximo	424127	WCC_PW042161	Wcc_pw042161 valve ball 0mm
	Leaking Pipes 10 ORARI STREET, Ngaio	Maximo			
	Leaking Pipes 10 ORARI STREET, Ngaio	Maximo			
	Caller advised watere leaking from a crack in the road opposite driveway to 11 Orari St. Steady flow straight into gutter. No flooding. Please attend.	Councils			
	COMMS - EMS RI ASSIGNED 11/02/19 - CAR R568558 11/02/19 Reinstatement Information Location : Road Type : Asphalt Size (sq/m) : 1x1 Other Details : . Road : Open CAR TO BE REMOVED PASS TO ATMS PLANS ATTACHED 17/01/19 Caller advised watere leaking from a crack in the road opposite driveway to 11 Orari St. Steady flow straight into gutter. No flooding. Please attend. EM#[3641445] - do not delete this.	Councils			
	Leaking Pipes 10-12 ORARI STREET, Ngaio	Maximo			
	Reinstatement: Leaking Pipes 10-12 ORARI STREET, Ngaio	Maximo			
	Reduced Service 12 ORARI STREET, Ngaio	Maximo	564222	WCC_PWP060190	Wcc_pwp060190 pipe pressure 20mm mdpe80
	Fault 3rdP Damage 15 ORARI STREET, Ngaio	Maximo			
	Fault 16 Orari St, Ngaio (ROVER)	Maximo	380736	WCC_PW042174	Wcc_pw042174 valve ball 0mm
	Fault 16 Orari Street, Ngaio (ROVER)	Maximo	380736	WCC_PW042174	Wcc_pw042174 valve ball 0mm
	There is a pipe gushing water into the gutter outside 16 orari at ngaio. Please investigat possible private leak.	Councils			
	Caller advised this is a pressure issue at their home in it not being enough pressure to get enough pressure to heat the gas in the kitchen area. Please Attend.	Councils			
	Caller advised brown water coming through the pipes at her property. Have advised to run taps for 15mins and call back if still brown. Please attend.	Councils			
	water is broken and running from under asphalt and into stumps but their is a bit running into the property of #22, need to pass onto water crew urgently,	CityCare	3207751	WCC_PWP016921	Reticulation main-14 orari st ngaio
	Water is flowing from 2 drains onto the road and into number 21.	Councils			
	There was a leaking water main on Perth street for the last few days. We live below where the leak was, in Orari Street. since the leak, water has started seeping out from under our bank and across our driveway - even though there hasn't been any rain. I'm worried there is a broken pipe somewhere and the water is seeping under our section and out across the drive.	CityCare	3300306	WCC_PWP060193	W-valve-21 orari st ngaio
	Water running out of the bank next to his driveway, may be coming from mainwater pipe between 21 & 20 Orari St. water flows down his driveway into the channel and curb, slowly been getting worse over last few weeks	Councils			
	Water seeping up through the ground. Can someone please attend and assess.	Councils			
	Water seeping out of bank through drive. May be related to leaking water main on Perth Street. Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.254105,174.773331&amp;z=19">http://maps.google.co.nz/?q=-41.254105,174.773331&amp;z=19</a>	Councils			
	Water is leaking from a fire hydrant and is going down the driveway of a nearby property so a bit worried in case it does any damage.	Councils			
	Caller is a plumber, turned water off to do some work. Accu flow toby has failed and he is unable to turn the water back on. Please assess.	CityCare	3294794		W-meter cus inline-22 orari st ngaio
	Caller advised they are working infront of 24 Orari St and a digger has hit the top off the main. Water flowing out currently. Please attend	MagicBus		WCC_PW147778	Water meter: wcc_pw147778



No.	Address	Council Ref ID	Water Type	Request ID	Request type	Comm Description	Date Created	Status	Resolution Date	Priority	Allocation	Responsible User
	Perth stngaiowgtn	WCC	Water	WCC2561010	0	W-P3 Non Urgent Fault	15 Apr 2017	Completed	18 Apr 2017	P3	CityCare	City Care - Water
	3 perth street, ngaio, wellington, 6035	WCC	Water	WCCSR-267680	System faults	Leaky or Faulty Connection/Meter/Toby	08 Nov 2021	90 closed (close)	25 Nov 2021	P3	007-WGTN-PW-RETC-CONN-VALV	Not Given
	4 perth street, ngaio, wellington, 6035	WCC	Water	WCCSR-108536	System faults	Leaking Pipes	20 Feb 2021	90 closed (close)	08 Mar 2021	P3	007-WGTN-PW-RETC-CONN-VALV	
				WCCSR-119029	System faults	Leaking Pipes	08 Mar 2021	90 closed (close)	11 Mar 2021	P2	007-WGTN-PW-RETC	
	8 perth stngaiowgtn	WCC	Water	WCC2774252	0	W-Private Leaks	06 Mar 2019	Completed	13 Mar 2019	P3	CityCare	City Care - Water
	10 perth street, ngaio, wellington, 6035	WCC	Water	WCCSR-111414	System faults	Leaky or Faulty Connection/Meter/Toby	25 Feb 2021	90 closed (close)	11 Mar 2021	P3	007-WGTN-PW-RETC-CONN-VALV	Not Given
	13 perth street, ngaio, wellington	WCC	Water	WCC2625809	0	W-P3 Minor Leaks	14 Nov 2017	Completed	22 Dec 2017	P3	CityCare	City Care - Water
				WCC2736257	0	W-P3 Minor Leaks	10 Nov 2018	Completed	16 Nov 2018	P3	CityCare	City Care - Water
	13 perth street, ngaio, wellington, 6035	WCC	Water	WCCSR-50829	System faults	Leaking Pipes	28 Oct 2020	90 closed (close)	30 Oct 2020	P2	007-WGTN-PW-RETC	Notgiven DO NOT DELETE
	14 perth stngaiowgtn	WCC	Water	WCC2492568	0	W-P2 Major Leaks	06 Sep 2016	Completed	07 Sep 2016	P2	CityCare	City Care - Water
	15 perth street, ngaio, wellington, 6035	WCC	Water	WCCSR-66083	System faults	Leaking Pipes	25 Nov 2020	Cancelled, raised in error (can)		P3	007-WGTN-PW-RETC	
				WCCSR-302854	System faults	Leaky or Faulty Connection/Meter/Toby	06 Jan 2022	41 work completed	26 Apr 2022	P3	007-WGTN-PW-RETC-CONN-VALV	
				WCCSR-302854R		Other Reinstatement	06 Jan 2022	00 received (rcvd)		P4	007-WGTN-PW-RETC-CONN-VALV	
	16 perth street, ngaio, wellington	WCC	Water	WCC2722986	0	W-P3 Minor Leaks	25 Sep 2018	Completed	01 Oct 2018	P3	CityCare	City Care - Water
	16 perth street, ngaio, wellington, 6035	WCC	Water	WCCSR-66084	System faults	Leaking Pipes	25 Nov 2020	90 closed (close)	10 Dec 2020	P3	007-WGTN-PW-RETC	
	20 perth stngaiowgtn	WCC	Water	WCC2490370	0	W-P3 Non Urgent Fault	30 Aug 2016	Completed	07 Sep 2016	P3	CityCare	City Care - Water
				WCC2492618	0	W-P3 Non Urgent Fault	07 Sep 2016	Cancelled	07 Sep 2016	P3	CityCare	City Care - Water
	22 perth street, ngaio, wellington, 6035	WCC	Water	WCCSR-104975	Third party damages	Fault - Third Party Damage	15 Feb 2021	90 closed (close)	15 Feb 2021	P2	007-WGTN-PW-RETC	Notgiven DO NOT DELETE
	25 perth st, ngaio	WCC	Water	WCC2445813	0	W-P3 Minor Leaks	06 Apr 2016	Completed	06 May 2016	P3	CityCare	Wellington Water
	26 perth st, ngaio, wellington, 6035	WCC	Water	WCCSR-223739	System faults	Leaking Pipes	23 Aug 2021	90 closed (close)	24 Aug 2021	P1	007-WGTN-PW-RETC	Not Given
	26b perth street, ngaio, wellington, 6035	WCC	Water	WCC2924296	System faults	Leaky or Faulty Connection/Meter/Toby	28 Aug 2020	Cancelled, raised in error (can)		P2	007-WGTN-PW-RETC	Not Given
	28 perth stngaiowgtn	WCC	Water	WCC2326229	0	W-P3 Non Urgent Fault	25 Feb 2015	Completed	12 Mar 2015	P3	CityCare	Wellington Water
	39 perth st, ngaio, wellington, 6035	WCC	Water	WCCSR-223411	System faults	Leaking Pipes	23 Aug 2021	90 closed (close)	23 Aug 2021	P2	007-WGTN-PW-RETC	
	40 perth street, ngaio, wellington, 6035	WCC	Water	WCCSR-223241	System faults	Leaking Pipes	22 Aug 2021	90 closed (close)	23 Aug 2021	P2	007-WGTN-PW-RETC	
				WCCSR-374611		Instructed Works	03 May 2022	90 closed (close)	01 Jun 2022	P4	007-WGTN-PW-RETC	
	42 perth st	WCC	Water	WCC2529252	0	W-P3 Minor Leaks	09 Jan 2017	Completed	07 Apr 2017	P3	CityCare	City Care - Water
	42 perth stngaiowgtn	WCC	Water	WCC2239421	0	W-P3 Minor Leaks	05 Apr 2014	Completed	14 Apr 2014	P3	CityCare	Capacity
				WCC2529845	0	W-P3 Minor Leaks	11 Jan 2017	Cancelled	11 Jan 2017	P3	CityCare	City Care - Water
				WCC2654077	0	W-P3 Minor Leaks	17 Feb 2018	Completed	07 May 2018	P3	CityCare	City Care - Water
	42 perth street, ngaio, wellington, 6035	WCC	Water	WCCSR-83840	System faults	Leaking Pipes	06 Jan 2021	90 closed (close)	15 Feb 2021	P3	007-WGTN-PW-RETC-CONN-VALV	
				WCCSR-83840R		Asphalt Reinstatement	06 Jan 2021	90 closed (close)	15 Mar 2021	P4	007-WGTN-PW-RETC-CONN-VALV	
				WCCSR-114304	System faults	Leaking Pipes	02 Mar 2021	90 closed (close)	19 Mar 2021	P3	007-WGTN-PW-RETC	



				WCCSR-114304R		Asphalt Reinstatement	02 Mar 2021	90 closed (close)	22 Mar 2021	P4	007-WGTN-PW-RETC	
				WCCSR-124750	System faults	Leaking Pipes	16 Mar 2021	90 closed (close)	17 Mar 2021	P3	007-WGTN-PW-RETC	
44 perth street, ngaio, wellington, 6035	WCC	Water		WCCSR-223634	System faults	Leaking Pipes	23 Aug 2021	90 closed (close)	23 Aug 2021	P1	007-WGTN-PW-RETC	
				WCCSR-319705		General Fault	02 Feb 2022	90 closed (close)	04 Feb 2022	P2	007-WGTN-PW-RETC	
46 perth street, ngaio, wellington, 6035	WCC	Water		WCCSR-223237	System faults	Leaking Pipes	22 Aug 2021	31 on site work complete - may require reinstatement (jobcomp)	24 Aug 2021	P2	007-WGTN-PW-RETC-CONN-PIPE	
				WCCSR-223237R		Asphalt Reinstatement	22 Aug 2021	31 on site work complete - may require reinstatement (jobcomp)	03 Nov 2021	P4	007-WGTN-PW-RETC-CONN-PIPE	
				WCCSR-223282	System faults	Leaking Pipes	22 Aug 2021	90 closed (close)	22 Aug 2021	P2	007-WGTN-PW-RETC	
				WCCSR-223287	System faults	Leaking Pipes	22 Aug 2021	90 closed (close)	22 Aug 2021	P2	007-WGTN-PW-RETC	
				WCCSR-223440	System faults	Leaking Pipes	23 Aug 2021	90 closed (close)	23 Aug 2021	P3	007-WGTN-PW-RETC	
				WCCSR-223813	System faults	Leaking Pipes	24 Aug 2021	90 closed (close)	24 Aug 2021	P2	007-WGTN-PW-RETC	
				WCCSR-223814	System faults	Leaking Pipes	24 Aug 2021	90 closed (close)	24 Aug 2021	P3	007-WGTN-PW-RETC	
O.s 30 perth st	WCC	Water		WCC2239638	0	W-P3 Minor Leaks	06 Apr 2014	Completed	01 May 2014	P3	CityCare	Capacity
O/s 15 perth st ngaio wgtm	WCC	Water		WCC2213778	0	W-P3 Minor Leaks	06 Jan 2014	Completed	07 Jan 2014	P3	CityCare	Capacity
O/s 30 perth st, ngaio wgtm.	WCC	Water		WCC2213784	0	W-P3 Minor Leaks	06 Jan 2014	Completed	17 Mar 2014	P3	CityCare	Capacity
Outside 25 perth street ngaio.	WCC	Water		WCC2241728	0	W-P3 Minor Leaks	14 Apr 2014	Cancelled	15 Apr 2014	P3	CityCare	Capacity
Perth st 15 perth st, ngaio, wellington 6035, new zealand	WCC	Water		WCC2841765		Leaky Connection/Meter/Toby	06 Oct 2019	Completed	14 Oct 2019	P3	FH	FH
Perth st 42 perth st ngaio wgtm	WCC	Water		WCC2868220		Leaky Connection/Meter/Toby	03 Jan 2020	Completed	12 Feb 2020	P3	FH	FH
Perth st & crofton rd, ngaio, wellington, 6035	WCC	Water		WCCSR-224138	System faults	Leaking Pipes	24 Aug 2021	90 closed (close)	26 Aug 2021	P2	007-WGTN-PW-RETC	
Perth st, ngaio	WCC	Water		WCC2543336	0	W-P3 Minor Leaks	21 Feb 2017	Completed	23 Feb 2017	P3	CityCare	City Care - Water
Perth st, ngaio, wellington, 6035	WCC	Water		WCCSR-223253	System faults	Leaking Pipes	22 Aug 2021	90 closed (close)	23 Aug 2021	P2	007-WGTN-PW-RETC	
				WCCSR-223274	System faults	Leaking Pipes	22 Aug 2021	90 closed (close)	23 Aug 2021	P2	007-WGTN-PW-RETC	
				WCCSR-223276	System faults	Leaking Pipes	22 Aug 2021	90 closed (close)	23 Aug 2021	P3	007-WGTN-PW-RETC	
				WCCSR-223484	System faults	Leaking Pipes	23 Aug 2021	90 closed (close)	24 Aug 2021	P2	007-WGTN-PW-RETC	
				WCCSR-223738	System faults	Leaking Pipes	23 Aug 2021	90 closed (close)	24 Aug 2021	P2	007-WGTN-PW-RETC	
				WCCSR-223815	System faults	Leaking Pipes	24 Aug 2021	90 closed (close)	24 Aug 2021	P2	007-WGTN-PW-RETC	
Perth st, ngaio, wgtm	WCC	Water		WCC2445933	0	W-P3 Minor Leaks	07 Apr 2016	Cancelled	18 Apr 2016	P3	CityCare	Wellington Water

No.	Details	Data Source	ID asset	Asset ID	Asset Description
	Outsidee 10 Perth St minor leaks on road in a several spots	Councils			
	Leaky Connection 3 Perth Street, Ngaio	Maximo	323403	WCC_PW043877	Wcc_pw043877 valve ball 0mm
	Leaking Pipes 4 PERTH STREET, Ngaio	Maximo	363513	WCC_PW043871	Wcc_pw043871 valve ball 0mm
	Leaking Pipes 4 PERTH STREET, Ngaio	Maximo			
	Caller lives at 22 Crofton Rd, advised there is a leak coming onto his property from 8 Perth St. Requesting private leak letter be delivered. Please assist.	Councils			
	Leaky Connection 10 PERTH STREET, Ngaio	Maximo	304644	WCC_PW043870	Wcc_pw043870 valve ball 0mm
	Water leaking from middle of road outside 13 Perth Street in Ngaio	CityCare	3134149	WCC_PWP061762	W-pipe connection service-13 perth st
	Very small leak on road as the area at is constantly wet. Outside 13 Perth St.	Councils			
	Leaking Pipes 13 PERTH STREET, Ngaio	Maximo			
	Caller has advised that there are 7 or 8 cracks in the ground that have started to really open up and there is alot of water coming out of them. The ground is extremely wet and they are spread out a whole distance of the street (from callers property to 30 Perth St). Tar seal is very soft when caller put her foot on it. Water is not shooting in the air but it is gushing out quite fast. Caller has advised there are always road works going on on her street and this may be a factor.	CityCare	3141435	WCC_PWP061759	W-pipe connection service-16 perth st
	Leaking Pipes 15 PERTH STREET, Ngaio	Maximo			
	Leaky Connection 15 Perth Street, Ngaio (TRAFFIC)	Maximo	328060	WCC_PW043880	Wcc_pw043880 valve 20mm
	Reinstatement: Leaky Connection 15 Perth Street, Ngaio (TRAFFIC)	Maximo	328060	WCC_PW043880	Wcc_pw043880 valve 20mm
	Water coming up through road surface.	Councils			
	Leaking Pipes 16 PERTH STREET, Ngaio	Maximo			
	Steady flow of water seeping out from underneath asphalt.	Councils			
	Water leak on road reported by bus driver. Near 20 Perth Street.	Councils			
	Fault 3rdP Damage 22 PERTH STREET, Ngaio	Maximo			
	Water leaking from toby. Has been leaking for approx 2 weeks.	CityCare	3237299	WCC_PWP061769	W-valve-34b perth st ngaio
	Leaking Pipes 26 PERTH STREET, Ngaio	Maximo			
	Leaky Connection 26B Perth St Ngaio Wgtn	Maximo			
	Leaking WCC toby here. Request for attendance as soon as possible as Downers are layign a new kerb and channel here.	Councils			
	Leaking Pipes 39 Perth St, Ngaio (ROVER)	Maximo			
	Leaking Pipes 40 PERTH STREET, Ngaio	Maximo			
	Instructed Works 40 Perth Street, Ngaio	Maximo			
	Caller says there is a small water leak coming up through a shared driveway	CityCare	0		Unable to select asset
	Light flow coming out of the ashphelt and there is a bulge	CityCare	3237299	WCC_PW043878	W-valve-34b perth st ngaio
	Caller advised that there is a leak coming up through a shared driveway. There is already a job logged but caller wanted own reference number. Existing job is 2529252.	Councils			
	Water coming out of the berm. Recurring issue and has been fixed in the past. Couple days to fill a bucket not much water. Please asses.	CityCare	1160185 8	WCC_PW147548	Ws147548 ws147551
	Leaking Pipes 42 PERTH STREET, Ngaio	Maximo	390129	WCC_PW147550	Wcc_pw147550 valve 0mm
	Reinstatement: Leaking Pipes 42 PERTH STREET, Ngaio	Maximo	390129	WCC_PW147550	Wcc_pw147550 valve 0mm
	Leaking Pipes 42 PERTH STREET, Ngaio	Maximo			
	Reinstatement: Leaking Pipes 42 PERTH STREET, Ngaio	Maximo			
	Leaking Pipes 42 PERTH STREET, Ngaio	Maximo			
	Leaking Pipes 44 Perth Street, Ngaio, Wellington	Maximo			
	Fault 44 PERTH STREET, Ngaio	Maximo			
	Leaking Pipes 46 PERTH STREET, Ngaio	Maximo	683901	WCC_PWP085651	Wcc_pwp085651 pipe pressure 20mm mdpe80



Reinstatement: Leaking Pipes 46 PERTH STREET, Ngaio	Maximo	683901	WCC_PWP085651	Wcc_pwp085651 pipe pressure 20mm mdpe80
Leaking Pipes 46 PERTH STREET, Ngaio	Maximo			
Leaking Pipes 46 PERTH STREET, Ngaio	Maximo			
Leaking Pipes 46 PERTH STREET, Ngaio	Maximo			
Leaking Pipes 46 PERTH STREET, Ngaio	Maximo			
Leaking Pipes 46 PERTH STREET, Ngaio	Maximo			
Water bubbling up through road	Councils			
Steady leak on the road both locations.	Councils			
Steady leak on the road both locations.	Councils			
There is a water leak which is causing potholes in the tar seal. The road breaks up as the water leaks through.	Councils			
Two or possibly three leaks surfacing	MagicBus		WCC_PW043880	Water valve: wcc_pw043880
The water pipe is leaking outside our property. This has been a problem previously which you have fixed.	MagicBus		WCC_PWP085649	Wcc_pwp085649
Leaking Pipes Perth St & Crofton Rd, Ngaio (ROVER)	Maximo			
Perth St, at the top of Crofton Road. Coming from the ckerb and across the road and down crofton road.	Councils			
Leaking Pipes PERTH STREET, Ngaio	Maximo			
Leaking Pipes PERTH STREET, Ngaio	Maximo			
Leaking Pipes PERTH STREET, Ngaio	Maximo			
Leaking Pipes PERTH STREET, Ngaio	Maximo			
Leaking Pipes PERTH STREET, Ngaio	Maximo			
Leaking Pipes PERTH STREET, Ngaio	Maximo			
Leaking Pipes PERTH STREET, Ngaio	Maximo			
Corner of Perth st and Ngaio Gorge Road, Water is flowing in the gutter round the corner of Perth St. Looks clean. Has been there for 3 days. Haven't investigated where its coming from. Reasonable stream of water. See it when I walk to bus and thought you ought to know.	Councils			

No.	Address	Council Ref ID	Water Type	Request ID	Request type	Comm Description	Date Created	Status	Resolution Date	Priority	Allocation	Responsible User
	Quetta stngaiowgtn	WCC	Water	WCC2432808	0	W-P3 Minor Leaks	26 Feb 2016	Cancelled	26 Feb 2016	P3	CityCare	Wellington Water
	5 and 12a quetta st	WCC	Water	WCC2698399	0	W-P3 Minor Leaks	05 Jul 2018	Completed	16 Jul 2018	P3	CityCare	City Care - Water
	5 quetta stngaiowgtn	WCC	Water	WCC2685954	0	W-P3 Minor Leaks	25 May 2018	Completed	30 May 2018	P3	CityCare	City Care - Water
	5 quetta street, ngaio, wellington, 6035	WCC	Water	WCCSR-130671	System faults	Leaking Pipes	24 Mar 2021	90 closed (close)	24 Mar 2021	P2	007-WGTN-PW-RETC	[REDACTED]
				WCCSR-130698	System faults	Leaking Pipes	24 Mar 2021	90 closed (close)	24 Mar 2021	P3	007-WGTN-PW-RETC	[REDACTED]
	5b quetta stngaiowgtn	WCC	Water	WCC2495148	0	W-P3 Non Urgent Fault	15 Sep 2016	Completed	06 Oct 2016	P3	CityCare	City Care - Water
				WCC2537015	0	W-Enquiry to Engineer	02 Feb 2017	Cancelled	10 Feb 2017	P4	CityCare	City Care - Water
				WCC2538725	0	W-Enquiry to Engineer	08 Feb 2017	Completed	09 Feb 2017	P4	WWL	[REDACTED]
	5b quetta street	WCC	Water	WCC2498613	0	W-Instructed Works	26 Sep 2016	Completed	12 Dec 2016	P4	CityCare	City Care - Water
	6 quetta st, ngaio, wgtm	WCC	Water	WCC2455802	0	W-Toby Locate	09 May 2016	Completed	10 May 2016	P3	CityCare	Wellington Water
	7 quetta street, ngaio, wellington, 6035	WCC	Water	WCCSR-137787	System faults	Leaking Pipes	05 Apr 2021	90 closed (close)	06 Apr 2021	P2	007-WGTN-PW-RETC	[REDACTED]
				WCCSR-140034	System faults	Leaking Pipes	08 Apr 2021	90 closed (close)	09 Apr 2021	P3	007-WGTN-PW-RETC	[REDACTED]
	7a quetta street, ngaio, wellington, 6035	WCC	Water	WCCSR-138782	System faults	Leaking Pipes	06 Apr 2021	90 closed (close)	07 Apr 2021	P3	007-WGTN-PW-RETC	[REDACTED]
	7c quetta street, ngaio, wellington, 6035	WCC	Water	WCCSR-127246	System faults	Leaking Pipes	18 Mar 2021	31 on site work complete - may require reinstatement (jobcomp)		P3	007-WGTN-PW-RETC-CONN-VALV	[REDACTED]
				WCCSR-127246R		Asphalt Reinstatement	18 Mar 2021	90 closed (close)	03 May 2021	P4	007-WGTN-PW-RETC-CONN-VALV	[REDACTED]
	9 quetta stngaiowgtn	WCC	Water	WCC2577261	0	W-P3 Minor Leaks	07 Jun 2017	Completed	09 Jun 2017	P3	CityCare	City Care - Water
	12 quetta st	WCC	Water	WCC2706843	0	W-P3 Minor Leaks	01 Aug 2018	Completed	02 Aug 2018	P3	CityCare	City Care - Water
	12a & b quetta street, ngaio	WCC	Water	WCC2913265		Leaking Pipes	24 Jun 2020	Completed		P3	FH	FH
	12a quetta stngaiowgtn	WCC	Water	WCC2396730	0	W-P3 Minor Leaks	27 Oct 2015	Completed	13 Nov 2015	P3	CityCare	Wellington Water
				WCC2599119	0	W-P3 Minor Leaks	16 Aug 2017	Completed	03 Oct 2017	P3	CityCare	City Care - Water
				WCC2657151	0	W-P3 Minor Leaks	26 Feb 2018	Completed	15 Mar 2018	P3	CityCare	City Care - Water
	14 quetta stngaiowgtn	WCC	Water	WCC2309841	0	W-P3 Minor Leaks	30 Dec 2014	Completed	31 Dec 2014	P3	WWL	[REDACTED]
				WCC2309903	0	W-P3 Minor Leaks	30 Dec 2014	Cancelled	30 Dec 2014	P3	CityCare	Wellington Water
	14 quetta street ngaio	WCC	Water	WCC2309982	0	W-Toby Fault	30 Dec 2014	Cancelled	31 Dec 2014	P3	CityCare	Wellington Water
	15a quetta stngaiowgtn	WCC	Water	WCC2220956	Drinking water pressure or flow complaints	W-Pressure Issues	02 Feb 2014	Completed	02 Feb 2014	P3	CityCare	Capacity
	16 quetta street, ngaio, wellington, 6035	WCC	Water	WCCSR-361292	System faults	Leaking Pipes	09 Apr 2022	90 closed (close)	11 Apr 2022	P2	007-WGTN-PW-RETC	[REDACTED]
	17 quetta street, ngaio, wellington, 6035	WCC	Water	WCCSR-361302	System faults	Leaking Pipes	09 Apr 2022	90 closed (close)	11 Apr 2022	P2	007-WGTN-PW-RETC	[REDACTED]
	18 quetta stngaiowgtn	WCC	Water	WCC2282920	0	W-Instructed Works	22 Sep 2014	Completed	25 Sep 2014	P4	CityCare	Wellington Water
				WCC2297871	0	W-P3 Minor Leaks	14 Nov 2014	Completed	14 Nov 2014	P3	CityCare	Wellington Water
	18 quetta street, ngaio, wellington, 6035	WCC	Water	WCCSR-360426	System faults	Leaking Pipes	07 Apr 2022	90 closed (close)	13 Apr 2022	P2	007-WGTN-PW-RETC-DIST-HYDR	[REDACTED]
	19 quetta stngaiowgtn	WCC	Water	WCC2603422	No water calls to council	W-P1 No Water	30 Aug 2017	Completed	30 Aug 2017	P1	CityCare	City Care - Water
	20 quetta street, ngaio	WCC	Water	WCC2509914	0	W-Mark Outs	03 Nov 2016	Completed	04 Nov 2016	P4	CityCare	City Care - Water
	20 quetta street, ngaio, wellington, 6035	WCC	Water	WCCSR-86702	System faults	Leaking Pipes	12 Jan 2021	90 closed (close)	13 Jan 2021	P3	007-WGTN-PW-RETC	[REDACTED]



22 quetta stngaiowgtn	WCC	Water	WCC2441231	Drinking water pressure or flow complaints	W-Pressure Issues	22 Mar 2016	Completed	22 Mar 2016	P3	CityCare	Wellington Water
22 quetta street, ngaio, wellington, 6035	WCC	Water	WCCSR-85410	System faults	Leaking Pipes	10 Jan 2021	90 closed (close)	11 Jan 2021	P3	007-WGTN-PW-RETC	Notgiven DO NOT DELETE
22a quetta stngaiowgtn	WCC	Water	WCC2436616	0	W-Enquiry to Engineer	08 Mar 2016	Completed	05 Apr 2016	P4	CityCare	Wellington Water
			WCC2669821	0	W-P3 Minor Leaks	05 Apr 2018	Completed	04 May 2018	P3	CityCare	City Care - Water
22a quetta street, ngaio, wellington, 6035	WCC	Water	WCCSR-85117	System faults	Leaky or Faulty Connection/Meter/Toby	09 Jan 2021	90 closed (close)	27 May 2021	P3	007-WGTN-PW-RETC	
			WCCSR-85117R		Asphalt Reinstatement	09 Jan 2021	90 closed (close)	26 Oct 2021	P4	007-WGTN-PW-RETC	
			WCCSR-87237	System faults	Leaking Pipes	13 Jan 2021	90 closed (close)	13 Jan 2021	P2	007-WGTN-PW-RETC	Notgiven DO NOT DELETE
			WCCSR-92142	System faults	Leaking Pipes	22 Jan 2021	90 closed (close)	22 Jan 2021	P1	007-WGTN-PW-RETC	
22b quetta stngaiowgtn	WCC	Water	WCC2173449	0	W-P3 Minor Leaks	12 Aug 2013	Completed	13 Aug 2013	P3	CityCare	Capacity
22b quetta stngaiowgtn	WCC	Water	WCC2174223	0	W-Toby Fault	14 Aug 2013	Completed	26 Aug 2013	P3	CityCare	Capacity
			WCC2427750	0	W-Toby Fault	11 Feb 2016	Completed	22 Feb 2016	P3	CityCare	Wellington Water
			WCC2431188	0	W-Toby Fault	22 Feb 2016	Completed	29 Feb 2016	P3	CityCare	Wellington Water
23 quetta street, ngaio, wellington, 6035	WCC	Water	WCCSR-360540	System faults	Leaking Pipes	08 Apr 2022	90 closed (close)	11 Apr 2022	P3	007-WGTN-PW-RETC	
24 quetta street, ngaio, wellington, 6035	WCC	Water	WCCSR-92165	System faults	Leaking Pipes	22 Jan 2021	90 closed (close)	22 Jan 2021	P1	007-WGTN-PW-RETC	Notgiven DO NOT DELETE
25 quetta st, ngaio	WCC	Water	WCC2212831	0	W-P3 Minor Leaks	31 Dec 2013	Completed	07 Jan 2014	P3	CityCare	Capacity
25 quetta stngaio	WCC	Water	WCC2490581	0	W-Toby Fault	31 Aug 2016	Completed	01 Sep 2016	P3	CityCare	City Care - Water
26 quetta stngaiowgtn	WCC	Water	WCC2601796	0	W-P3 Minor Leaks	24 Aug 2017	Completed	08 Sep 2017	P3	CityCare	City Care - Water
118 quetta stngaiowgtn	WCC	Water	WCC2536025	0	W-P3 Minor Leaks	31 Jan 2017	Cancelled	31 Jan 2017	P3	CityCare	City Care - Water
512a quetta stngaiowgtn	WCC	Water	WCC2692172	0	W-P3 Minor Leaks	15 Jun 2018	Completed	20 Jun 2018	P3	CityCare	City Care - Water
Intersection of cockayne road and quetta street ngaio.	WCC	Water	WCC2240594	0	W-P3 Minor Leaks	09 Apr 2014	Completed	09 Apr 2014	P3	CityCare	Capacity
O/s 17 quetta stngaiowgtn	WCC	Water	WCC2220855	0	W-P2 Major Leaks	01 Feb 2014	Completed	04 Feb 2014	P2	CityCare	Capacity
O/s garage of 22b quetta street, ngaio.	WCC	Water	WCC2174357	0	W-Toby Fault	14 Aug 2013	Cancelled	15 Aug 2013	P3	CityCare	Capacity
Quetta st	WCC	Water	WCC2172066	0	W-Mark Outs	07 Aug 2013	Completed	09 Aug 2013	P4	CityCare	Capacity
			WCC2277702	0	W-Mark Outs	02 Sep 2014	Completed	17 Sep 2014	P4	CityCare	Wellington Water
Quetta st 5 quetta st ngaio	WCC	Water	WCC2897698		Leaky Connection/Meter/Toby	08 Apr 2020	Completed	20 Apr 2020	P3	FH	FH
Quetta st 23 quetta st ngaio wgn	WCC	Water	WCC2843613		Fault	12 Oct 2019	Cancelled		P3	FH	FH
			WCC2863650		Information Request Client Council	14 Dec 2019	Completed		P4	FH	FH
Quetta st 25 quetta st ngaio wgn	WCC	Water	WCC2867011		Leaky Connection/Meter/Toby	27 Dec 2019	Completed	31 Dec 2019	P3	FH	FH
Quetta st 26-28 quetta st ngaio wgn	WCC	Water	WCC2821179		Leaky Connection/Meter/Toby	31 Jul 2019	Completed		P3	FH	FH
Quetta st 27 quetta st ngaio wgn	WCC	Water	WCC2844570		Leaky Connection/Meter/Toby	15 Oct 2019	Completed	27 Nov 2019	P3	FH	FH
			WCC2860274		Information Request Client Council	04 Dec 2019	Awaiting reinstatement	07 Feb 2020	P2	FH	FH
Quetta st quetta st ngaio wgn	WCC	Water	WCC2859379		Fault	02 Dec 2019	Completed	04 Feb 2020	P3	FH	FH

	Quetta st, ngaio, wellington, 6035	WCC	Water	WCCSR-361320	System faults	Leaking Pipes	09 Apr 2022	90 closed (close)	11 Apr 2022	P2	007-WGTN-PW-RETC	Not Given
				WCCSR-362699	System faults	Leaking Pipes	12 Apr 2022	90 closed (close)	14 Apr 2022	P3	007-WGTN-PW-RETC	Not given
	Quetta street	WCC	Water	WCC2606971	0	W-Enquiry to Engineer	11 Sep 2017	Completed	11 Sep 2017	P4	WWL	



No.	Details	Data Source	ID asset	Asset ID	Asset Description
	Caller is reporting a minor leak near 22A. Can someone please attend and assess.	Councils			
	Refer to 2692172. Caller has advised bonet needs to be replaced and was told this by the previous contractor who repaired the job before. Refer 260971 & 2657151: ongoing issue with this water leaking from 14 Quetta St onto 12A, which is now starting to destabilise the retaining wall at this address. Leak is beginning to flood down the driveway at 12A, caller believes pipe needs to be replaced. She also has photos of this area if required. Caller [REDACTED] would like to be contacted in the first instance to discuss further.	Councils			
	From the Ministry of Plumbing. Leaking toby, steady stream. Please contact when this been repaired.	CityCare	3245573	WCC_PW045149	W-valve-5 quetta st ngaio
	Leaking Pipes 5 QUETTA STREET, Ngaio	Maximo			
	Leaking Pipes 5 QUETTA STREET, Ngaio	Maximo			
	Caller advised that there is a leak coming from near the toby but unsure where the fault is coming from. Have looked at webmap and it is difficult to see where the leak could be coming from, there are private SW and WW pipes but also a 'rider main' that runs down this driveway. Please assess.	CityCare	5233393	WCC_PW045170	W-valve-5a quetta st ngaio
	Caller had a leaky toby which was fixed by our contractors which had to cut through concrete. They unfortunately cut through the cable for internet and phone. would like to know if and when the contractor will be back out to fix it as they knew they cut through it.	Councils			
	Caller had a leaky toby which was fixed by our contractors which had to cut through concrete. They unfortunately cut through the cable for internet and phone. would like to know if and when the contractor will be back out to fix it as they knew they cut through it.	Councils			
	Toby marked. Rechecked three times. Water visible out of toby box outside 5B. Suspect leak is on private rider prior to 5B's toby.	CityCare	5233393	WCC_PW045170	W-valve-5a quetta st ngaio
	Advised that they need to locate the toby at this location. This is for Grant Plumbing Ltd.	CityCare	3239373	WCC_PW045140	W-valve-6 quetta st ngaio
	Leaking Pipes 5-7 QUETTA STREET, Ngaio	Maximo			
	Leaking Pipes 7 QUETTA STREET, Ngaio	Maximo			
	Leaking Pipes 7a QUETTA STREET, Ngaio	Maximo			
	Leaking Pipes 7C QUETTA STREET, Ngaio	Maximo	337281	WCC_PW045153	Wcc_pw045153 valve 0mm
	Reinstatement: Leaking Pipes 7C QUETTA STREET, Ngaio	Maximo	337281	WCC_PW045153	Wcc_pw045153 valve 0mm
	Caller has advised that the toby in front of his property has a steady leak of water. Leaking on to the footpath.	CityCare	3235906	WCC_PW045141	W-valve-9 quetta st ngaio
	Ongoing issues with leak coming from underground shared toby and pipes leaking out into the driveway at number 12. See refs 260971, 2657151 and 2692172. Caller adv this has been happening for years and was fixed briefly last year but is leaking again, he thinks the toby under the road is being damaged by the weight of trucks and buses and needs to be moved. He is happy to show where the issue is as last time leak couldn't be located.	Councils			
	Non-urgent private leaks. Please assign to [REDACTED], retrospective jobs.	MagicBus			
	Please check toby	Councils			
	Approximately two years ago, there was a WCC mains leak on the road coming through 14 onto 12a. It appears after the earthquake this has started to leak again in much the same way. And is causing drainage issues for 12a. Please investigate.	CityCare	3137585	WCC_PWP062937	W-pipe connection service-14 quetta st
	In relation to old job 2606971. Caller has advised of the leak happening again. Please assist.	CityCare	5233491	WCC_PW045160	W-valve-a1/12a quetta st ngaio
	Steady trickle of water coming from the toby.	Councils			
	Leak on footpath, slow leak.	Councils			
	Toby leaking has a constant trickle.	Councils			
	noticed last night the water pressure has dropped severely really slow. The water starts off normal and within seconds the water pressure dropped. Please attend	CityCare	3235899	WCC_PW045136	W-valve-15 quetta st ngaio
	Leaking Pipes 16 QUETTA STREET, Ngaio	Maximo			
	Leaking Pipes 17 QUETTA STREET, Ngaio	Maximo			
	Leaking toby	CityCare	3281494	WCC_PW045129	W-valve-18 quetta st ngaio

Minor toby leak.	CityCare	3281494	WCC_PW045129	W-valve-18 quetta st ngaio
Leaking Pipes 18 QUETTA STREET, Ngaio	Maximo	52044	WCC_PW005726	Wcc_pw005726 hydrant
Caller advised that after the water off it came back on for ten minutes and then he heard a weird noise and now there is no water again. He waited for about 40minutes because he thought they were doing more work. He then checked with some of his neighbours and they have water.	Councils			
Caller would like markout for house toby as he is trying to secure a leak on site.	CityCare	3281495	WCC_PW045130	W-valve-18 quetta st ngaio
Leaking Pipes 20 QUETTA STREET, Ngaio	Maximo			
Advised that his water pressure is now a dribble. It will run for a few seconds and then the pressure is reduced. He has tried running the taps for 5 mins at a time and no change. Please assess	Councils			
Leaking Pipes 22 QUETTA STREET, Ngaio	Maximo			
My neighbour lodged an incident with the council just over two weeks ago to do with what we think is a cracked water pipe. The incident number is listed above. Our neighbour had noticed a possible crack in a shared driveway, this coming to his attention as a small amount of water was bubbling up from a point in the driveway before following the natural fall of the driveway and going down a stormwater drain. I have attached two photographs to illustrate my point as this is hard to describe. My neighbour who is a tenant, and the actual owner of that property have both contacted the council in order to have someone inspect the pipe as we are concerned about a possible crack in the pipe, and do not want the water flow to increase or for there to be other issues to do with the pipes that may affect the foundations of our properties. The advice from the council to my neighbours to date is that the problem has been fixed. Unfortunately, it has not been fixed but I suspect that as there was a water issue on Quetta street approximately 100m away that the two problems have been assumed to be one. Can you please help by forwarding this on to the pipes maintenance team or a relevant staff member so that this problem can be looked into. I am very concerned that there are big problems with the pipes and what that may mean for our properties, and am also concerned what happens if the water flow increases. I understand that the water first came up to the surface immediately following an earthquake in early February. As I was in Australia at the time we were not present to comment on this, but again the particulars will be in the original incident listed My personal cell phone is [REDACTED] and the neighbours contact details will already be listed against the incident number. If someone could email me with an update that would be much appreciated Thanks Other comments: I am now the fourth person contacting you in regard to this and its now bordering on 4 weeks since it w	CityCare	3134503	WCC_PW116048	W-pipe connection service-20 quetta st
I live at 22 A Quetta St Wellington and I am the joint owner of the property. It would appear that a heavy vehicle has driven over the toby outside our house and damaged it as it leaking water. This appeared to have happened over Easter weekend when away. At first we thought the water was due to rain but today I have noticed it running constantly	CityCare	3281495	WCC_PW116048	W-valve-18 quetta st ngaio
Leaky Connection 22a QUETTA STREET, Ngaio	Maximo			
Reinstatement: Leaky Connection 22a QUETTA STREET, Ngaio	Maximo			
Leaking Pipes 22A QUETTA STREET, Ngaio	Maximo			
Leaking Pipes 22a QUETTA STREET, Ngaio	Maximo			
Minor leak near toby box on the street side. is spraying steadily but not an urgent job.	CityCare	3281495	WCC_PW045130	W-valve-18 quetta st ngaio
2173449 Toby still spraying water	CityCare	3134503	WCC_PWP062934	W-pipe connection service-20 quetta st
Caller has advised there is water leaking near the toby at this address. He said its been an issue before. Please attend and assess fault.	Councils			
Refer to job 2427750. Landlord advised that the tenant checked the toby today and it is still leaking?	CityCare	3281495	WCC_PW045130	W-valve-18 quetta st ngaio
Leaking Pipes 23 QUETTA STREET, Ngaio	Maximo			
Leaking Pipes 24 QUETTA STREET, Ngaio	Maximo			
Slow leak coming from the toby.	CityCare	3285309	WCC_PW045142	W-valve-25 quetta st ngaio
Water seeping steadily from toby, reported by neighbour as house is empty, has been leaking like this for weeks.	Councils			
ridermain leak between number 26 and 28 manafolds needs to be repaired	CityCare	5231956	WCC_PWP062980	W-pipe connection service-25 to 26
Slow leak from toby.	Councils			



Refer 260971 & 2657151: ongoing issue with this water leaking from 14 Quetta St onto 12A, which is now starting to destabilise the retaining wall at this address. Leak is beginning to flood down the driveway at 12A, caller believes pipe needs to be replaced. She also has photos of this area if required. Caller (Nicola) would like to be contacted in the first instance to discuss further.	Councils			
There is a water valve that is leaking.	CityCare	3160847	WCC_PW019439	W-valve-229 cockayne rd ngaio-khandallah
Water bubbling up through footpath	CityCare	3281501	WCC_PW116061	W-valve-17 quetta st ngaio
Please call tenant on arrival. The water toby outside his garage for the property 22B Quetta Street, has been leaking since the weekend, but now is leaking quite badly, a 10L bucket could fill in 5minutes. Please attend Thrusday Morning as tenant can be home to show the toby that is faulty, the toby for 22 or 22A is very close to it and the water team may have already been out and fixed the wrong toby.	Councils			
Mark out, for 3 Quetta St, Ngaio (2x new water connections)	Councils			
Mark out, Quetta Street from Cockayne Road to end of Cul de sac	Councils			
Leak from toby outside number 5. Has been getting steadily worse over the past few days.	MagicBus			
Up set of steps for approx 23 Quetta minor leak	MagicBus		WCC_PWP062978	Water pipe: wcc_pwp062978
<p>Complaint, request to escalate job number 2843613. Multiple WW jobs in the system, all marked completed or cancelled.</p> <p>From customer...</p> <p>Hi,</p> <p>Can you please advise how I go about making a formal&amp;#xA0;complaint about this water leak still not being resolved?</p> <p>I received a call from Wellington water after I raise this email with WCC and was advised someone would&amp;#xA0;be here the next day this was almost 2 weeks&amp;#xA0;ago.</p> <p>I slipped over again today due to the path being very unsafe since Wellington water attempted to fix this leak only to make the path more dangerous.</p> <p>Can we please have this escalated&amp;#xA0;and resolved ASAP as this is now a major health and safety issue.</p> <p>Regards,</p> <p>█&amp;#xA0;</p>	MagicBus			
Leak detection team have attended site and found leaking toby on the footpath outside of #25. Per notes: This was not there when I went there before. The water is going straight down and is not filling up the toby box. This may be the leak that is contributing to the issues on the path outside of #23 - investigation is under ref: wcc2859379.	MagicBus			
Caller advised leaking water pipe underneath concrete accessway. Has been going for some time. Please attend and fix. Thanks	MagicBus		WCC_PW045173	Water valve: wcc_pw045173
Water leak under shared access way to 26,27,28 Quetta st, Ngaio. Leak appeared not long after the subdivision and new build on number 25, but this may be just a coincidence. Leak is now significant and is affecting drainage on all 3 properties. I contacted the council about this in early August, but have heard nothing. That was under previous ref of 2821179. Can someone please contact customer about this.	MagicBus		WCC_PWP062978	Water pipe: wcc_pwp062978
Refer to ref#:2844570. Leak on shared accessway to 26,27,28 Quetta St, Ngaio. Leak on shared accessway to 26,27,28 Quetta St, Ngaio. Hello again. Could you give me an update on this request, please? Blue markings appeared, then a couple of Wellington Water guys came last week to dig up the area but found no nothing fixable, and so patched up the hole with some tarmac (it used to be concrete). The path (which is rather steep) is now a bit dangerous to be honest - it's wet and slippy as water is dribbling continuously through the tarmac. The path does not dry out, even after a few days of no rain: it is going to be treacherous in winter if left in this state. What now?	MagicBus		WCC_PWP062978, WCC_PW045173	Wcc_pwp062978, wcc_pw045173, wcc_pwp062978, wcc_pw045173
Up set of steps for approx 23 Quetta minor leak was fixed by WW but is leaking againfrom patch	MagicBus		WCC_PW045142	Water valve: wcc_pw045142
Leaking Pipes 18 QUETTA STREET, Ngaio	Maximo			
Leaking Pipes 16 Quetta Street, Ngaio	Maximo			

	Housing contractor having issues with dirty water and leaks from 14 Quetta st but he has turned up to site and there is a big square spray painted in blue with WL written on it. this looks like excavation is going to happen? Please call and discuss water issues in this area to help contractor resolve issue. He has checked private lines and they are all clear.	Councils			
--	---	----------	--	--	--



No.	Address	Council Ref ID	Water Type	Request ID	Request type	Comm Description	Date Created	Status	Resolution Date	Priority	Allocation	Responsible User
	Setsan way and cochane roadngaiowgtn	WCC	Water	WCC2527931	0	W-Enquiry to Engineer	04 Jan 2017	Completed	04 Jan 2017	P4	WWL	
	Setsan wayngaiowgtn	WCC	Water	WCC2470613	0	W-P3 Minor Leaks	25 Jun 2016	Completed	01 Jul 2016	P3	CityCare	Wellington Water
				WCC2531890	0	W-P3 Non Urgent Fault	18 Jan 2017	Cancelled	18 Jan 2017	P3	CityCare	City Care - Water
	1 setsan wayngaiowgtn	WCC	Water	WCC2275329	0	W-P2 Major Leaks	24 Aug 2014	Completed	02 Sep 2014	P2	CityCare	Capacity
				WCC2390669	0	W-P3 Minor Leaks	04 Oct 2015	Completed	20 Oct 2015	P3	CityCare	Wellington Water
	1-9 setsan way wellington ngaio	WCC	Water	WCC2519268	0	W-P3 Minor Leaks	01 Dec 2016	Cancelled	01 Dec 2016	P3	CityCare	City Care - Water
	10 setsan wayngaiowgtn	WCC	Water	WCC2272788	0	W-P3 Minor Leaks	14 Aug 2014	Completed	02 Sep 2014	P3	CityCare	Capacity
	199 setsan wayngaiowgtn	WCC	Water	WCC2459451	0	W-Damage Caused By 3rd Party	19 May 2016	Completed	19 May 2016	P2	CityCare	Wellington Water
	Cockayne rd 201 cockayne road cockayne road at setsan way, wellington 6035, new zealand	WCC	Water	WCC2855692		Leaking Pipes	21 Nov 2019	Cancelled		P3	FH	FH
	Cockayne rd cockayne road at setsan way, wellington 6035, new zealand	WCC	Water	WCC2855936		Leaking Pipes	22 Nov 2019	Cancelled		P2	FH	FH
	Intersection of cockayne rd and setsan way	WCC	Water	WCC2521234	0	W-P3 Minor Leaks	07 Dec 2016	Cancelled	07 Dec 2016	P3	CityCare	City Care - Water
	Setsan way	WCC	Water	WCC2516024	0	W-P3 Minor Leaks	22 Nov 2016	Completed	30 Nov 2016	P3	CityCare	City Care - Water
	Setsan way (private) 1 setsan way ngaio wgtn	WCC	Water	WCC2885957		Leaky Connection/Meter/Toby	25 Feb 2020	Awaiting reinstatement	06 Mar 2020	P3	FH	FH
	Setsan way, ngaio	WCC	Water	WCC2503032	0	W-P3 Minor Leaks	10 Oct 2016	Completed	09 Feb 2017	P3	CityCare	City Care - Water
	Setsan way, ngaio, wellington 6035	WCC	Water	WCC2519185	0	W-P3 Minor Leaks	30 Nov 2016	Cancelled	01 Dec 2016	P3	CityCare	City Care - Water
	Setsan wayngaiowgtn	WCC	Water	WCC2472212	0	W-P3 Minor Leaks	30 Jun 2016	Cancelled	30 Jun 2016	P3	CityCare	Wellington Water
				WCC2518782	0	W-P3 Minor Leaks	29 Nov 2016	Cancelled	30 Nov 2016	P3	CityCare	City Care - Water
				WCC2520261	0	W-P3 Minor Leaks	04 Dec 2016	Cancelled	05 Dec 2016	P3	CityCare	City Care - Water

No.	Details	Data Source	ID asset	Asset ID	Asset Description
	Pot hole in middle of road by this intersection. Caused by recent water job on the street.	Councils			
	Bottom of Setsan Way where it meets Cockayne Rd minor leak from footpath near trenching works	Councils			
	Related to 2527931 and 2503032 - pot hole is still in the middle of the road and getting a lot worse caller has advised, now approx 8 inches deep. This was logged as a DH but its a private road. The pothole is being caused by the water leaking	Councils			
	Citycare recently made repairs to watermain on street outside callers address, he now has water leaking on to his property	CityCare	3240519	WCC_PWP041614	Tee-1 setsan way ngaio
	I'm sorry to say that right after the roadwork chaps concreted in the valves a the bottom of Setsan Way in Ngaio,we appear to have sprung a leak of some sort directly outside my house at #1 Setsan Way.	CityCare	3112063	WCC_PWP040464	W-pipe connection service-184 cockayne rd
	Water streaming out of crack in driveway onto road. Location on Google Map: <a href="http://maps.google.co.nz/?q=-41.252724,174.779648&amp;z=19">http://maps.google.co.nz/?q=-41.252724,174.779648&amp;z=19</a>	Councils			
	Service to main leak, driveway marked	CityCare	3240519	WCC_PW120766	Tee-1 setsan way ngaio
	Called from downer. They cut through the concrete and hit a water pipe. The toby has been turned off.	CityCare	3112066	WCC_PWP066197	W-pipe connection service-2 setsan way
	continuous water leak coming out of side of hill, onto footpath and road	MagicBus			
	Burst water pipe somewhere near the road.	MagicBus			
	█ comms for NZ Bus reported his driver seeing a water leak coming from the footpath. Has been like this for the last couple of days Please assess.	Councils			
	Leak coming from road surface.	Councils			
	Caller advised there is a strong seep of clear water coming up from underneath the driveway outside 1 Setsan Way. He says this job is completely different to the other two jobs recently logged in the area. Please assess	MagicBus		WCC_PWP019669	Wcc_pwp019669
	Small trickle of clear water coming through a crack in the concrete. It is streaming out in varying amounts. It's located on the corner of Setsan Way and Cockayne Road. Please assess.	Councils			
	What looks like a broken water pipe, at the beginning of Setsan Way	Councils			
	Water still leaking from toby near bottom of Setsan Way near Cockayne Rd not urgent	Councils			
	Water is leaking out of joint in concrete slab which was recently repaired after council work at the bottom of Setsan Way, Ngaio. The amount of water leaking is increasing and is clear, so we think it is domestic supply water.	Councils			
	Right at the base of Setsan Way, where the lane meets Cockayne road in Ngaio, lots of mains water work was done over the last 12-18 months and it's been fine until recently. We seem to have sprung a leak where those previous works were done and it's not just seepage now, there is visibly rippling water coming up from the edges of the works concrete borders and flowing into the street gutters. Perhaps some one from the water works department could come and take a look?	Councils			